

# MIAMI-DADE COUNTY SEWER DISCHARGE STANDARDS

Abstract - effective 03/16/2004

<b>Chemical, Physical or Biological</b>	<b>Characteristic</b>
Biochemical oxygen demand	145.00 lb./day and <200 mg/l(surcharge)
Total suspended solids	145.00 lb./day and <200 mg/l(surcharge)
Oil and Grease	100.00 mg/l
Dissolved Hydrocarbons	50.00 mg/l
Temperature	150°F and shall not cause the plant influent to exceed 104° (40°C) or inhibit biological activity.
pH	5.5-11.5, or capable of causing damage or hazard to structures, equipment, or personnel of the POTW.
Ammonia	100.00 mg/l
Arsenic	0.325 mg/l
Cadmium	0.187 mg/l
Chromium, total	7.60 mg/l
Copper	0.50 mg/l
Lead	0.70 mg/l
Mercury	0.01 mg/l
Molybdenum	0.40 mg/l
Manganese	1.90 mg/l
Nickel	0.39 mg/l
Selenium	0.65 mg/l
Silver	0.60 mg/l
Thallium	0.0005 mg/l
Zinc	6.80 mg/l
Cyanides, total	0.50 mg/l
Benzene	0.20 mg/l
Carbon Tetrachloride	0.22 mg/l
1,2-c-Dichloroethylene	3.75 mg/l
Tetrachloroethylene	0.125 mg/l
Trichloroethylene	0.16 mg/l
Vinyl Chloride	0.08 mg/l
Polychlorinated Biphenyls..	0.008 mg/l