



BUILDING CODE COMPLIANCE OFFICE
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

PRODUCT CONTROL NOTICE OF ACCEPTANCE

Ceco Door Products
1959 Telecom Drive
Milan TN 38358

CONTRACTOR LICENSING SECTION
(305) 375-2527 FAX (305) 375-2558

CONTRACTOR ENFORCEMENT SECTION
(305) 375-2966 FAX (305) 375-2908

PRODUCT CONTROL DIVISION
(305) 375-2902 FAX (305) 372-6339

Your application for Product Approval of:

Series "Regent" & "Omega" 18 ga. Outswing Commercial Steel Door - Impact

under Chapter 8 of the Code of Miami-Dade County governing the use of Alternate Materials and Types of Construction, and completely described herein, has been recommended for acceptance by the Miami-Dade County Building Code Compliance Office (BCCO) under the conditions specified herein.

This approval shall not be valid after the expiration date stated below. BCCO reserves the right to secure this product or material at anytime from a jobsite or manufacturer's plant for quality control testing.

If this product or material fails to perform in the approved manner, BCCO may revoke, modify, or suspend the use of such product or material immediately. BCCO reserves the right to revoke this approval, if it is determined BCCO that this product or material fails to meet the requirements of the South Florida Building Code.

The expense of such testing will be incurred by the manufacturer.

Acceptance No.: 00-0307.03

Expires: 05/14/2003

Raul Rodriguez
Chief Product Control Division

THIS IS THE COVERSHEET, SEE ADDITIONAL PAGES FOR SPECIFIC AND GENERAL CONDITIONS

BUILDING CODE & PRODUCT REVIEW COMMITTEE

This application for Product Approval has been reviewed by the BCCO and approved by the Building Code and Product Review Committee to be used in Dade County, Florida under the conditions set forth above.

Francisco J. Quintana, R.A.
Director

Miami-Dade County
Building Code Compliance Office

Approved: 06/08/2000



Ceco Door Products.

ACCEPTANCE No.: 00-0307.03

APPROVED : JUN 0 8 2000

EXPIRES : August 14, 2003

NOTICE OF ACCEPTANCE: SPECIFIC CONDITIONS

1. SCOPE

- 1.1** This **renews** the Notice of Acceptance No. 96-1217.03, which was issued on August 14, 1997. This approves a commercial steel door system, as described in Section 2 of this Notice of Acceptance, designed to comply with the South Florida Building Code (SFBC), 1994 Edition for Miami-Dade County, for the locations where the pressure requirements, as determined by SFBC Chapter 23, do not exceed the Design Pressure Rating values indicated in the approved drawings.

2. PRODUCT DESCRIPTION

- 2.1** The Series "**Regent**" & "**Omega**" 18 ga. **Outswing Commercial Steel Door (4° x 7°) with Panic Exit Device - Impact Resistant** and its components shall be constructed in strict compliance with the following documents: Drawing No **RD0088**, titled "4-0 x 7-0 Series," Sheets 1 through 7 of 7, prepared by manufacturer, dated June 1997 and revision B on February 24, 2000, bearing the Miami-Dade County Product Control approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division. These documents shall hereinafter be referred to as the approved drawings.

3. LIMITATIONS

- 3.1** This approval applies to single door units only, as shown in approved drawings

4. INSTALLATION

- 4.1** The commercial steel door system and its components shall be installed in strict compliance with the approved drawings.
- 4.2** Hurricane protection system (shutters): the installation of this unit **will not require** a hurricane protection system.

5. LABELING

- 5.1** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved".

6. BUILDING PERMIT REQUIREMENTS

- 6.1** Application for building permit shall be accompanied by copies of the following:
- 6.1.1** This Notice of Acceptance
- 6.1.2** Duplicate copies of the approved drawings, as identified in Section 2 of this Notice of Acceptance, clearly marked to show the components selected for the proposed installation.
- 6.1.3** Any other documents required by the Building Official or the South Florida Building Code (SFBC) in order to properly evaluate the installation of this system.


Manuel Perez, P.E. Product Control Examiner
Product Control Division

Ceco Door Products.


ACCEPTANCE No.: 00-0307.03

APPROVED : JUN 0 8 2000


EXPIRES : August 14, 2003

NOTICE OF ACCEPTANCE: STANDARD CONDITIONS

1. Renewal of this Acceptance (approval) shall be considered after a renewal application has been filed and the original submitted documentation, including test supporting data, engineering documents, are no older than eight (8) years.
2. Any and all approved products shall be permanently labeled with the manufacturer's name, city, state, and the following statement: "Miami-Dade County Product Control Approved", or as specifically stated in the specific conditions of this Acceptance.
3. Renewals of Acceptance will not be considered if:
 - a) There has been a change in the South Florida Building Code affecting the evaluation of this product and the product is not in compliance with the code changes;
 - b) The product is no longer the same product (identical) as the one originally approved;
 - c) If the Acceptance holder has not complied with all the requirements of this acceptance, including the correct installation of the product;
 - d) The engineer who originally prepared, signed and sealed the required documentation initially submitted is no longer practicing the engineering profession.
4. Any revision or change in the materials, use, and/or manufacture of the product or process shall automatically be cause for termination of this Acceptance, unless prior written approval has been requested (through the filing of a revision application with appropriate fee) and granted by this office.
5. Any of the following shall also be grounds for removal of this Acceptance:
 - a) Unsatisfactory performance of this product or process.
 - b) Misuse of this Acceptance as an endorsement of any product, for sales, advertising or any other purpose.
6. The Notice of Acceptance number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the Notice of Acceptance is displayed, then it shall be done in its entirety.
7. A copy of this Acceptance as well as approved drawings and other documents, where it applies, shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at all time. The engineer need not reseal the copies.
8. Failure to comply with any section of this Acceptance shall be cause for termination and removal of Acceptance.
9. This Notice of Acceptance consists of pages 1, 2 and this last page 3.



Manuel Perez, P.E. Product Control Examiner
Product Control Division

END OF THIS ACCEPTANCE



Caulk Frame Perimeter

Caulk Underneath Threshold



Tested For Water Penetration		
Design Pressure	+53 psf	-45 psf

	Dim "A"	Dim "B"
3/4" Undercut	83 1/8	3/4
3/8" Undercut	83 1/2	3/8

Sheet 2	Frame Anchor Installation
Sheet 3	Threshold Installation
Sheet 3	Weatherstrip Installation
Sheet 4	Cylindrical Lock Reinforcement
Sheet 5-6	Cross Section View
Sheet 7	Bill Of Material

MATERIAL SPECIFICATIONS:
Finish: Rust Inhibitive Primer

4-0 x 7-0 Series
Elevation Drawing

CECO DOOR PRODUCTS
Milan, Tennessee 38358

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE June 08/2009
BY Mauld
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 00-0307.03


B
2/21/00
JAR
A
7/22/97
GWS

Revised Format, Transferred
Information from NOA
Deleted (2) Drawings
Revised Sheet Numbers


ISSUE REVISIONS
DRAWN BY: GWS DATE: 6/09/97

DRAWING NUMBER:
RD0088
Sheet 1 Of 7


00-0307.03






Masonry "T" Anchor



Existing Opening Anchor Into Block



Existing Opening Anchor Into Wood Stud



NOTES:
1. SEE SHEET 7 FOR BILL OF MATERIALS

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE June 08, 2000
BY Manuel Ruiz
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 00-0307-03

B
2/24/00
JAR Revised Format, Transferred
Information from NOA

A
7/22/97
GWS Revised Sheet Number

ISSUE REVISIONS




DRAWN BY: GWS DATE: 6/09/97

DRAWING NUMBER:
RD0088
Sheet 2 of 7

MATERIAL SPECIFICATIONS:


Frame Anchor
Installation Details

CECO DOOR PRODUCTS
Milan, Tennessee 38358




Lead Anchor #10 x 1 1/2"
1 3/8" Min Embedment

Threshold: National Guard 803S




Lead Anchor #10 x 1 1/2"
1 3/8" Min Embedment

Threshold: National Guard 950S



Lead Anchor #10 x 1 1/2"
1 3/8" Min Embedment


Threshold: Pemko 2005AV



Lead Anchor #10 x 1 1/2"
1 3/8" Min Embedment

Threshold: Pemko 181AV


NOTE: 1. All thresholds shown are made from extruded aluminum with slide-in vinyl weatherstrip insert.



Weatherstrip: Pemko 303AS

NOTE:
2. LOCATION: ALONG THE ENTIRE HEAD AND JAMB PERIMETER. ATTACHED WITH THIRTY SIX (36) #8 X 3/4" PPH SMS SPACED AT 6" O/C.

NOTE: 4. See Sheet 7 For Bill of Material



Weatherstrip: National Guard 130NA

NOTE:
3. LOCATION: ALONG THE ENTIRE HEAD AND JAMB PERIMETER. ATTACHED WITH THIRTY SIX (36) #8 X 3/4" PPH SMS SPACED AT 6" O/C.

MATERIAL SPECIFICATIONS:


Threshold & Weatherstrip Installation details

CECO DOOR PRODUCTS
Milan, Tennessee 38358

APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE
DATE *June 08, 2000*
BY *Maura King*
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. *00-0307-03*



B 2/21/00 JAR	Revised Format, Transferred Information from NOA
A 7/22/97 GWS	Revised Sheet Number
ISSUE	REVISIONS
DRAWN BY: GWS	DATE: 6/09/97

RD0088
Sheet 3 Of 7




Interlocking Fold Over Tab

Frame Head



Frame Jamb



Note: 1. For Cylindrical Lock Only
 2. See Sheet 7 For Bill of Material

APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE: June 08, 2009
 BY: Manuel Perez
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 00-0307-03


B 2/24/00 JAR	Revised Format, Transferred Information from NOA
A 7/22/97 GWS	Revised Sheet Number

ISSUE		REVISIONS	
DRAWN BY:	GWS	DATE:	6/09/97
DRAWING NUMBER:		RD0088	
		Sheet 4 of 7	

MATERIAL SPECIFICATIONS:

Cylindrical Lock Reinforcement
 and "SF" Series Frame Corner
 Installation Details

CECO DOOR PRODUCTS
 Milan, Tennessee 38358



Section X-X

Note: See Sheet 7 For Bill Of Material

APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE
 DATE *June 08, 2000*
 BY *W. J. ...*
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. *00-0307-03*

B
 2/24/00
 JAR Revised Format, Transferred information from NOA

A
 7/22/97
 GWS Revised Sheet Number

ISSUE		REVISIONS	
DRAWN BY:	GWS	DATE:	6/09/97

DRAWING NUMBER:
RD0088
 Sheet 5 of 7


MATERIAL SPECIFICATIONS:

Cross Section View
 Regent Door

 **CECO DOOR PRODUCTS**
 Milan, Tennessee 38358

Section Y-Y

Concrete Slab



Section X-X

Note: See Sheet 7 For Bill Of Material

Section Y-Y

APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE *June 08, 2000*
 BY *Maudslayi*
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. *00-030703*

2/24/00 JAR	Revised Format, Transferred Information from NOA
7/22/97 GWS	Revised Sheet Number
ISSUE	REVISIONS
DRAWN BY: GWS	DATE: 6/09/97
DRAWING NUMBER: RD0088	
Sheet 6 of 7	

MATERIAL SPECIFICATIONS:

Cross Section View
 Omega Door
 CECO DOOR PRODUCTS
 Milan, Tennessee 38358