



**BUILDING CODE COMPLIANCE OFFICE**  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908

**CONTRACTOR LICENSING SECTION**  
(305) 375-2527 FAX (305) 375-2558

**CONTRACTOR ENFORCEMENT DIVISION**  
(305) 375-2966 FAX (305) 375-2908

**PRODUCT CONTROL DIVISION**  
(305) 375-2902 FAX (305) 372-6339

**PRODUCT CONTROL NOTICE OF ACCEPTANCE**

**Amarr Garage Doors**  
**5931 Grassy Creek Blvd.**  
**Winston-salem ,NC 27105**

Your application for Notice of Acceptance (NOA) of:

**Residential 2" EPS Steel Sectional Overhead Garage Door**

under Chapter 8 of the Code of Miami-Dade County governing the use of Alternate Materials and Types of Construction, and completely described herein, has been recommended for acceptance by the Miami-Dade County Building Code Compliance Office (BCCO) under the conditions specified herein.

This NOA shall not be valid after the expiration date stated below. BCCO reserves the right to secure this product or material at any time from a jobsite or manufacturer's plant for quality control testing. If this product or material fails to perform in the approved manner, BCCO may revoke, modify, or suspend the use of such product or material immediately. BCCO reserves the right to revoke this approval, if it is determined by BCCO that this product or material fails to meet the requirements of the South Florida Building Code.

The expense of such testing will be incurred by the manufacturer.

Raul Rodriguez  
Chief Product Control Division

**ACCEPTANCE NO.: 00-0614.07**  
**EXPIRES: 08/21/2003**

**THIS IS THE COVERSHEET, SEE ADDITIONAL PAGES FOR SPECIFIC AND GENERAL**  
**CONDITIONS**  
**BUILDING CODE & PRODUCT REVIEW COMMITTEE**

This application for Product Approval has been reviewed by the BCCO and approved by the Building Code and Product Review Committee to be used in Miami-Dade County, Florida under the conditions set forth above.

Francisco J. Quintana, R.A.  
Director  
Miami-Dade County  
Building Code Compliance Office

**APPROVED: 08/24/2000**

**Amarr Garage Doors.**

ACCEPTANCE No. : 00-0614.07  
APPROVED : AUG 24 2000  
EXPIRES : 08/21/2003

**NOTICE OF ACCEPTANCE: SPECIFIC CONDITIONS**

**1. SCOPE**

This renews the Notice of Acceptance No. 96-0821.05 that was issued on 08/21/97. It approves a sectional insulated steel garage door 9'-0" wide x 7'-0" through 8'-0" high, as described in Section 2 of this Notice of Acceptance (NOA), designed to comply with the South Florida Building Code, 1994 Edition for Miami-Dade County. For the locations where the pressure requirements, as determined by SFBC Chapter 23, do not exceed the Design Pressure Rating values indicated in the approved drawings.

**2. PRODUCT DESCRIPTION**

The **Amarr 9' wide Sectional Insulated Garage Door** and its components shall be constructed in strict compliance with the following documents: Drawing No. SFC-590-008, titled "Model #1200 "WeatherGuard Plus" Short Panel, Long Panel and Flush" prepared by Amarr Garage Doors, drawn & checked on 04/30/96 with last revision on 05/15/00, sheet 1 and 2 of 2. They bear the Miami-Dade County Product Control Approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division. These documents shall hereinafter be referred to as the approved drawings.

**3. LIMITATIONS**

This approval requires the manufacturer to do testing of all coils used to fabricate door panels under this Notice of Acceptance. A minimum of 2 specimens shall be cut from each coil and tensile tested according to ASTM E-8 by a Dade County approved laboratory selected and paid by the manufacturer. Every 3 months, four times a year, the manufacturer shall mail to this office: a copy of the tested reports with confirmation that the specimens were selected from coils at the manufacturer production facilities. And a notarized statement from the manufacturer that only coils with yield strength of 21,000 psi or more shall be used to make door panels for Dade County under this Notice of Acceptance.

**4. INSTALLATION**

- 4.1** The sectional steel garage door and its components shall be installed in strict compliance with the approved drawings.
- 4.2** The installation of this door does **not require** a hurricane protection system.
- 4.3** Units with dimensions equal to or smaller than those shown in the approved drawing shall qualify under this approval.

**5. LABELING**

Each door shall bear a **permanent** label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved".

**6. BUILDING PERMIT REQUIREMENTS**

- 6.1** Application for building permit shall be accompanied by copies of the following:
  - 6.1.1** This Notice of Acceptance.
  - 6.1.2** Duplicate copies of the approved drawings as identified in Section 2 of this NOA, clearly marked to show the components selected for the proposed installation.
  - 6.1.3** Any other documents required by the Building Official or the South Florida Building Code (SFBC) in order to properly evaluate the installation of this system.

  
Candido Font, PE. Sr. Product Control Examiner  
Product Control Division

**Amarr Garage Doors.**

ACCEPTANCE No. : 00-0614.07  
APPROVED : AUG 24 2000  
EXPIRES : 08/21/2003

**NOTICE OF ACCEPTANCE: SPECIFIC CONDITIONS**

1. Renewal of this Acceptance (approval) shall be considered after a renewal application has been filed and the original submitted documents, including test-supporting data, engineering documents, are no older than eight (8) years.
2. Any and all approved products shall be permanently labeled with the manufacturer's name, city, state, and the following statement: "Miami-Dade County Product Control Approval", or as specifically stated in the specific conditions of this Acceptance.
3. Renewals of Acceptance will not be considered if:
  - a. There has been a change in the South Florida Building Code affecting the evaluation of this product and the product is not in compliance with the code changes.
  - b. The product is no longer the same product (identical) as the one originally approved.
  - c. If the Acceptance holder has not complied with all the requirements of this acceptance, including the correct installation of the product.
  - d. The engineer, who originally prepared, signed and sealed the required documentation initially submitted, is no longer practicing the engineering profession.
4. Any revision or change in the materials, use, and/or manufacture of the product or process shall automatically be cause for termination of this Acceptance, unless prior written approval has been requested (through the filing of a revision application with appropriate fee) and granted by this office.
5. Any of the following shall also be grounds for removal of this Acceptance:
  - a. Unsatisfactory performance of this product or process.
  - b. Misuse of this Acceptance as an endorsement of any product, for sales, advertising or any other purposes.
6. The Notice of Acceptance number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the Notice of Acceptance is displayed, then it shall be done in its entirety.
7. A copy of this Acceptance as well as approved drawings and other documents, where it applies, shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at all time. The engineer needs not reseal the copies.
8. Failure to comply with any section of this Acceptance shall be cause for termination and removal of Acceptance.
9. This Notice of Acceptance consists of pages 1, 2 and this last page 3.

**END OF THIS ACCEPTANCE**



Candido Font, PE. Sr. Product Control Examiner  
Product Control Division



REV		DESCRIPTION OF REVISIONS	DATE	BY
F	RMS	REMOVED HEADER AND SPRING PAD BOLTS.	05/15/00	
E	AAE	Note 5. (pg 1) only list Diversiroom, (pg2) min yield 21 KSI.	12/19/96	
D	AAE	Note 2. (pg 1) ...and finished with polyester coat.	12/19/96	
C	AAE	Wood jamb Attach. (Pg 2) Note 5 and Strap Info. (Pg 1)	10/24/96	
B	AAE	Alternative Horizontal Reinforcement	06/27/96	Page 2
A	AAE	NEW DRAWING	04/30/96	

  

MAX SIZE	9" x 8"
DESIGN LOADS	+52.0 PSF -62.0 PSF
APPROVED AS COMPLYING WITH THE	SOUTH FLORIDA BUILDING CODE
DATE	April 24, 2000
BY	[Signature]
PRODUCT CONTROL DIVISION	BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO.	00-0614.07

MAY 24 2000

WOOD JAMB ATTACHMENT TO STRUCTURE

FOR ATTACHMENT OF JAMBS TO CAST IN PLACE CONCRETE, USE 3/8" DIAMETER KWIK BOLTS BY HILTI. INSTALL BOLTS A MAXIMUM OF 6" FROM EACH END AND AT 24" ON CENTER. ANCHORS MUST HAVE A MINIMUM OF 2-1/2" EMBEDMENT INTO CONCRETE. ANCHORS BY OTHER MANUFACTURERS ARE ACCEPTABLE PROVIDED MINIMUM PULLOUT CAPACITY IS 4500 POUNDS (1200 POUNDS ALLOWABLE) IN  $f_c = 2000$  PSI CONCRETE.

FOR ATTACHMENT TO HOLLOW BLOCK, USE 1/4" DIAMETER TAPCON ANCHORS BY ITW BUILDEX. INSTALL A PAIR OF ANCHORS A MAXIMUM OF 6" FROM EACH END, AND A PAIR AT 16" ON CENTER. THE PAIR OF ANCHORS SHOULD BE APPROXIMATELY 3" CENTER TO CENTER. ANCHORS MUST HAVE A MINIMUM OF 1-1/4" EMBEDMENT INTO HOLLOW BLOCK. ANCHORS BY OTHER MANUFACTURERS ARE ACCEPTABLE PROVIDED MINIMUM PULLOUT CAPACITY IS 615 POUNDS ULTIMATE (154 POUNDS ALLOWABLE).

FOR ATTACHMENT TO WOOD, USE 5/16" DIAMETER LAG BOLTS. INSTALL BOLTS HAVE A MINIMUM OF 6" FROM EACH END, AND AT 18" ON CENTER. ANCHORS MUST BE INSTALLED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS.

ALL BOLTS MUST BE INSTALLED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS.

BACK HANGER (SUPPLIED BY INSTALLERS)

HORIZONTAL ANGLE

DOOR COUNTERBALANCE SYSTEM

HORIZONTAL TRACK

