



PRODUCT CONTROL NOTICE OF ACCEPTANCE

Metal Sales Manufacturing Corporation
7800 State Road 60
Sellersburg ,IN 47172

BUILDING CODE COMPLIANCE OFFICE
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

CONTRACTOR LICENSING SECTION
(305) 375-2527 FAX (305) 375-2558

CONTRACTOR ENFORCEMENT DIVISION
(305) 375-2966 FAX (305) 375-2908

PRODUCT CONTROL DIVISION
(305) 375-2902 FAX (305) 372-6339

Your application for Notice of Acceptance (NOA) of:

Pro-Panel II Wall System

under Chapter 8 of the Code of Miami-Dade County governing the use of Alternate Materials and Types of Construction, and completely described herein, has been recommended for acceptance by the Miami-Dade County Building Code Compliance Office (BCCO) under the conditions specified herein.

This NOA shall not be valid after the expiration date stated below. BCCO reserves the right to secure this product or material at any time from a jobsite or manufacturer's plant for quality control testing. If this product or material fails to perform in the approved manner, BCCO may revoke, modify, or suspend the use of such product or material immediately. BCCO reserves the right to revoke this approval, if it is determined by BCCO that this product or material fails to meet the requirements of the South Florida Building Code.

The expense of such testing will be incurred by the manufacturer.

ACCEPTANCE NO.: 00-0628.12
EXPIRES: 07/23/2003

Raul Rodriguez
Chief Product Control Division

**THIS IS THE COVERSHEET, SEE ADDITIONAL PAGES FOR SPECIFIC AND GENERAL
CONDITIONS
BUILDING CODE & PRODUCT REVIEW COMMITTEE**

This application for Product Approval has been reviewed by the BCCO and approved by the Building Code and Product Review Committee to be used in Miami-Dade County, Florida under the conditions set forth above.

Francisco J. Quintana, R.A.
Director
Miami-Dade County
Building Code Compliance Office

APPROVED: 11/09/2000

Metal Sales Manufacturing Corporation.

ACCEPTANCE NO: 00-0628.12

APPROVED: NOV 09 2000

EXPIRES: 07/23/2003

NOTICE OF ACCEPTANCE: SPECIFIC CONDITIONS

1. SCOPE

- 1.1** This renews the Notice of Acceptance No 96-1226.01, which was issued on 07/23/97. It approves a steel wall panel as described in Section 2 of this Notice of Acceptance, designed to comply with the South Florida Building Code, (SFBC) 1994 Edition for Miami-Dade County. For the locations where the pressure requirements, as determined by SFBC Chapter 23 do not exceed the Design Pressure Rating values indicated on the approve drawings.

2. PRODUCT DESCRIPTION

- 2.1** The **Pro-Panel II Wall Panel** and its components shall be constructed in strict compliance with the following documents: Drawing No PP2DADE, titled "Pro-Panel II Dade County", prepared by Metal Sales Manufacturing Corporation, dated 09/07/00, with latest revision on 09/27/00, Sheets 1 through 9 of 9. It bears the Miami-Dade County Product Control Approval Stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division. These documents shall hereinafter be referred to as the approved drawings.

3. LIMITATIONS

- 3.1** The maximum design pressure rating is + 55.2 psf. & - 75.3 psf.

4. INSTALLATION

- 4.1** The Pro-Panel II Wall Panel shall be installed in strict compliance with the approved drawings.
4.2 The installation of this product **will not** require a hurricane protection system.

5. LABELING

- 5.1** Each panel shall bear a permanent label with the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved".

6. BUILDING PERMIT REQUIREMENTS

- 6.1** Application for Building Permit shall be accompanied by copies of the following:
- 6.1.1** This Notice of Acceptance
 - 6.1.2** Duplicate copies of the approved drawings as identified in Section 2 of this Notice of Acceptance clearly marked to show the components selected for the proposed installation.
 - 6.1.3** Any other documents required by the Building Official or the SFBC in order to properly evaluate the installation of this system.


Candido Font, PE, Sr., Product Control Examiner
Product Control Division

Metal Sales Manufacturing Corporation.


ACCEPTANCE NO.: 00-0628.12

APPROVED: NOV 09 2000

EXPIRES: 07/23/2003

NOTICE OF ACCEPTANCE STANDARD CONDITIONS

1. Renewal of this Acceptance (approval) shall be considered after a renewal application has been filed and the original submitted documentation, including test supporting data, engineering documents, are no older than eight (8) years.
2. Any and all approved products shall be permanently labeled with the manufacturer's name, city, state, and the following statement: "Miami-Dade County Product Control Approved", or as specifically stated in the specific conditions of this Acceptance.
3. Renewals of Acceptance will not be considered if:
 - a) There has been a change in the South Florida Building Code affecting the evaluation of this product and the product is not in compliance with the code changes;
 - b) The product is no longer the same product (identical) as the one originally approved;
 - c) If the Acceptance holder has not complied with all the requirements of this acceptance, including the correct installation of the product;
 - d) The engineer who originally prepared, signed and sealed the required documentation initially submitted is no longer practicing the engineering profession.
4. Any revision or change in the materials, use, and/or manufacture of the product or process shall automatically be cause for termination of this Acceptance, unless prior written approval has been requested (through the filing of a revision application with appropriate fee) and granted by this office.
5. Any of the following shall also be grounds for removal of this Acceptance:
 - a) Unsatisfactory performance of this product or process.
 - b) Misuse of this Acceptance as an endorsement of any product, for sales, advertising or any other purpose.
6. The Notice of Acceptance number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the Notice of Acceptance is displayed, then it shall be done in its entirety.
7. A copy of this Acceptance as well as approved drawings and other documents, where it applies, shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at all time. The engineer need not reseal the copies.
8. Failure to comply with any section of this Acceptance shall be cause for termination and removal of Acceptance.
9. This Notice of Acceptance consists of pages 1, 2 and this last page 3.


Candido Font, PE, Sr., Product Control Examiner
Product Control Division

END OF THIS ACCEPTANCE

Metal Sales Manufacturing Corporation.

ACCEPTANCE NO: 00-0628.12

APPROVED: NOV 09 2000

EXPIRES: 07/23/2003

NOTICE OF ACCEPTANCE: SPECIFIC CONDITIONS

EVIDENCE SUBMITTED

A DRAWINGS

- 1 Drawings prepared by Metal Sales Manufacturing Corporation, titled "Pro-Panel II Dade County", No. PP2DADE, dated 09/07/00 with latest revision on 09/27/00, Sheet 1 through 9 of 9 signed and sealed by Walter A Tillit Jr., PE.

B TEST

- 1 - Test report on Large Missile Impact test, Cyclic Wind Pressure test and Uniform Static Air Pressure test and Air Infiltration test on "26 gage Pro-Panel II Steel Wall Siding", prepared by Hurricane Test Laboratory, Inc., report No. 0103-0707-96, dated 07/24/96 & 10/09,10 & 11/96, signed and sealed by T. S. Marshall, PE.

C CALCULATIONS

- 1 Code compliance calculations, prepared by Encon Consultants, Inc., on 10/29/96, signed and sealed by Walter A Tilit Jr., PE.

D MATERIAL CERTIFICATION

- 1 Tensile test report of metal roof panel on 4 ft. clear span, prepared by Q. C. Metallurgical, Inc. on 12/06/96, signed and sealed by F. Grate, PE.
- 2 Certified test analysis No. 47327, prepared by National Steel Corporation on 02/05/96, with out signature.

E STATEMENTS

- 1 No change letter issued by Metal Sales Manufacturing Corporation on 06/02/2000, signed by J. M. Dahdah, PE.



Candido Font, PE, Sr., Product Control Examiner
Product Control Division


REVIEWED BY:

Walter A. Tillit Jr.
10/27/00

WALTER A. TILLIT JR., P.E.
STRUCTURAL ENGINEER
FL. LIC. NO. 44167



DESIGN PRESSURE RATING
+ 55.2 PSF - 75.3 PSF
LARGE MISSILE IMPACT RESISTANCE



- 1 Wall Siding - Pro-Panel II profile, 26 gauge (min.), 50ksi (min yield) steel with G-90 cladding and paint finish.
- 2 Siding Screws - #10 Woodscrew with hex head, sealing washer, type A point, corrosion resistant alloy or coating and painted to match the wall siding. Use 1-1/2" long screws to attach the siding and support members to the sheathing at the edge conditions (head, sill, jamb, and header, etc.) Install these screws at each side of the sidings major ribs at 2-1/2", 6-1/2", 2-1/2" (o.c.). Use 1" long screws to attach the siding to the sheathing field. Install these screws at one side of the sidings major ribs (at 9" o.c.)
- 3 Weather Membrane - 30# felt (ASTM D226 type II or Dade County approved equal). Membrane edge laps must be oriented to shed water and must be 4" wide (min). Attach the weather membrane to the sheathing with Dade County approved felt nails. Install the nails at 6" o.c. along the edges and laps. Install the nails on a 12" grid in the membrane field.
- 4 Sheathing - 5/8" thick (19/32" min) CDX grade plywood. Attach the plywood to the 2 x wood framing members (head and sill plates, jambs, headers, girts and studs etc.) with 8d ring shank nails at 6" o.c..
- 5 Building Structures - the building structure must be designed to conform to the requirements of the South Florida Building Code and must be designed to accommodate the Dade County Approved Pro-Panel II wall system as described on the following section of details.


- 6 Splash Board (optional) - wood or masonry. The following wall framing members must be sized and connected to the building structurals as necessary to conform to the requirements of the South Florida Building code and must be designed to conform to the requirements of the Dade County Approved Pro-Panel II Wall systems as described on the following section of details.
- 7 Jamb - 2 x wood member, #2 southern pine.
- 8 Sill or Head plate - 2 x wood member, #2 southern pine.
- 9 Girts (for horizontal support construction) 2 x wood member, #2 southern pine.
- 10 Studs (for vertical support construction) 2 x wood member, #2 southern pine.
- 11 Rake and Eave trim - 26 gauge (min) steel with G-90 cladding and paint finish.
- 12 Jamb Trim - 26 gauge (min) steel with G-90 cladding and paint finish.
- 13 Jamb Flashing - 26 gauge (min) steel with G-90 cladding and paint finish.
- 14 Corner Trim - 26 gauge (min) steel with G-90 cladding and paint finish.
- 15 Head Trim - 26 gauge (min) steel with G-90 cladding and paint finish.
- 16 Sill Trim - 26 gauge (min) steel with G-90 cladding and paint finish.
- 17 Closures - closed cell, cross linked, polyethylene foam closure strip, die cut to fit panel profile.
- 18 Sealant - Industrial grade, one part, solvent based urethane, elastimeric sealant.
- 19 Ends shall be closed with 1" thick closed cell polyethylene foam closure strips die cut to fit the metal panel profile.

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE November 09, 2000
BY [Signature]
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 00-062812

DRAWING NUMBER: PP2/DADA	SALES PERSON	SCALE: None	SALES OFFICE: Technical Services	DATE	9/27/00	DESCRIPTION	Revisions per Dade County
				NAME	Troy Huffman	DATE	9/7/00
				DRAWN	Troy Huffman		
				CHECKED	John Dahdah		
				APPROVED	John Dahdah		
				DATE:	9/7/00		
7800 State Road 60 Sellersburg, IN 47172 PH (317) 248-2819 FAX (317) 248-0828							
						1 of 9	
						Sheet No.	

VERTICAL CONSTRUCTION

3'-0" PANEL SPACING




#10 x 1-1/2" EDGE FASTENERS @ EACH SIDE OF RIBS (2-1/2", 6-1/2", 2-1/2" O.C.)
 #10 x 1" FIELD FASTENERS @ ONE SIDE OF RIBS (9" O.C.)

REVIEWED BY:

Walter A. Tillit Jr.
 10/9/00
WALTER A. TILLIT JR., P.E.
STRUCTURAL ENGINEER
FL. LIC. NO. 44167


TYPICAL WALL ELEVATION

TILTECO
 TILLIT TESTING & ENGINEERING COMPANY
 6595 NW 36th STREET, STE. 217
 MIAMI, FLORIDA 33166




TYPICAL WALL PLAN

APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE November 09, 2000
 BY [Signature]
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 00-0628-12



TYPICAL WALL SECTION



SIDING SIDELAP DETAIL

No.	Description	Date	Revisions per Dade County
1	WALL SIDING	9/27/00	


Pro-Panel II Dade County		DATE	9/7/00
SALES OFFICE	Technical Services	NAME	Troy Huffman
DRAWN		CHECKED	John Dahdah
APPROVED		DATE	9/7/00

DRAWING NUMBER:	PP2DADE
SALESPERSON	
SCALE	None

ms metal sales
 manufacturing corporation
 7800 State Road 50
 Sellersburg, IN 47172
 Ph: (317) 246-9919 Fax: (317) 246-9928


HORIZONTAL CONSTRUCTION

APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE November 09, 2000
 BY [Signature]
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 00-0628-12



REVIEWED BY: #10 x 1-1/2" EDGE FASTENERS @ EACH SIDE OF RIBS (2-1/2", 6-1/2", 2-1/2" O.C.)
 #10 x 1" FIELD FASTENERS @ ONE SIDE OF RIBS (9" O.C.)



TYPICAL WALL ELEVATION



TYPICAL WALL SECTION

[Signature]
 10/9/00
WALTER A. TILLIT JR., P.E.
 STRUCTURAL ENGINEER
 FL. LIC. NO. 44167
TILIECO INC.
 TILLIT TESTING & ENGINEERING COMPANY
 6595 NW 36th STREET, STE. 217
 MIAMI, FLORIDA 33142

TYPICAL WALL PLAN



SIDING SIDELAP DETAIL

No.	Date	Description
1	9/27/00	Revisions per Dade County

DRAWING NUMBER	PPZDADE
SALES PERSON	None
SALES OFFICE	Technical Services
SCALE	None
DRAWN	Troy Huffman
CHECKED	[Signature]
APPROVED	John Dandah
DATE	9/7/00
DATE	9/7/00

ms metal sales
manufacturing corporation
7800 State Road 50
Sellersburg, IN 47172
Ph: (317) 248-0519 Fax: (317) 248-0628

DATE	9/7/00
3 of 9	
Sheet No.	

VERTICAL CONSTRUCTION


REVIEWED BY:

Walter A. Tillit Jr.

10/9/00
WALTER A. TILLIT JR., P.E.
STRUCTURAL ENGINEER
FL. LIC. NO. 44167




TILLIT TESTING & ENGINEERING COMPANY
 4995 NW 36th STREET, STE. 217
 MIAMI, FLORIDA 33166



SECTION A
 WALL TERMINATION

Notes: Building structurals shown as typical metal building construction. Actual building structurals may vary. Building structurals and wall framing materials are not provided with the Pro-Panel II wall system. The sizing of the wall framing members and their connections to the building structurals must be designed to meet the requirements of the South Florida Building Code and the details shown on these drawings.

HORIZONTAL CONSTRUCTION



SECTION A
 WALL TERMINATION

APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE *November 09, 2000*
 BY *[Signature]*
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 00-0628.12

DRAWING NUMBER PPZDADE	SALESPERSON	SCALE None	Pro-Panel II Dade County		
			DATE 9/7/00	NAME Troy Huffman	DATE 9/7/00
SALES OFFICE Technical Services			CHECKED John Dandah	APPROVED 9/7/00	
ms metal sales manufacturing corporation 7800 State Road 80 Sellersburg, IN 47172 Ph: (317) 246-8818 FAX: (317) 246-9889			DATE 9/7/00		
			4 of 9		
			Sheet No.		


VERTICAL CONSTRUCTION

REVIEWED BY:

Walter A. Tillit Jr.
10/9/00
WALTER A. TILLIT JR., P.E.
STRUCTURAL ENGINEER
FL. LIC. NO. 44167




TILLIT TESTING & ENGINEERING COMPANY
 6595 NW 36th STREET, STE. 217
 MIAMI, FLORIDA 33166



SECTION B
 FRAMED OPENING JAMB

HORIZONTAL CONSTRUCTION



SECTION B
 FRAMED OPENING JAMB

Notes: Building structurals shown as typical metal building construction. Actual building structurals may vary. Building structurals and wall framing materials are not provided with the Pro-Panel II wall system. The sizing of the wall framing members and their connections to the building structurals must be designed to meet the requirements of the South Florida Building Code and the details shown on these drawings.

APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE *November 09, 2000*
 BY *[Signature]*
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. *00-0628-12*

No.	Date	Description	Revisions per	Date	County
1	9/27/00				Dade

DRAWING NUMBER: PP2DADE		SALES OFFICE: Technical Services	
SALES PERSON: None		SALES OFFICE: Technical Services	
SCALE: None	DRAWN: Troy Huffman	CHECKED: John Dandah	APPROVED: John Dandah
DATE: 9/7/00			

ms metal sales manufacturing corporation 7800 State Road 60 Sellersburg, IN 47172 Ph: (317) 248-8818 FAX: (317) 248-8859	DATE: 9/7/00
	5 of 9


Sheet No.

VERTICAL CONSTRUCTION

REVIEWED BY:

Walter A. Tillit Jr.
10/9/00
WALTER A. TILLIT JR., P.E.
STRUCTURAL ENGINEER
FL. LIC. NO. 44167


TILIECO INC.
TILLIT TESTING & ENGINEERING COMPANY
6595 NW 36th STREET, STE. 217
MIAMI, FLORIDA 33166



SECTION C
WALL CORNER

Notes: Building structurals shown as typical metal building construction. Actual building structurals may vary. Building structurals and wall framing materials are not provided with the Pro-Panel II wall system. The sizing of the wall framing members and their connections to the building structurals must be designed to meet the requirements of the South Florida Building Code and the details shown on these drawings.

HORIZONTAL CONSTRUCTION



SECTION C
WALL CORNER

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE *November 07, 2000*
BY *[Signature]*
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 00-0628.12

No.	Date	Description
1	9/27/00	Revisions Per Dade County

DRAWING NUMBER:	PP2DADE
SALES PERSON:	None
SALES OFFICE:	Technical Services
DRAWN:	Troy Huffman
CHECKED:	John Dahdah
DATE:	9/7/00
APPROVED:	9/7/00

Pro-Panel II Dade County	
DRAWING NUMBER:	PP2DADE
SALES PERSON:	None
SALES OFFICE:	Technical Services
DRAWN:	Troy Huffman
CHECKED:	John Dahdah
DATE:	9/7/00
APPROVED:	9/7/00

ms metal sales manufacturing corporation 7800 State Road 80 Sellersburg, IN 47172 Ph: (317) 248-0810 Fax: (317) 248-0829


DATE:	9/7/00
6 of 9	
Sheet No.	

VERTICAL OR HORIZONTAL CONSTRUCTION

REVIEWED BY:

Walter A. Tillit Jr.
WALTER A. TILLIT JR., P.E.
STRUCTURAL ENGINEER
 FL. LIC. NO. 44167

TILECO INC.
 TILLIT TESTING & ENGINEERING COMPANY
 6525 NW 36th STREET, STE. 217
 MIAMI, FLORIDA 33166




SECTION D
 WALL HEAD AT RAKE

Notes: The rake trim and eave trim face profiles may vary to accommodate aesthetic requirements, but the functional surfaces (for attachment, sealing, watershed, etc.) must not deviate from these details.

Building structurals shown as typical metal building construction. Actual building structurals may vary. Building structurals and wall framing materials are not provided with the Pro-Panel II wall system. The sizing of the wall framing members and their connections to the building structurals must be designed to meet the requirements of the South Florida Building Code and the details shown on these drawings.

Roof is shown as a typical metal roof system. Actual roof construction may vary. Roof design and roof materials are to comply with chapter 34 of the S.F.B.C.

VERTICAL OR HORIZONTAL CONSTRUCTION



SECTION D
 WALL HEAD AT EAVE

APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE *November 09, 2000*
 BY *[Signature]*
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. *00-0628.12*

No.	Date	Description
1	9/27/00	Revisions per Dade County

DRAWING NUMBER: PP2DADE	SALES OFFICE: Technical Services
SALES PERSON: None	SALES OFFICE: Technical Services
DRAWN: Troy Huffman	CHECKED: John Dahdah
DATE: 9/7/00	APPROVED: 9/7/00

Pro-Panel II	Dade County
metal sales	manufacturing corporation
7800 State Road 60	Sellersburg, IN 47172
Ph: (317) 246-0019	Fax: (317) 246-0020


DATE: 9/7/00
7 of 9
Sheet No.

VERTICAL OR HORIZONTAL CONSTRUCTION

REVIEWED BY:


Walter A. Tillit Jr.
10/9/00
WALTER A. TILLIT JR., P.E.
STRUCTURAL ENGINEER
FL. LIC. NO. 44167

TILTECO INC.
TILLIT TESTING & ENGINEERING COMPANY
6595 NW 36th STREET, STE. 217
MIAMI, FLORIDA 33166



SECTION E
FRAMED OPENING HEADER

VERTICAL OR HORIZONTAL CONSTRUCTION



SECTION F
WALL SILL

Notes: Building structurals shown as typical metal building construction. Actual building structurals may vary. Building structurals and wall framing materials are not provided with the Pro-Panel II wall system. The sizing of the wall framing members and their connections to the building structurals must be designed to meet the requirements of the South Florida Building Code and the details shown on these drawings.

The head and sill trim's exposed lip may vary to satisfy specific building conditions or aesthetic requirements, but the functional surfaces (for attachment, sealing, watershed, etc.) must not deviate from these details.


APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE *November 09, 2000*
BY *[Signature]*
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. *00-0628.12*

DRAWING NUMBER PP2DADE	SALES PERSON	SALES OFFICE	SCALE	NAME	DATE	Description	Revisions per	Date	County	
										None
Technical Services			APPROVED:		9/7/00					
MS metal sales manufacturing corporation 7800 State Road 60 Sellersburg, IN 47172 Ph: (317) 248-0619 FAX: (317) 248-0629										
						DATE:	9/7/00			
						8 of 9				
						Sheet No.				


REVIEWED BY:

Walter A. Tillit Jr.
10/9/00
WALTER A. TILLIT JR., P.E.
STRUCTURAL ENGINEER
FL. LIC. NO. 44167


TILECO INC.
TILLIT TESTING & ENGINEERING COMPANY
6595 NW 36th STREET, STE. 217
MIAMI, FLORIDA 33166




CORNER TRIM




RAKE TRIM




EAVE TRIM



BASE TRIM OR
OPTIONAL HEAD TRIM



JAMB AND
HEAD TRIM



PRO-PANEL II PANEL PROFILE
PER ASTM A653 GRADE D, 26 GAUGE, G-90

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE *November 09, 2000*
BY *[Signature]*
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. *00-0628-12*

DRAWING NUMBER: PP2DADE	Pro-Panel II Dade County			No.	Date	Description
	SALESPERSON	SCALE	NAME	1	9/27/00	Revisions per Dade County
SALES OFFICE: Technical Services	None	DRAWN: Troy Huffman	DATE: 9/7/00			
		CHECKED:	APPROVED: John Dandah			
ms metal sales manufacturing corporation 7800 State Road 60 Sellersburg, IN 47172 Ph: (317) 246-8818 FAX: (317) 246-9829						
		DATE: 9/7/00				
		9 of 9				
		Sheet No.				