MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING

**BUILDING CODE COMPLIANCE OFFICE**
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

**CONTRACTOR LICENSING SECTION**
(305) 375-2527 FAX (305) 375-2558

**CONTRACTOR ENFORCEMENT DIVISION**
(305) 375-2966 FAX (305) 375-2908

**PRODUCT CONTROL DIVISION**
(305) 375-2902 FAX (305) 372-6339

# PRODUCT CONTROL NOTICE OF ACCEPTANCE

**Owens Corning**
**One Owens Corning Parkway**
**Toledo ,OH 43659**

Your application for Notice of Acceptance (NOA) of:
**WeatherGuard High Wind 110 Hip & Ridge**
under Chapter 8 of the Code of Miami-Dade County governing the use of Alternate Materials and Types of Construction, and completely described herein, has been recommended for acceptance by the Miami-Dade County Building Code Compliance Office (BCCO) under the conditions specified herein.

This NOA shall not be valid after the expiration date stated below. BCCO reserves the right to secure this product or material at any time from a jobsite or manufacturer's plant for quality control testing. If this product or material fails to perform in the approved manner, BCCO may revoke, modify, or suspend the use of such product or material immediately. BCCO reserves the right to revoke this approval, if it is determined by BCCO that this product or material fails to meet the requirements of the South Florida Building Code.

The expense of such testing will be incurred by the manufacturer.

**ACCEPTANCE NO.: 00-1121.02**
**EXPIRES: 01/11/2006**

Raul Rodriguez
Chief Product Control Division

**THIS IS THE COVERSHEET, SEE ADDITIONAL PAGES FOR SPECIFIC AND GENERAL CONDITIONS**
**BUILDING CODE & PRODUCT REVIEW COMMITTEE**

This application for Product Approval has been reviewed by the BCCO and approved by the Building Code and Product Review Committee to be used in Miami-Dade County, Florida under the conditions set forth above.

Francisco J. Quintana, R.A.
Director
Miami-Dade County
Building Code Compliance Office

**APPROVED: 01/11/2001**

# PRODUCT CONTROL NOTICE OF ACCEPTANCE
# ROOFING SYSTEM APPROVAL

Product Control No: **00-1121.02**
Approval Date: **January 11, 2001**
Expiration Date: **January 11, 2006**

## 1. SCOPE

This revises Owens Corning WeatherGuard High Wind 110 Hip & Ridge as manufactured by Owens Corning described in Section 2 of this Notice of Acceptance, designed to comply with the South Florida Building Code

Category: Roofing
Sub Category: Hip & Ridge Shingles
Materials Asphalt, Fiberglass

## 2. PRODUCT DESCRIPTION

| Product | Dimensions | Test Specifications | Product Description |
|---|---|---|---|
| WeatherGuard High Wind 110 Hip & Ridge | 12" x 12" | PA 110 | Prefabricated hip and ridge fiberglass reinforced asphalt shingle. All shingles shall be labeled on the underside with the Miami Dade insignia. |

## 3. LIMITATIONS

**3.1** Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.

**3.2** Shall not be installed on roof mean heights in excess of 33 ft.

## 4 INSTALLATION

**4.1** Hip and Ridge shingles shall be installed in compliance with Miami-Dade County Product Control Shingle Installation Procedure No. 115.

**4.2** Flashings shall be in accordance with Section 9.3 Option "B" (Step-flashings) of Miami-Dade County Product Control Shingle Installation Procedure No. 115

**4.3** The manufacturer shall provide clearly written application instructions.

**4.4** Exposure and course layout shall be in compliance with Detail 'A', attached.

**4.5** Nailing shall be in compliance with Detail 'B', attached.

## 5 LABELING

**5.1** Shingles shall be labeled with the Miami-Dade Logo or the wording "Miami-Dade County- Product Control Approved".

## 6 BUILDING PERMIT REQUIREMENTS

**6.1** Application for building permit shall be accompanied by copies of the following:

**6.1.1** This Notice of Acceptance.

**6.1.2** Any other documents required by the Building Official or the applicable Building Code in order to properly evaluate the installation of this system.



Frank Zuloaga, RRC
Roofing Product Control Examiner

## DETAIL A

OWENS CORNING
WEATHERGUARD HIGH WIND
110 HIP & RIDGE




## DETAIL B






Frank Zuloaga, RRC
Roofing Product Control Examiner

## NOTICE OF ACCEPTANCE STANDARD CONDITIONS

1 Renewal of this Acceptance (approval) shall be considered after a renewal application has been filed and the original submitted documentation, including test supporting data, engineering documents, are no older than eight (8) years.

2 Any and all approved products shall be permanently labeled with the manufacturer's name, city, state, and the following statement: "Miami-Dade County Product Control Approved", or as specifically stated in the specific conditions of this Acceptance.

3 Renewals of Acceptance will not be considered if:

a) There has been a change in the South Florida Building Code affecting the evaluation of this product and the product is not in compliance with the code changes;

b) The product is no longer the same product (identical) as the one originally approved;

c) If the Acceptance holder has not complied with all the requirements of this acceptance, including the correct installation of the product;

d) The engineer who originally prepared, signed and sealed the required documentation initially submitted, is no longer practicing the engineering profession.

4 Any revision or change in the materials, use, and/or manufacture of the product or process shall automatically be cause for termination of this Acceptance, unless prior written approval has been requested (through the filing of a revision application with appropriate fee) and granted by this office.

5 Any of the following shall also be grounds for removal of this Acceptance:

a) Unsatisfactory performance of this product or process;

b) Misuse of this Acceptance as an endorsement of any product, for sales, advertising or any other purposes.

6 The Notice of Acceptance number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the Notice of Acceptance is displayed, then it shall be done in its entirety.

7 A copy of this Acceptance as well as approved drawings and other documents, where it applies, shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at all times. The copies need not be resealed by the engineer.

8 Failure to comply with any section of this Acceptance shall be cause for termination and removal of Acceptance.

9 This Acceptance contains pages 1 through 4.

**END OF THIS ACCEPTANCE**



Frank Zuloaga, RRC
Roofing Product Control Examiner