



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Soprema, Inc.
310 Quadral Drive
Wadsworth, OH 44281**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The BCCO (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BCCO reserves the right to revoke this acceptance, if it is determined by BCCO that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Soprema Modified Bitumen Roofing Systems Over Concrete Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA # 98-0112.02 and consists of pages 1 through 39.
The submitted documentation was reviewed by Frank Zuloaga, RRC



**NOA No.: 01-0116.03
Expiration Date: 03/01/06
Approval Date: 09/18/03
Page 1 of 39**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Modified Bitumen

Material: SBS
Deck Type: Concrete
Maximum Design Pressure -620 psf
Fire Classification: See General Limitation #1

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Sopra-G	39" x 99' (3 sq.)	ASTM D 4601	Fiberglass reinforced oxidized asphalt base sheet for bonding or mechanically attaching to substrate.
Modified Sopra-G	39" x 99' (3 sq.)	ASTM D 4601	Fiberglass reinforced oxidized asphalt base sheet for bonding or mechanically attaching to substrate.
Sopraglass 100	39" x 66' (2 sq.)	ASTM D 4601	Fiberglass reinforced oxidized asphalt base sheet for bonding or mechanically attaching to substrate.
Soprabase	39" x 99' (3 sq.)	ASTM D 6164	Oxidized asphalt, polyester reinforced base sheets. Primarily used as a mechanically attached anchor sheet. Applied in hot asphalt or cold adhesive.
Sopra IV or VI	36" x 180' (5 sq.)	ASTM D 2178 type IV or VI	Type IV or VI, fiberglass reinforced, smooth surfaced plysheet. Sopra IV or VI are used in multi-ply systems and complies with ASTM and UL standards. Applied in hot asphalt or cold adhesive.
Colvent	39" x 49' (1.5 sq.)	ASTM D 6163	Fiberglass reinforced, modified bitumen membrane with 1" wide factory applied strips on back side.
Sopra G-Vent	39" x 99' (3 sq.)	ASTM D 6163	Fiberglass reinforced, modified bitumen membrane with perforated holes.
Elastophene Sanded or Sanded 3.0	39" x 49' (1½ sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane sanded on both sides, used as a base and top ply. Applied in hot asphalt or cold adhesive.
Elastophene Sanded FR	39" x 49' (1½ sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane with fire retardants and sanded on both sides. Applied in hot asphalt or cold adhesive.



NOA No.: 01-0116.03
 Expiration Date: 03/01/06
 Approval Date: 09/18/03
 Page 2 of 39

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Elastophene HR	39" x 49' (1½ sq.)	ASTM D 6163	Fiberglass scrim reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt or cold adhesive.
Elastophene HR FR	39" x 49' (1½ sq.)	ASTM D 6163	Fiberglass scrim reinforced modified bitumen membrane with fire retardants and sanded on both sides. Applied in hot asphalt or cold adhesive.
Elastophene PS	39" x 49' (1½ sq.)	ASTM D 6163	Glass reinforced modified bitumen membrane with thermofusible plastic film for heat weld bonding to the top side; applied in hot asphalt or cold adhesive.
Elastophene Flam or Flam 2.2	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane covered on both sides with a thermofusible plastic film. Applied by heat weld.
Elastophene 180	39" x 49' (1½ sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt or cold adhesive.
Elastophene 180 PS	39" x 48' (1½ sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with thermofusible plastic film for torch bonding to the topside, used as a base sheet. Applied in hot asphalt or cold adhesive.
Elastophene GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane surfaced with colored granules. Applied in hot asphalt or cold adhesive.
Elastophene FR GR or FR+ GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane surfaced with colored granules. Applied in hot asphalt or cold adhesive.
Elastophene Flam FR GR or FR+ GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane surfaced with colored granules. Applied by heat weld.
Sopralene 180, 250 or 350	39" x 33' (1 sq.) 39" x 26' (¾ sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides, used primarily as a base ply. Applied in hot asphalt or cold adhesive.
Soprafixx, Soprafixx [S], [H], [F] and [X]	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.
Sopralene Flam 180 or 250	39" x 33' (1 sq.) 39" x 26' (¾ sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with a thermofusible plastic film on both sides. Applied by heat weld.
Sopralene 180, 250 or 350 GR or FR GR	39" x 26' (¾ sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants and surfaced with colored granules. Applied in hot asphalt or cold applied adhesive.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Sopralene Flam 180, 250 or 350 GR	39" x 26' (¾ sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane surfaced with colored granules. Applied by heat weld.
Sopralene Flam 180, 250 or 350 FR GR or FR+ GR	39" x 26' (¾ sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane surfaced with colored granules. Applied by heat weld.
Sopralast	various	ASTM D 6298	Fiberglass reinforced modified bitumen waterproof sheeting faced with aluminum, copper or stainless steel foil.
UNILAY	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane fire retardants and surfaced with colored granules. Applied by mechanical attachment.
Sopralene Stick or Flam Stick	39" x 33' (1 sq.)	ASTM D 6163	Non-woven polyester reinforced modified bitumen membrane and faced with film or sand. Applied by self –adhesive.
EPS Flam Stick	39" x 33' (1 sq.)	ASTM D 6164	Fiberglass reinforced modified bitumen membrane with fire retardants and faced with film. Applied by self –adhesive.
Colphene 1000 or 1500	39" x 33' (1 sq.) 39" x 132' (4 sq.) 39" x 66' (2.1 sq.)	ASTM D 1970	Self adhered, non-reinforced waterproofing membranes ('Peel and Stick').
Colphene FR GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane with fire retardants and surfaced with colored granules. Applied by self –adhesive. ('Peel and Stick').
Colphene HR FR GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane with fire retardants and faced with film. Applied by self –adhesive. ('Peel and Stick').
Sopratape 606	5" wide		Bituminous tape for sealing of side and head laps.
Sopramastic 200 or SBS Mastic	17 oz. pouch or 10.4 oz cartridge		Caulking compound.
Elastocol 500 and 600c		ASTM D 41	Asphalt primers.
Sopracolle			Cold-applied adhesive used to bond membrane to prepared substrates or to other membranes.
High Velocity Insulation Adhesive II (HVIA II)		Proprietary	One part elastomeric urethane foam adhesive.
High Velocity Insulation Adhesive III (HVIA III)		Proprietary	Two part elastomeric urethane foam adhesive.



APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
ACFoam II	Polyisocyanurate foam insulation	Atlas Energy Products
ACFoam Composite	Composite polyisocyanurate insulation board	Atlas Energy Products
Gypsum	Gypsum board	generic
High Density Wood Fiberboard	Wood fiber insulation board	generic
Perlite Insulation	Perlite insulation board	generic
Dens Deck	Water resistant gypsum board	G-P Gypsum Corp.
ENRGY-2,	Polyisocyanurate foam insulation	Johns Manville
ENRGY-2 Plus, Composite, Fesco Foam	Composite Insulation board	Johns Manville
Fesco Board	Expanded mineral fiber	Johns Manville
Multi-Max FA	Polyisocyanurate foam insulation	Rmax, Inc.

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Soprema Fasteners	Fasteners for membrane or insulation attachment to wood, steel or concrete decks.		Soprema, Inc.
2.	Soprafix [X]-EL #15	Fasteners for membrane attachment to steel or concrete decks.		Soprema, Inc.
3.	Soprema Plates	Metal or plastic stress plates for use with Soprema Fasteners.	3" diameter	Soprema, Inc.
4.	SopraFixx Plates	AZ-55 Galvalume steel plate for use with the Soprafix system.	2" diameter	Soprema, Inc.
5.	Sopradisc	Galvanized metal bearing plate used for side lap attachment of Soprafix system.	2" diameter	Soprema, Inc.
6.	Soprema Isofast IF/IFT	AZ-50 Galvalume steel plate for use with the Soprafast System.	2¾" diameter	Soprema, Inc.
7.	Soprafixx/Soprafast	Stress plates for membrane securement.	3" diameter	Soprema, Inc.
8.	UNILAY Plate	Stress plates for Unilay membrane securement.	2-3/8" diameter	Soprema, Inc.



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
9.	#14, #15 Dekfast Fastener	Insulation fastener		Construction Fasteners, Inc.
10.	Omega Fastener	Stainless steel insulation fastener		Construction Fasteners, Inc.
11.	Dekfast Hex Plate	Galvalume AZ50 steel plate	2 7/8" x 3 1/4"	Construction Fasteners, Inc.
12.	Dekfast Lock Plate	Polypropylene locking plate.	3" x 3 1/4"	Construction Fasteners, Inc.
13.	#14, #15 Roofgrip Fasteners	Insulation fastener for wood, steel and concrete.		ITW Buildex Corp.
14.	AccuTrac Hextra Fasteners	Insulation fastener for wood, steel and concrete.		ITW Buildex Corp.
15.	Accutrac Plate	Galvalume square stress plate	3" square	ITW Buildex Corp.
16.	Metal Plate	Galvalume stress plate.	3" round 3" square	ITW Buildex Corp.
17.	Gearlok Plastic Plate	Polyolefin round stress plate	3.2" round	ITW Buildex Corp.
18.	Olympic Fastener #14	Insulation fastener.		Olympic Mfg. Group, Inc.
19.	Olympic CD-10	Insulation fastener.		Olympic Mfg. Group, Inc.
20.	Olympic Fluted Nail	Insulation fastener.		Olympic Mfg. Group, Inc.
21.	Olympic Standard	3" round galvalume AZ50 steel plate	3" round	Olympic Mfg. Group, Inc.
22.	Olympic Plastic	Polypropylene stress plate	3.25" round	Olympic Mfg. Group, Inc.
23.	#14 HD Insul-Fixx Fastener	Insulation fastener for wood, steel and concrete.		SFS Intec, Inc.
24.	Isofast Fasteners	Insulation fastener for wood, steel and concrete.		SFS Intec, Inc.
25.	Extra Load Fasteners #15	Fasteners for membrane attachment to steel or concrete decks.		SFS Intec, Inc.



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
26.	Insul-Fixx S Plate	3" round galvalume AZ50 steel plate	3" round	SFS Intec, Inc.
27.	Insul-Fixx P Plate	Polyethylene stress plate	3" round	SFS Intec, Inc.
28.	Isofast Plate	Square or oblong galvalume steel plates for use with Isofast fasteners		SFS Intec, Inc.
29.	#14 ES-I Fastening Systems	Insulation fastening assembly with plate.	3" round	SFS Intec, Inc.
30.	Tru-Fast Fastener	Insulation fastener for wood, steel and concrete.		The Tru-Fast Corp.
31.	Tru-Fast HD or EHD	Insulation fastener for wood, steel and concrete.		The Tru-Fast Corp.
32.	Tru-Fast MP-3	3" round galvalume AZ50 steel plate	3" round	The Tru-Fast Corp.
33.	Tru-Fast Plastic	Polypropylene plate	3" round	The Tru-Fast Corp.

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corp.	J.I. 1W8A1.AM	Wind Uplift Classification	07.15.93
	J.I. 1Z3A6.AM	Wind Uplift Classification	04.27.95
	J.I. 2D0A0.AM	Wind Uplift Classification	08.15.97
	300507	Class 4450	02.16.00
	309610	Class 4450	10.22.01
	3008869	Class 4470	03.19.01
Underwriters Laboratories, Inc.	UL Roofing Materials and Systems Directory	File No. R11436	Published Annually
		Fire Classification	
Dynatech Engineering Corp.	10.94.27	Wind Uplift	10.27.94
	2491-04.95	Wind Uplift	01.04.95
Exterior Research & Design, LLC	2003.02.97-1	Wind Uplift	02.15.97
	2003-2.04.97-1	Wind Uplift	04.15.97
	2002.07.97-1	Wind Uplift	08.15.97



NOA No.: 01-0116.03
 Expiration Date: 03/01/06
 Approval Date: 09/18/03
 Page 7 of 39

APPROVED ASSEMBLIES:

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(1): One or more layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
AC Foam II, ENRGY-2 Minimum 1.4" thick	N/A	N/A
Base or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Toprox Minimum 1" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
BP High Strength, FM-90 Traffic Top/High Density, GAFTEMP High Density, Roof Insulation Board, High Density Fiberboard, Fiber Base HD1, HD6, Structodek Minimum 1/2" thick	N/A	N/A
GAFTEMP Permalite, Fesco Board Minimum 3/4" thick	N/A	N/A
Dens Deck Minimum 1/4" thick	N/A	N/A
Fireguard, type X gypsum Minimum 5/8" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of vapor barrier or insulation. All insulation shall be adhered to the vapor barrier or primed deck in full moppings of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or in Henry III Insulbond at 2.0-2.5 gallons/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) One or more plies of Sopra-G, Modified Sopra-G, Sopraglass 40, Sopraglass 100, Sopra-IV, Sopra-VI, Soprabase, GAFGLAS #75, Perma Ply 28, JM Glasply IV or JM Glasply Premier adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.



- Ply Sheet:** (Optional, required if no base sheet used) One or more plies of Elastophene Flam, Elastophene Flam 2.2, Sopralene (180, 250 or 350) Flam, or Sopralene (180, 250 or 350) SP heat welded
or
One or more plies of of Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded or one or more plies of Type IV or Type VI ply sheets adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Membrane:** Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR, or Sopralast heat welded
or
Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Sopralene (180, 250, 350) Sanded, Elastophene FR GR or FR+ GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Surfacing:** (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.
- Maximum Design Pressure:**
- 420 psf; (for min. 1.5" thick Approved polyisocyanurate in asphalt followed by min. ¾" FescoBoard in asphalt.) (See General Limitation #9.)
 - 345 psf; (for min. 1.5" thick Approved polyisocyanurate in asphalt followed by min. ½" thick High Density Fiberboard or ¾" thick GAFTEMP Permalite in asphalt.) (See General Limitation #9.)
 - 177 psf; (for min. 1.5" thick Approved polyisocyanurate in asphalt followed by min. ¼" thick Georgia Pacific Dens Deck in asphalt.) (See General Limitation #9.)
 - 237 psf; (for min. ¼" thick Dens Deck in asphalt only.) (See General Limitation #9.)
 - 130 psf; (for min. 1.5" thick Approved polyisocyanurate in Henry III Insulbond at a rate of 2-2.5 gal./sq., followed by min. ½" thick High Density Fiberboard or ¾" thick GAFTEMP Permalite in Henry III Insulbond.) (See General Limitation #9.)
 - 60 psf; (for all other applications) (See General Limitation #9.)



Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(2): One or more layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer

**Insulation Fasteners
(Table 3)**

**Fastener
Density/ft²**

ENRGY-2

Minimum 1.4" thick

N/A

N/A

Top Insulation Layer

**Insulation Fasteners
(Table 3)**

**Fastener
Density/ft²**

Dens Deck

Minimum ¼" thick

N/A

N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of vapor barrier or insulation. All insulation shall be adhered to the vapor barrier or primed deck in full moppings of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or High Velocity Insulation Adhesive applied in continuous ¾" to 1" wide ribbons at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: One ply of Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded adhered High Velocity Insulation Adhesive at application rate of 1.5-2 gal./100 ft² or in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: None.

Membrane: Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR, or Sopralast heat welded.
(Maximum Design Pressure -120 psf, See General Limitation #9.)
Or
Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Sopralene (180, 250, 350) Sanded, Elastophene FR GR or FR+ GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered High Velocity Insulation Adhesive at application rate of 1.5-2 gal./100 ft² or in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. *(Maximum Design Pressure -112.5 psf, See General Limitation #9.)*



Surfacing:

(Optional) Install one of the following:

1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.

Maximum Design
Pressure:

See Membrane Options Above.



Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(3): One or more layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ENRGY-2		
Minimum 1.4" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of vapor barrier or insulation. All insulation shall be adhered to the vapor barrier or primed deck in full moppings of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or High Velocity Insulation Adhesive applied in continuous 3/4" to 1" wide ribbons at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: One ply of Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded adhered High Velocity Insulation Adhesive at application rate of 1.5-2 gal./100 ft² or in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: None.

Membrane: Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR, or Sopralast heat welded.

Surfacing: (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.

Maximum Design Pressure: -52.5 psf; (See General Limitation #9.)



Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(4): One or more layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Tapered ENRGY-2, Tapered AC Foam II		
Minimum ½" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Dens Deck		
Minimum ¼" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of vapor barrier or insulation. All insulation shall be adhered to the vapor barrier or primed deck in full moppings of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or High Velocity Insulation Adhesive applied in continuous ¾" to 1" wide ribbons at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: One ply of Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded adhered High Velocity Insulation Adhesive at application rate of 1.5-2 gal./100 ft² or in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: None.

Membrane: Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Sopralene (180, 250, 350) Sanded, Elastophene FR GR or FR+ GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered High Velocity Insulation Adhesive at application rate of 1.5-2 gal./100 ft² or in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.

Maximum Design Pressure:

-60 psf; (See General Limitation #9.)

-82.5 psf; (for tapered AC Foam II) (See General Limitation #9.)



NOA No.: 01-0116.03
Expiration Date: 03/01/06
Approval Date: 09/18/03
Page 13 of 39

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(5): One or more layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer (Optional)

**Insulation Fasteners
(Table 3)**

**Fastener
Density/ft²**

Tapered AC Foam II

Minimum ½" thick

N/A

N/A

Top Insulation Layer

**Insulation Fasteners
(Table 3)**

**Fastener
Density/ft²**

AC Foam II Composite

Minimum 2" thick

N/A

N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of vapor barrier or insulation. All insulation shall be adhered to the vapor barrier or primed deck in full moppings of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or High Velocity Insulation Adhesive applied in continuous ¾" to 1" wide ribbons at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: One ply of Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded adhered High Velocity Insulation Adhesive at application rate of 1.5-2 gal./100 ft² or in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: None.

Membrane: Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Sopralene (180, 250, 350) Sanded, Elastophene FR GR or FR+ GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered High Velocity Insulation Adhesive at application rate of 1.5-2 gal./100 ft² or in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.

Maximum Design Pressure: -67.5 psf; (See General Limitation #9.)



NOA No.: 01-0116.03
Expiration Date: 03/01/06
Approval Date: 09/18/03
Page 14 of 39

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(6): One or more layers of insulation adhered with approved adhesive or asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer

AC Foam II
Minimum 2" thick

Insulation Fasteners
(Table 3)

Fastener
Density/ft²

N/A

N/A

Top Insulation Layer

Dens Deck
Minimum 1/4" thick

Insulation Fasteners
(Table 3)

Fastener
Density/ft²

N/A

N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of vapor barrier or insulation. All insulation shall be adhered to the vapor barrier or primed deck in full moppings of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or Insta-Stick Adhesive applied in continuous 3/4" to 1" wide ribbons at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) One or more plies of Sopra-G, Modified Sopra-G, Sopraglass 40, Sopraglass 100, Sopra-IV, Sopra-VI, Soprabase, GAFGLAS #75, Perma Ply 28, JM Glasply IV or JM Glasply Premier adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: One or more plies of Elastophene Flam, Elastophene Flam 2.2, Sopralene (180, 250 or 350) Flam, or Sopralene (180, 250 or 350) SP heat welded
or
One or more plies of of Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded or one or more plies of Type IV or Type VI ply sheets adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR, or Sopralast heat welded
or
Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Sopralene (180, 250, 350) Sanded, Elastophene FR GR, Elastophene GR or FR+ GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.



Surfacing:

(Optional) Install one of the following:

1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.

Maximum Design

Pressure:

-90 psf; (See General Limitation #9.)



NOA No.: 01-0116.03
Expiration Date: 03/01/06
Approval Date: 09/18/03
Page 16 of 39

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(7): One or more layers of insulation adhered with approved adhesive or asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
AC Foam II, ENRGY 2 Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Dens Deck Minimum ¼" thick	N/A	N/A
High Density Wood Fiberboard Minimum ½" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of vapor barrier or insulation. All insulation shall be adhered to the vapor barrier or primed deck in full moppings of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or High Velocity Insulation Adhesive applied in continuous ¾" to 1" wide ribbons at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) One or more plies of Sopra-G, Modified Sopra-G, Sopraglass 40, Sopraglass 100, Sopra-IV, Sopra-VI, Soprabase, GAFGLAS #75, Perma Ply 28, JM Glasply IV or JM Glasply Premier adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: One or more plies of Elastophene Flam, Elastophene Flam 2.2, Sopralene (180, 250 or 350) Flam, or Sopralene (180, 250 or 350) SP heat welded
or
One or more plies of Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded or one or more plies of Type IV or Type VI ply sheets adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.



Membrane: Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR, or Sopralast heat welded or
Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Sopralene (180, 250, 350) Sanded, Elastophene FR GR, Elastophene GR or FR+ GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.

Maximum Design Pressure:
-105 psf; (for ½" thick High Density Wood Fiberboard)
(See General Limitation #9.)
-127.5 psf; (for ¼" thick Dens Deck) (See General Limitation #9.)



Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(8): One or more layers of insulation adhered with approved adhesive or asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer

AC Foam II, ENRGY 2

Minimum 1.5" thick

**Insulation Fasteners
(Table 3)**

**Fastener
Density/ft²**

N/A

N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of vapor barrier or insulation. Base insulation layer shall be adhered to the vapor barrier or primed deck in full moppings of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or OlyBond Insulation Adhesive applied at a rate of 1 gal./100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Top Insulation Layer

**Insulation Fasteners
(Table 3)**

**Fastener
Density/ft²**

Dens Deck

Minimum ¼" thick

N/A

N/A

High Density Wood Fiberboard (requires two coat application of OlyBond)

Minimum ½" thick

N/A

N/A

Note: Apply top layer of insulation in a full mopping of any approved mopping hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or OlyBond Insulation Adhesive applied at a rate of 1 gal./100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as Base Layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet:

(Optional) One or more plies of Sopra-G, Modified Sopra-G, Sopraglass 40, Sopraglass 100, Sopra-IV, Sopra-VI, Soprabase, GAFGLAS #75, Perma Ply 28, JM Glasply IV or JM Glasply Premier adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet:

One or more plies of Elastophene Flam, Elastophene Flam 2.2, Sopralene (180, 250 or 350) Flam, or Sopralene (180, 250 or 350) SP heat welded or

One or more plies of of Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded or one or more plies of Type IV or Type VI ply sheets adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.



Membrane: Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR, or Sopralast heat welded or
Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Sopralene (180, 250, 350) Sanded, Elastophene FR GR or FR+ GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.

Maximum Design Pressure: -217.5 psf; (for ½” thick High Density Wood Fiberboard)
(See General Limitation #9.)
-232.5 psf; (for ¼” thick Dens Deck) (See General Limitation #9.)



Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type B(1): Base layer of insulation mechanically fastened, optional top layer adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ENRGY-2, PSI-25 Minimum 1.4" thick	1, 9, 13, 18, 19, 20, 23, 29 or 31	1:2.67 ft²
AC Foam II, Multi-Max FA Minimum 1.5" thick	1, 9, 13, 18, 19, 20, 23, 29 or 31	1:2 ft²
ACFoam II, ENRGY-2, PSI-25, Multi-Max FA Minimum 2" thick	1, 9, 13, 18, 19, 20, 23, 29 or 31	1:4 ft²
ACFoam Composite, ENRGY-2 Composite, ENRGY-2 Plus, Thermarroof Composite Minimum 1.5" thick	1, 9, 13, 18, 19, 20, 23, 29 or 31	1:4 ft²
Toprox Minimum 1" thick	1 or 18	1:2.4 ft²
Dens Deck Minimum ¼" thick	1, 9, 18 or 23	1:4 ft²
Fireguard Minimum 5/8" thick	1, 9, 18 or 23	1:4 ft²
GAFTEMP Permalite, Fesco Board Minimum ¾" thick	9	1:2 ft²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

(Optional) Middle Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EPS Board - For use between Dens Deck or Fireguard base layer and Approved wood fiber top layer only. Minimum 1" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
BP High Strength, FM-90 Traffic Top/High Density, GAFTEMP High Density, Roof Insulation Board, High Density Fiberboard, Fiber Base HD1, HD6, Structodek Minimum ½" thick	N/A	N/A



Membrane: Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR, or Sopralast heat welded or
Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Sopralene (180, 250, 350) Sanded, Elastophene FR GR or FR+ GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.

Maximum Design Pressure: -67.5 psf; (Min. ¾" thick Approved Perlite in asphalt) (See General Limitation #7.)
-75 psf; (Min. ½" thick Approved High Density Fiberboard in asphalt) (See General Limitation #7.)



GAFTEMP Permalite, Fesco Board

Minimum 3/4" thick	N/A	N/A
Dens Deck		
Minimum 1/4" thick	N/A	N/A
Fireguard, type X gypsum		
Minimum 5/8" thick	N/A	N/A
Fireguard, type X gypsum		
Minimum 1" thick	N/A	N/A

Note: Apply optional top layer of insulation shall be adhered with approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as the base layer shall only be used as the base layer with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

- Base Sheet:** (Optional) One or more plies of Sopra-G, Modified Sopra-G, Sopraglass 40, Sopraglass 100, Sopra-IV, Sopra-VI, Soprabase, GAFGLAS #75, Perma Ply #28, JM Glasply IV or JM Glasply Premier adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Ply Sheet:** (Optional, required if no base sheet used) One or more plies of Elastophene Flam, Elastophene Flam 2.2, Sopralene (180, 250 or 350) Flam, or Sopralene (180, 250 or 350) SP heat welded
or
One or more plies of of Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded or one or more plies of Type IV or Type VI ply sheets adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Membrane:** Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR, or Sopralast Alu heat welded
or
Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Sopralene (180, 250, 350) Sanded, Elastophene FR GR or FR+ GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Surfacing:** (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.
- Maximum Design Pressure:** -52.5 psf; (See General Limitation #9.)



Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type B(2): Base layer of insulation mechanically fastened, optional top layer adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
AC Foam II, ENRGY-2, PSI-25 Minimum 1.5" thick	1, 9, 10, 13, 14, 18, 20, 23, 29 or 30	1:1.33 ft²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
BP High Strength, FM-90 Traffic Top/High Density, GAFTEMP High Density, Roof Insulation Board, High Density Fiberboard, Fiber Base HD1, HD6, Structodek Minimum 1/2" thick	N/A	N/A
GAFTEMP Permalite, Fesco Board Minimum 3/4" thick	N/A	N/A

Note: Apply optional top layer of insulation shall be adhered with approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as the base layer shall only be used as the base layer with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Base Sheet: (Optional) One or more plies of Sopra-G, Modified Sopra-G, Sopraglass 40, Sopraglass 100, Sopra-IV, Sopra-VI, Soprabase, GAFGLAS #75, Perma Ply 28, JM Glasply IV or Glasply Premier adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: One or more plies of of Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene HP, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded or one or more plies of Type IV or Type VI ply sheets adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.



Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type C: All layers of insulation simultaneously attached.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
AC Foam II, ENRGY-2, PSI-25, Multi-Max FA Minimum 1.4" thick	N/A	N/A
Dens Deck Minimum 1/4" thick	N/A	N/A
Fireguard, type X gypsum Minimum 5/8" thick	N/A	N/A
Toprox Minimum 1" thick	N/A	N/A
GAFTEMP Permalite, Fesco Board Minimum 3/4" thick	N/A	N/A

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam Composite, ENRGY-2 Composite, ENRGY-2 Plus, ENRGY-2, PSI-25, Therमारoof Composite Minimum 1.5" thick	1, 9, 13, 18, 19, 20, 23, 29 or 31	1:4 ft ²
Toprox Minimum 1" thick	1 or 18	1:2.4 ft ²
Dens Deck Minimum 1/4" thick	1, 9, 18,19, 20 or 23	1:4 ft ²
Fireguard Minimum 5/8" thick	1, 9, 18,19, 20 or 23	1:4 ft ²
GAFTEMP Permalite, Fesco Board Minimum 3/4" thick	1, 9, 13, 18, 19, 20, 23, 29 or 31	1:2 ft ²
Esgard, High Density Fiberboard, GAFTEMP Fiberboard, Huebert Fiberboard Minimum 1" thick	1, 9, 13, 18, 19, 20, 23, 29 or 31	1:2 ft ²



Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. (See Roofing Application Standard RAS 117 for fastening details.)

- Base Sheet: (Optional) One or more plies of Sopra-G, Modified Sopra-G, Sopraglass 100, Sopra-IV, Sopra-VI, Soprabase, GAFGLAS #75, JM Glasbase, or JM Glasply IV adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Ply Sheet: (Optional, required if no base sheet used) One or more plies of Elastophene Flam, Elastophene Flam 2.2, Sopralene (180, 250 or 350) Flam, or Sopralene (180, 250 or 350) SP heat welded
or
One or more plies of of Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded or one or more plies of Type IV or Type VI ply sheets adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Membrane: Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR, or Sopralast Alu heat welded
or
Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Sopralene (180, 250, 350) Sanded, Elastophene FR GR or FR+ GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Surfacing: (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.
- Maximum Design Pressure: -52.5 psf; (See General Limitation #9.)



Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type D(1): All layers of insulation and base sheet simultaneously attached.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer

**Insulation Fasteners
(Table 3)**

**Fastener
Density/ft²**

**AC Foam II, ENRGY-2, Multi-Max FA
Minimum 1.4" thick**

N/A

N/A

Base or Top Insulation Layer

**Insulation Fasteners
(Table 3)**

**Fastener
Density/ft²**

**Toprox
Minimum 1" thick**

N/A

N/A

(Optional) Top Insulation Layer

**Insulation Fasteners
(Table 3)**

**Fastener
Density/ft²**

**BP High Strength, FM-90 Traffic Top/High Density, GAFTEMP High Density, Roof Insulation Board, High Density Fiberboard, Fiber Base HD1, HD6, Structodek
Minimum 1/2" thick**

N/A

N/A

**GAFTEMP Permalite, Fesco Board
Minimum 3/4" thick**

N/A

N/A

**Dens Deck
Minimum 1/4" thick**

N/A

N/A

**Fireguard, type X gypsum
Minimum 5/8" thick**

N/A

N/A

Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Base Sheet: One ply of Sopra-G, Modified Sopra-G, Sopraglass 100, GAFGLAS #75 or PermaPly 28 fastened to the deck as described below:

Fastening: Attach base sheet using CF #14 Dekfast with Hex Plates or SFS HD Insulfixx S spaced 9" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.



- Ply Sheet:** One or more plies of Elastophene Flam, Elastophene Flam 2.2, Sopralene (180, 250 or 350) Flam, or Sopralene (180, 250 or 350) SP heat welded
or
One or more plies of Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded or one or more plies of Type IV or Type VI ply sheets adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Membrane:** Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR, or Sopralast heat welded
or
Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Sopralene (180, 250, 350) Sanded, Elastophene FR GR or FR+ GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Surfacing:** (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.
- Maximum Design Pressure:** -60 psf; (See General Limitation #9.)



Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type D(2): All layers of insulation and base sheet simultaneously attached.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
AC Foam II, ENRGY-2, Multi-Max FA Minimum 1.5" thick	N/A	N/A
Toprox Minimum 2" thick	N/A	N/A
(Optional) Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
BP High Strength, FM-90 Traffic Top/High Density, GAFTEMP High Density, Roof Insulation Board, High Density Fiberboard, Fiber Base HD1, HD6, Structodek Minimum 1/2" thick	N/A	N/A
GAFTEMP Permalite, Fesco Board Minimum 3/4" thick	N/A	N/A
Dens Deck Minimum 1/4" thick	N/A	N/A
Fireguard, type X gypsum Minimum 5/8" thick	N/A	N/A

Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Base Sheet: One ply of Soprafix, Soprafix [S], Soprafix [X], Soprafix [H], Sopralene 180 Flam or Elastophene 180 Flam 2.5 mm fastened to the deck as described below:



- Fastening #1: Attach base sheet using HD Insulfixx or SOPREMA #14 fasteners with Soprafix 2" Round Barbed Plates spaced 18" o.c. in a 4" wide heat welded or bituminous taped seam.
(Maximum Design Pressures –45 psf; See General Limitation #9.)
- Fastening #2: Attach base sheet using HD Insulfixx or SOPREMA #14 fasteners with Soprafix 2" Round Barbed Plates spaced 12" o.c. in a 4" wide heat welded or bituminous taped seam.
(Maximum Design Pressures –77.5 psf; See General Limitation #9.)
- Fastening #3: Attach base sheet using HD Insulfixx S fasteners spaced 24" o.c. in the center of the sheet. Laps are heat welded. Fastener rows are stripped in with a 7" wide section of heat welded base sheet membrane.
(Maximum Design Pressures –45 psf; See General Limitation #9.)
- Fastening #4: (Except Elastophene 180 Flam 2.5 mm) Attach base sheet using SOPREMA #14 fasteners with Soprafix 2" Round Barbed Plates 12" o.c. in a 5" heat welded lap.
(Maximum Design Pressures –60 psf; See General Limitation #7.)
- Ply Sheet: (Optional) One or more plies of Elastophene Flam, Elastophene Flam 2.2, Sopralene (180, 250 or 350) Flam, or Sopralene (180, 250 or 350) SP heat welded or
One ply of Sopralene Flam Stick or Sopralene Stick self adhered. (Note: Prime sanded surfaced base Sheet.)
- Membrane: Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR, UNILAY or Sopralast heat welded
or
Colphene FR GR or Colphene HR FR GR self adhered. (Note: Prime sanded surfaced base or ply Sheet.)
- Surfacing: (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.
- Maximum Design Pressure: See Fastening Requirements above.



Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type E(1): Base sheet mechanically fastened.

All General and System Limitations apply.

Barrier: (Optional) Tritex Rocroof, loose laid

Base Sheet: One ply of Sopra-G, Modified Sopra-G, Sopraglass 100, GAFGLAS #75 or PermaPly 28 fastened to the deck as described below:

Fastening: Attach base sheet using CF #14 Dekfast with Hex Plates or SFS HD Insulfixx S spaced 9" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.

Ply Sheet: One or more plies of Elastophene Flam, Elastophene Flam 2.2, Sopralene (180, 250 or 350) Flam, or Sopralene (180, 250 or 350) SP heat welded
or
One or more plies of Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded or one or more plies of Type IV or Type VI ply sheets adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR, or Sopralast Alu heat welded
or
Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Sopralene (180, 250, 350) Sanded, Elastophene FR GR or FR+ GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.

Maximum Design Pressure: -45 psf (See General Limitation #9.)



Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type E(2): Base sheet mechanically fastened.

All General and System Limitations apply.

Barrier: (Optional) Tritex Rocroof, loose laid

Base Sheet: One ply of Soprafix, Soprafix [S], Soprafix [X], Soprafix [H], Sopralene 180 Flam or Elastophene 180 Flam 2.5 mm fastened to the deck as described below:

Fastening #1: Attach base sheet using HD Insulfixx or SOPREMA #14 fasteners with Soprafix 2" Round Barbed Plates spaced 18" o.c. in a 4" wide heat welded or bituminous taped seam.
(Maximum Design Pressures –45 psf; See General Limitation #9.)

Fastening #2: Attach base sheet using HD Insulfixx or SOPREMA #14 fasteners with Soprafix 2" Round Barbed Plates spaced 12" o.c. in a 4" wide heat welded or bituminous taped seam.
(Maximum Design Pressures –77.5 ps; See General Limitation #9.)

Fastening #3: Attach base sheet using HD Insulfixx S fasteners spaced 24" o.c. in the center of the sheet. Laps are heat welded. Fastener rows are stripped in with a 7" wide section of heat welded base sheet membrane.
(Maximum Design Pressures –45 psf; See General Limitation #9.)

Fastening #4: (Except Elastophene 180 Flam 2.5 mm) Attach base sheet using SOPREMA #14 fasteners with Soprafix 2" Round Barbed Plates 12" o.c. in a 5" heat welded lap.
(Maximum Design Pressures –60 psf; See General Limitation #7.)

Ply Sheet: (Optional) One or more plies of Elastophene Flam, Elastophene Flam 2.2, Sopralene (180, 250 or 350) Flam, or Sopralene (180, 250 or 350) SP heat welded or
One ply of Sopralene Flam Stick or Sopralene Stick self adhered. (Note: Prime sanded surfaced base Sheet.)

Membrane: Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR or Sopralast heat welded or
Colphene FR GR or Colphene HR FR GR self adhered. (Note: Prime sanded surfaced base or ply Sheet.)

Surfacing: (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.

Maximum Design Pressure: See Fastening Requirements above



Deck Type 3: Concrete Decks, Non-insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type F(1): Base sheet adhered to primed substrate.

All General and System Limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet.

Base Sheet: (Optional) One or more plies of Sopra-G, Modified Sopra-G, Sopraglass 40, Sopraglass 100, Sopra-IV, Sopra-VI, Soprabase, GAFGLAS #75, Perma Ply 28, JM Glasply IV or Glasply Premier adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: One or more plies of Elastophene Flam, Elastophene Flam 2.2, Sopralene (180, 250 or 350) Flam, or Sopralene (180, 250 or 350) SP heat welded
or
One or more plies of Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded or one or more plies of Type IV or Type VI ply sheets adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR, or Sopralast heat welded
or
Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Sopralene (180, 250, 350) Sanded, Elastophene FR GR or FR+ GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.

Maximum Design Pressure: -620 psf; (See General Limitation #9.)



Deck Type 3: Concrete Decks, Non-insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(2): Base sheet adhered to primed substrate.

All General and System Limitations apply.

Primer: Elastocol 600c applied to deck at a rate of 1 gal./100ft².

Base Sheet: One ply of Sopralene Flam Stick, Sopralene Stick or EPS Flam Stick, self adhered.

Ply Sheet: One or more plies of Elastophene Flam, Elastophene Flam 2.2, Sopralene (180, 250 or 350) Flam, or Sopralene (180, 250 or 350) SP heat welded
or
One or more plies of Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded or one or more plies of Type IV or Type VI ply sheets adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
or
One ply of Sopralene Flam Stick or Sopralene Stick self adhered. (Note: Prime sanded surfaced base Sheet.)

Membrane: Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR, or Sopralast heat welded
or
Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Sopralene (180, 250, 350) Sanded, Elastophene FR GR or FR+ GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
or
Colphene FR GR or Colphene HR FR GR self adhered. (Note: Prime sanded surfaced ply Sheet.)

Surfacing: (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.

Maximum Design Pressure: -67.5 psf; (See General Limitation #9.)



Deck Type 3: Concrete Decks, Non-insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type F(3): Base sheet loose laid.

All General and System Limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet.

Base Sheet: One ply of Sopra G-Vent loose laid.

Ply Sheet: One or more plies of Elastophene Flam, Elastophene Flam 2.2 or Sopralene (180, 250 or 350) Flam heat welded.

Membrane: Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR, or Sopralast heat welded.

Surfacing: (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.

Maximum Design Pressure: -157.5 psf; (See General Limitation #9.)



Deck Type 3: Concrete Decks, Non-insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(4): Base sheet loose laid.

All General and System Limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet.

Base Sheet: One ply of Sopra G-Vent loose laid.

Ply Sheet: One or more plies of Elastophene Sanded, Elastophene Sanded FR, Elastophene Sanded HR, Elastophene Sanded HR FR, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Sopralene (180, 250, 350) Sanded, Elastophene FR GR or FR+ GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.

Maximum Design Pressure: -420 psf; (See General Limitation #9.)



Deck Type 3: Concrete Decks, Non-insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type F(5): Base sheet heat welded to primed deck.

All General and System Limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet.

Base Sheet: One ply of Colvent TG heat welded.

Ply Sheet: (Optional) One or more plies of Elastophene Flam, Elastophene Flam 2.2, Sopralene (180, 250 or 350) Flam or Sopralene (180, 250 or 350) SP heat welded or
One or more plies of of Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Elastophene PS, Elastophene 180 PS, Sopralene (180, 250 or 350) PS, or Sopralene (180, 250 or 350) Sanded adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: Elastophene Flam, Elastophene 180 Flam, Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR or FR+ GR, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR or FR+ GR or Sopralast heat welded or
Elastophene Sanded, Elastophene Sanded FR, Elastophene HR, Elastophene HR FR, Elastophene 180 Sanded, Sopralene (180, 250, 350) Sanded, Elastophene FR GR or FR+ GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Optional) Install one of the following:
1. Gravel or slag at 400 lbs. or 300 lbs./sq., respectively, adhered with approved asphalt at an application rate of 60 lbs./sq.
2. Karnak 97 aluminum roof coating applied at an application rate of 1½ gal./sq.

Maximum Design Pressure: -187.5 psf; (See General Limitation #9.)



NOA No.: 01-0116.03
Expiration Date: 03/01/06
Approval Date: 09/18/03
Page 37 of 39

CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 01-0116.03
Expiration Date: 03/01/06
Approval Date: 09/18/03
Page 39 of 39