



**BUILDING CODE COMPLIANCE OFFICE**  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908

**CONTRACTOR LICENSING SECTION**  
(305) 375-2527 FAX (305) 375-2558

**CONTRACTOR ENFORCEMENT DIVISION**  
(305) 375-2966 FAX (305) 375-2908

**PRODUCT CONTROL DIVISION**  
(305) 375-2902 FAX (305) 372-6339

**PRODUCT CONTROL NOTICE OF ACCEPTANCE**

**Tropical Asphalt Products Corporation**  
1904 S. 31st Ave.  
Hallandale ,FL 33009

Your application for Notice of Acceptance (NOA) of:

**Eternalastic II**

under Chapter 8 of the Code of Miami-Dade County governing the use of Alternate Materials and Types of Construction, and completely described herein, has been recommended for acceptance by the Miami-Dade County Building Code Compliance Office (BCCO) under the conditions specified herein.

This NOA shall not be valid after the expiration date stated below. BCCO reserves the right to secure this product or material at any time from a jobsite or manufacturer's plant for quality control testing. If this product or material fails to perform in the approved manner, BCCO may revoke, modify, or suspend the use of such product or material immediately. BCCO reserves the right to revoke this approval, if it is determined by BCCO that this product or material fails to meet the requirements of the South Florida Building Code.

The expense of such testing will be incurred by the manufacturer.

Raul Rodriguez  
Chief Product Control Division

**ACCEPTANCE NO.: 01-0124.01**  
**EXPIRES: 07/05/2006**

**THIS IS THE COVERSHEET, SEE ADDITIONAL PAGES FOR SPECIFIC AND GENERAL  
CONDITIONS  
BUILDING CODE & PRODUCT REVIEW COMMITTEE**

This application for Product Approval has been reviewed by the BCCO and approved by the Building Code and Product Review Committee to be used in Miami-Dade County, Florida under the conditions set forth above.

Francisco J. Quintana, R.A.  
Director  
Miami-Dade County  
Building Code Compliance Office

**APPROVED: 07/05/2001**

**ROOFING ASSEMBLY APPROVAL**

Category: Roofing  
Sub-Category: Maintenance Coatings  
Fire Classification: See General Limitation #1

Approval Date: **July 5, 2001**  
Expiration Date: **July 5, 2006**

**1. SCOPE**

This new roofing maintenance coating system using Tropical Asphalt Products Eternalastic II, coating system used on existing roof assemblies as manufactured Tropical Asphalt Products Corporation., as described in Section 2 of this Notice of Acceptance, designed to comply with the South Florida Building Code, 1994 Edition for Miami-Dade County.

**2. PRODUCT DESCRIPTION**

<u>Manufactured by Applicant</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Eternalastic II	N/A	ASTM D 6083	Is a white single component, high performance, modified aliphatic urethane elastomeric industrial maintenance coating.

**3. LIMITATIONS**

- 3.1 Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 3.2 Eternalastic II shall not be applied in inclement weather conditions.
- 3.3 All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to BCCO upon request.
- 3.4 All approved products listed herein shall be labeled in compliance with PA 121.
- 3.5 Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
- 3.6 This maintenance coating system shall not be applied over, prepared roofing; i.e., fiber-cement shingles, quarry slate, cement or clay roof tile, metal shingles, wood shingles or shakes.
- 3.7 Eternalastic II shall be used as a roof maintenance coating system in accordance with applicable Building Code. Eternalastic II is not approved to be used as a repair or recover system.

**4. INSTALLATION**

- 4.1 Eternalastic II shall be installed in accordance with manufacturer's Product Data Sheet.
- 4.2 Substrates: Galvanized metal roofs, concrete decks, built-up roofs, and sprayed polyurethane foam.



Frank Zuloaga, RRC  
Roofing Product Control Examiner

4.3 Physical Properties of Components

Trade name: **Eternalastic II**

Application Rate: Smooth Surface Built-Up Roofing: 3gal./100 ft<sup>2</sup>  
Alligatored Built-Up Roofing 5 gal./100ft<sup>2</sup>  
Concrete 3 gal./100 ft<sup>2</sup>  
Foam 3gal./100ft<sup>2</sup>

Description: A white single component, high performance, modified aliphatic urethane elastomeric industrial maintenance. Used to protect various types of roofing surfaces.

Container Size: 2, 5 gallons. Note all cautions on container label.

5. **BUILDING PERMIT REQUIREMENTS**

5.1 Application for building permit shall be accompanied by copies of the following:

5.1.1 This Notice of Acceptance.

5.1.2 Any other documents required by the Building Official or the South Florida Building Code (SFBC) in order to properly evaluate the installation of this system.



Frank Zuloaga, RRC  
Roofing Product Control Examiner

**NOTICE OF ACCEPTANCE STANDARD CONDITIONS**

- 1 Renewal of this Acceptance (approval) shall be considered after a renewal application has been filed and the original submitted documentation, including test supporting data, engineering documents, are no older than eight (8) years.
- 2 Any and all approved products shall be permanently labeled with the manufacturer's name, city, state, and the following statement: "Miami-Dade County Product Control Approved", or as specifically stated in the specific conditions of this Acceptance.
- 3 Renewals of Acceptance will not be considered if:
  - a) There has been a change in the South Florida Building Code affecting the evaluation of this product and the product is not in compliance with the code changes;
  - b) The product is no longer the same product (identical) as the one originally approved;
  - c) If the Acceptance holder has not complied with all the requirements of this acceptance, including the correct installation of the product;
  - d) The engineer who originally prepared, signed and sealed the required documentation initially submitted, is no longer practicing the engineering profession.
- 4 Any revision or change in the materials, use, and/or manufacture of the product or process shall automatically be cause for termination of this Acceptance, unless prior written approval has been requested (through the filing of a revision application with appropriate fee) and granted by this office.
- 5 Any of the following shall also be grounds for removal of this Acceptance:
  - a) Unsatisfactory performance of this product or process;
  - b) Misuse of this Acceptance as an endorsement of any product, for sales, advertising or any other purposes.
- 6 The Notice of Acceptance number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the Notice of Acceptance is displayed, then it shall be done in its entirety.
- 7 A copy of this Acceptance as well as approved drawings and other documents, where it applies, shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at all times. The copies need not be resealed by the engineer.
- 8 Failure to comply with any section of this Acceptance shall be cause for termination and removal of Acceptance.
- 9 This Acceptance contains pages 1 through 4.

**END OF THIS ACCEPTANCE**



Frank Zuloaga, RRC  
Roofing Product Control Examiner

A. TESTS:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI□	PRI00038	ASTM D 6083	12/12/2000



Frank Zuloaga, RRC  
Roofing Product Control Examiner