



BUILDING CODE COMPLIANCE OFFICE
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

CONTRACTOR LICENSING SECTION
(305) 375-2527 FAX (305) 375-2558

CONTRACTOR ENFORCEMENT DIVISION
(305) 375-2966 FAX (305) 375-2908

PRODUCT CONTROL DIVISION
(305) 375-2902 FAX (305) 372-6339

PRODUCT CONTROL NOTICE OF ACCEPTANCE

Jeld-Wen, Inc
3250 Lakeport Drive
Klamath Falls ,OR 97601

Your application for Notice of Acceptance (NOA) of:

Jeld-wen series "Nord/Morgan" Inswing Glazed Double Wood Door w/ surface bolts

under Chapter 8 of the Code of Miami-Dade County governing the use of Alternate Materials and Types of Construction, and completely described herein, has been recommended for acceptance by the Miami-Dade County Building Code Compliance Office (BCCO) under the conditions specified herein.

This NOA shall not be valid after the expiration date stated below. BCCO reserves the right to secure this product or material at any time from a jobsite or manufacturer's plant for quality control testing. If this product or material fails to perform in the approved manner, BCCO may revoke, modify, or suspend the use of such product or material immediately. BCCO reserves the right to revoke this approval, if it is determined by BCCO that this product or material fails to meet the requirements of the South Florida Building Code.

The expense of such testing will be incurred by the manufacturer.

ACCEPTANCE NO.: 01-0206.26
EXPIRES: 09/20/2004

Raul Rodriguez
Chief Product Control Division

**THIS IS THE COVERSHEET, SEE ADDITIONAL PAGES FOR SPECIFIC AND GENERAL
CONDITIONS
BUILDING CODE & PRODUCT REVIEW COMMITTEE**

This application for Product Approval has been reviewed by the BCCO and approved by the Building Code and Product Review Committee to be used in Miami-Dade County, Florida under the conditions set forth above.

Francisco J. Quintana, R.A.
Director
Miami-Dade County
Building Code Compliance Office

APPROVED: 09/20/2001

Jeld-Wen, Inc.

ACCEPTANCE No.: 01-0206.26

APPROVED : September 20, 2001

EXPIRES : September 20, 2004

NOTICE OF ACCEPTANCE: SPECIFIC CONDITIONS

1. SCOPE

- 1.1 This approves a wood door, as described in Section 2 of this Notice of Acceptance, designed to comply with the South Florida Building Code (SFBC), 1994 Edition for Miami-Dade County, for the locations where the pressure requirements, as determined by SFBC Chapter 23, do not exceed the Design Pressure Rating values indicated in the approved drawings.

2. PRODUCT DESCRIPTION

- 2.1 The Jeld-Wen Series "Nord/Morgan" – Inswing Glazed Double Wood Door-W/ Surface bolts - and its components shall be constructed in strict compliance with the following documents: Drawing No S-2040, titled "Wood stile & rail door, Glazed 6-8/8-0 Inswing Double Doors" Sheets 1 through 7 of 7 dated 07/24/00, 04-04-01 and last revised on 08-24-01, prepared by R. W. Building Consultant Inc., bearing the Miami-Dade County Product Control approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division. These documents shall hereinafter be referred to as the approved drawings.

3. LIMITATIONS

- 3.1 This approval applies to single unit applications of Inswing double door, as shown in approved drawings In-active panel of the double door must contain surface bolts at top and bottom.
- 3.2 Unit shall be installed only at locations protected by a canopy or overhang such that the angle between the edge of canopy or overhang to sill is less than 45 degrees. Unless unit is installed in non-habitable areas where the unit and the area are designed to accept water infiltration.

4. INSTALLATION

- 4.1 The Inswing wood door and its components shall be installed in strict compliance with the approved drawings.
- 4.2 Hurricane protection system (shutters): the installation of these units **will require** a hurricane protection system

5. LABELING

- 5.1 Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved".

6. BUILDING PERMIT REQUIREMENTS

- 6.1 Application for building permit shall be accompanied by copies of the following:
- 6.1.1 This Notice of Acceptance
- 6.1.2 Duplicate copies of the approved drawings, as identified in Section 2 of this Notice of Acceptance, clearly marked to show the components selected for the proposed installation.
- 6.1.3 Any other documents required by the Building Official or the South Florida Building Code (SFBC) in order to properly evaluate the installation of this system.

Ishaq I. Chanda
Ishaq I. Chanda, P.E. Product Control Examiner
Product Control Division

Jeld-Wen, Inc.

ACCEPTANCE No.: 01-0206.26

APPROVED : September 20, 2001

EXPIRES : September 20, 2004

NOTICE OF ACCEPTANCE: STANDARD CONDITIONS

1. Renewal of this Acceptance (approval) shall be considered after a renewal application has been filed and the original submitted documentation, including test supporting data, engineering documents, are no older than eight (8) years.
2. Any and all approved products shall be permanently labeled with the manufacturer's name, city, state, and the following statement: "Miami-Dade County Product Control Approved", or as specifically stated in the specific conditions of this Acceptance.
3. Renewals of Acceptance will not be considered if:
 - a) There has been a change in the South Florida Building Code affecting the evaluation of this product and the product is not in compliance with the code changes;
 - b) The product is no longer the same product (identical) as the one originally approved;
 - c) If the Acceptance holder has not complied with all the requirements of this acceptance, including the correct installation of the product;
 - d) The engineer who originally prepared, signed and sealed the required documentation initially submitted is no longer practicing the engineering profession.
4. Any revision or change in the materials, use, and/or manufacture of the product or process shall automatically be cause for termination of this Acceptance, unless prior written approval has been requested (through the filing of a revision application with appropriate fee) and granted by this office.
5. Any of the following shall also be grounds for removal of this Acceptance:
 - a) Unsatisfactory performance of this product or process.
 - b) Misuse of this Acceptance as an endorsement of any product, for sales, advertising or any other purpose.
6. The Notice of Acceptance number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the Notice of Acceptance is displayed, then it shall be done in its entirety.
7. A copy of this Acceptance as well as approved drawings and other documents, where it applies, shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at all time. The engineer need not reseal the copies.
8. Failure to comply with any section of this Acceptance shall be cause for termination and removal of Acceptance.
9. This Notice of Acceptance consists of pages 1, 2 and this last page 3.

Ishaq I. Chanda
Ishaq I. Chanda, P.E. Product Control Examiner
Product Control Division

END OF THIS ACCEPTANCE

Jeld-Wen, Inc.

ACCEPTANCE No.: 01-0206.26

APPROVED : September 20, 2001

EXPIRES : September 20, 2004

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED
(For File ONLY. Not part of NOA.)

A. DRAWINGS

1. Manufacturer's die drawings and sections.
2. Drawing No **S-2040**, titled "Wood stile & rail door, Glazed 6-8/8-0 Inswing Double Doors" Sheets 1 through 7 of 7 dated 07/24/00, 04-04-01 and last revised on 08-24-01, prepared by R. W. Building Consultant Inc.

B. TESTS

1. Test reports on 1) Air Infiltration Test, per PA 202-94
2) Uniform Static Air Pressure Test, Loading per PA 202-94
3) Water Resistance Test, per PA 202-94
4) Forced Entry Test, per SFBC 3603.2 (b) and PA 202-94
along with marked-up drawings and installation diagram of double glazed outswing/Inswing wood doors, prepared by Certified Testing Laboratories, Test Report No. **CTLA572WA**, and **CTLA 572WC** both dated July 17 & 18, 2000 and revised dated May 04, 2001, signed and sealed by Ramesh Patel, P.E.
2. Additional structrual test report No. **CTLA-701W** along with marked-up drawings and installation diagram of fixed 18 lite glazed wood doors, prepared by Certified Testing Laboratories, dated June 08, 2001, signed and sealed by Ramesh Patel, P.E., issued by

C. CALCULATIONS

1. Anchor verification calculations dated 8-24-00, prepared, signed and sealed by Mark Fetherman, P.E.

D. MATERIAL CERTIFICATIONS

1. None

E. STATEMENTS

1. Statement letter of conformance and "No financial interest" dated December 18, 2000, signed and sealed by Mark C. Fetherman, P.E.
2. Statement letter of no financial interest, dated December 18, 2000, signed by Steve Frey, Products Testing Manager, Jeld-Wen, Inc.
3. Statement letter of compliance, as part of test reports No. **CTLA572WA**, and **572WC** dated July 17, 2000 and dated July 18, 2000 respectively, issued by Certified Testing Laboratories, signed and sealed by Ramesh Patel, P.E.
4. Statement letter issued by Jeld-wen, dated December 18, 2000, designating Rick Wright of R W Building Consultant, as representative and contact person, signed by Steve Frey.
5. Letter of explanation dated May 22, 2001, issued by Certified Testing Laboratories for test reports **CTLA-570 W**, **CTLA-570 WB**, **CTLA-570 WB** and **CTLA-572 WA**, signed by Jim Blakely.

Ishaq I. Chanda

Ishaq I. Chanda, P.E. Product Control Examiner
Product Control Division

Jeld-Wen, Inc.

ACCEPTANCE No.: 01-0206.26

APPROVED : September 20, 2001

EXPIRES : September 20, 2004

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED
(For File ONLY. Not part of NOA.)

6. Letter of explanation dated May 23, 2001, issued by Ramesh Patel, P. E., witnessing engineer Certified Testing Laboratories for test reports CTLA-570 W, CTLA-570 WB, CTLA-570 WB and CTLA-572 WA, signed and sealed by Ramesh Patel, P. E.
7. Letter of clarification for laboratory data, issued by Certified Testing Laboratories, signed by Christopher Benett (Lab Manager) for test reports CTLA-570 W, CTLA-570 WB, CTLA-570 WB and CTLA-572 WA, signed and sealed by Ramesh Patel, P. E. (witnessing engineer).

F. OTHER

1. Revised test reports CTLA-570 W, CTLA 570WA, CTLA-570 WB, CTLA-570 WC and CTLA-572 WA, issued by Certified Testing Laboratories, signed and sealed by Ramesh Patel, P. E.
2. Faxed Laboratory Worksheet data dated July 05, 2001 supplied by Certified Testing Laboratories and Lab notes provided thru manufacturer, for test reports CTLA-570 W, CTLA-570 WA, CTLA-570 WB CTLA-570 WC and CTLA-572 WA.
3. Various letter of explanations and addendum letter referenced above.
4. Manufacturing plant address of Jeld-Wen series "Nord / Morgan".
5. Manufacturing plant address of Jeld-Wen series "Nord / Morgan".
6. Glazing complies w/ASTME-1300-98.

Ishaq I. Chanda
Ishaq I. Chanda, P.E. Product Control Examiner
Product Control Division

Nord/Morgan/Nicolai Wood Door

6-8 AND 8-0 GLAZED INSWING
DOUBLE DOOR


GENERAL NOTES

1. THIS PRODUCT IS DESIGNED TO MEET THE SOUTH FLORIDA BUILDING CODE 1994 EDITION FOR MIAMI-DADE COUNTY.
2. WOOD BUCKS BY OTHERS, MUST BE ANCHORED PROPERLY TO TRANSFER LOADS TO THE STRUCTURE.
3. PRODUCT ANCHORS SHALL BE AS LISTED AND SPACED AS SHOWN ON DETAILS. ANCHOR EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.
4. MIAMI-DADE COUNTY APPROVED IMPACT RESISTANT SHUTTERS ARE REQUIRED
5. DESIGNED PRESSURE RATING SEE TABLE PAGE 1.
6. THIS SYSTEM DOES NOT MEET THE WATER REQUIREMENTS IN MIAMI-DADE COUNTY.

RESIDENTIAL STILE & RAIL WOOD DOOR (Common to all frame conditions)

Frame Construction: The head and side jambs are finger jointed ponderosa pine measuring 4.625" x 1.25". The head and side jambs are mortised, butted and joined using (3) 16GA. 2" X 1/2" crown staples at the top corners. The inswing threshold is attached to the floor.

Door Panel Construction: The panel is a stile and rail construction. The stiles and rails are constructed from solid wood of either Douglas Fir or Western Hemlock. They are laminated with a .0625" thk. wood veneer of the following species: Douglas Fir, Western Hemlock, Ponderosa Pine & Northern Red Oak. The veneer face sheet is glued to the stiles and rails. The top rail is connected to the perimeter stiles w/(2) .5" dia. min. x 4" long wooden dowels and the bottom rail is connected to the perimeter stile w/(3) .5" dia. min. x 4" long wooden dowels. The glazing is captured between the wood cap on the exterior and the wood glass stop on the interior. The panels are wet glazed using PRC 365 silicone.



ALL MODELS ARE INSWING DOORS & VIEWED FROM INTERIOR

NOTE
THE SURFACE BOLTS ARE AN OPTION ON THE ACTIVE DOOR AND ARE USED TO ACHIEVE A HIGHER PRESSURE SEE SHT. 3 SECTION 1/3 & NOTE 2 SHT. 3 FOR SURFACE BOLT OPTIONS.
(SEE DESIGN PRESSURE TABLE)

DESIGN PRESSURE RATING (INSWING DOORS) WHERE WATER INFILTRATION REQUIREMENT IS NOT NEEDED			
DOOR SIZE	W/SURFACE BOLTS ON INACTIVE PANEL	W/SURFACE BOLTS ON BOTH PANEL	
6-8	+47.0psf -47.0psf	+65.0psf -70.0psf*	
8-0	+32.0psf -32.0psf	+60.0psf -60.0psf	

*NOTE: 6-8 TRUE DMDED MUNTIN LITE DOOR PANELS CANNOT EXCEED +65.0psf -65.0psf

TABLE OF CONTENTS	
SHEET #	DESCRIPTION
1	COMMON (GENERAL NOTES, TYPICAL ELEVATION)
2	VERTICAL CROSS SECTION & B.O.M.
3	HOIZONTAL CROSS SECTIONS 1/3 & 2/3
4	ANCHORING LOCATIONS & DETAILS
5	RAIL DETAILS
6	UNIT COMPONENTS
7	DOOR MODELS

JELD-WEN, INC.
31725 HIGHWAY 97 NORTH
CHILOQUIN, OR. 97624
PH. 541.783.2057


PRODUCT: WOOD STILE & RAIL DOOR
GLAZED 6-8/8-0
INSWING DOUBLE DOOR
PART OR ASSEMBLY:
ELEVATIONS
AND GENERAL NOTES

NO.	DATE	BY	REVISIONS
1	08/24/01	TJH	GENERAL REVISION
1	04/04/01	TJH	GENERAL REVISION

RW BUILDING
CONSULTANTS, INC.
813.684.3831

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE SEPTEMBER 20, 2001
BY Ishag J. Chaudh
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 01-0206-26

DATE: 7/24/00
SCALE: N.T.S.
DWG. BY: TJH
CHK. BY: RW
DRAWING NO.: S-2040
SHEET 1 OF 7



Item	DESCRIPTION	Material
1	NORD/MORGAN/NICOLAI STILE & RAIL 6-8/8-0 WOOD DOOR (DOUGLAS FIR, WESTERN HEMLOCK, PONDEROSA PINE & NORTHERN RED OAK)	
2	HEAD JAMB (1 1/4" x 4 5/8" PONDEROSA PINE)	PINE
3	HINGE JAMB (1 1/4" x 4 5/8" PONDEROSA PINE)	PINE
4	(1) PIECE WOOD ASTRAGAL	PINE
5	INSWING ADJUSTABLE THRESHOLD (.051" WALL BY IMPERIAL)	ALUMINUM
6	#8 x 2 1/2" PHILLIPS FLATHEAD WOOD SCREW	STEEL
7	KWIKSET TITAN SERIES 400 LOCK	
8	KWIKSET TITAN SERIES 720 DEADBOLT	
9	1/4" x 2 1/2" LG. TAPCON OR ITW BUILDEX TAPCON (PER CURRENT NOA) OR ELCO TAPCON (PER CURRENT NOA)	STEEL
10	SILICONE CAULK (CR LAWRENCE 335)	SILICONE
11	NOT USED	-
12	2x WOOD BUCK	WOOD
13	1/4" MAX. SHIMS	WOOD
14	COMPRESSION WEATHERSTRIP (Q-LON QDS-650)	FOAM
15	#10 x 2" PHILLIPS FLATHEAD WOOD SCREW	STEEL
16	WOOD CAP FOR .50" THK. GLASS	PINE
17	BRAD TRIM NAIL 1 1/2" L.	STEEL
18	4" x 4" BUTT HINGE 12GA. (.089" MIN)	STEEL
19	#9 x 1" PHILLIPS FLATHEAD WOOD SCREW	STEEL
20	#8 x 2" PHILLIPS FLATHEAD WOOD SCREW	STEEL
21	SURFACE BOLT (IVES, .25" STEEL)	STEEL
22	SURFACE BOLT STRIKE PLATE (IVES, .125" STEEL)	STEEL
23	1/4" CARRIAGE BOLT x 3" LG.	STEEL
24	1/4" JAMB NUT	STEEL
25	#10 x 2 1/2" PHILLIPS FLATHEAD WOOD SCREW	STEEL
26	NOT USED	-
27	NOT USED	-
28	NOT USED	-
29	INSWING VINYL DOOR BOTTOM SWEEP	VINYL
30	WOOD CAP FOR .125" THK. GLASS	PINE
31	WOOD GLASS STOP FOR .50" THK. GLASS	PINE
32	WOOD GLASS STOP FOR .125" THK. GLASS	PINE
33	1/2" INSULATED TEMPERED GLASS (BY PPG) 1/8" TEMPERED GLASS (BY PPG)	GLASS GLASS
34	GLAZING COMPOUND (PRC 365 BY DE-SOTO INTER.)	SILICONE
35	BRAD TRIM NAIL 3/4" L.	STEEL
36	TRUE DIVIDED GLASS GLAZING STOP	WOOD

JELD-WEN, INC.
31725 HIGHWAY 97 NORTH
CHILOQUIN, OR. 97624
PH. 541.783.2057


PRODUCT: WOOD STILE & RAIL DOOR
GLAZED 6-8/8-0
INSWING DOUBLE DOOR
PART OR ASSEMBLY:
VERTICAL CROSS SECTION
& BILL OF MATERIALS

NO.	DATE	REVISIONS
2	08/24/01	GENERAL REVISION TJH
1	04/04/01	GENERAL REVISION TJH


RW BUILDING CONSULTANTS, INC.
813.684.3831

APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE
DATE SEP 20, 2001
BY Isiah J. Chavez
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 01-0206.26

DATE: 7/24/00
SCALE: 1/2" = 1"
DWG. BY: TJH
CHK. BY: RW
DRAWING NO.: S-2040
SHEET 2 OF 7



1 HORIZONTAL CROSS SECTION @ ASTRAGAL
 3 THE SURFACE BOLTS ARE AN OPTION ON THE ACTIVE DOOR TO ACHIEVE HIGHER PRESSURES SEE NOTE 2 SHEET 3 (SEE DESIGN PRESSURE TABLE)



2 HORIZONTAL CROSS SECTION
 3 @ HINGE JAMB TO BUCK

NOTES: (TYP. TO ALL FRAME CONFIGURATIONS)

1. SPACING FOR ITEM #20 (#8 x 2" SCREW) TO ATTACH THE WOOD ASTRAGAL TO THE INACTIVE DOOR IS AS FOLLOWS: FOR THE 6-8 UNIT TOP DOWN; 3", 12" & 21"; FOR THE 8-0 UNIT TOP DOWN; 3", 14", 25" & 36". THE SPACING FROM THE BOTTOM UP IS THE SAME FOR BOTH UNITS; 3", 13 3/8" & 24 1/8".
2. THE SURFACE BOLT IS INSTALLED ON BOTH THE ACTIVE AND INACTIVE DOOR, AT THE TOP AND BOTTOM. IT IS NOT SHOWN ON THE ACTIVE DOOR IN SECTION 1/3 FOR CLARITY. SURFACE BOLTS ON THE DOORS ARE AN OPTION TO ACHIEVE HIGHER DESIGN PRESSURES. SEE DESIGN PRESSURE TABLE.
3. THE THRESHOLD IS NOT ATTACHED TO THE FRAME, IT IS NOTCHED AND ATTACHED TO THE FLOOR WITH ITEM #26 1/4" x 2 3/4" TAPCON AND #10 (CR LAWRENCE 33S SILICONE CAULK). APPLY A CONTINUOUS BEAD .125" THK. x .375" W. AROUND ALL (4) OUTER EDGES WITH A MINIMUM OF (2) ROWS IN A ZIG-ZAG PATTERN IN THE MIDDLE THE ENTIRE LENGTH OF THE THRESHOLD, .125" THK. x .375" W.
4. THE TOP CORNERS OF THE DOOR FRAME, ARE STAPLED TOGETHER USING (3) 16GA. x 2" LG. x 1/2" CROWN STAPLES.
5. SPACING FOR ITEM #17 IS A MAX. OF 12" O.C.

JELD-WEN, INC.
 31725 HIGHWAY 97 NORTH
 CHILOQUIN, OR. 97624
 PH. 541.783.2057



PRODUCT:
 WOOD STILE & RAIL DOOR
 GLAZED 6-8/8-0
 INSWING DOUBLE DOOR
 PART OR ASSEMBLY:
 HORIZONTAL CROSS
 SECTIONS 1/3 & 2/3

NO.	DATE	BY	REVISIONS
2	08/24/01	TJH	GENERAL REVISION
1	04/04/01	TJH	GENERAL REVISION

RW BUILDING CONSULTANTS, INC.
 813.684.3831





APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE
 DATE SEP 20, 2001
 BY Ishaq I. Chauda
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 01-0206-26

DATE: 7/24/00
 SCALE: 1/2" = 1"
 DWG. BY: TJH
 CHK. BY: RW
 DRAWING NO.: S-2040
 SHEET 3 OF 7



8-0 ANCHORING LOCATIONS

6-8 ANCHORING LOCATIONS



DETAIL "B" SURFACE BOLT STRIKE PLATE

DETAIL "E" SURFACE BOLT STRIKE PLATE

DETAIL "D"

DETAIL "C" FOR ITEM #4

JELD-WEN, INC.
 31725 HIGHWAY 97 NORTH
 CHILOQUIN, OR. 97624
 PH. 541.783.2057


PRODUCT:
 WOOD STILE & RAIL DOOR
 GLAZED 6-8/8-0
 INSWING DOUBLE DOOR
 PART OR ASSEMBLY:
 ANCHORING LOCATIONS
 & DETAILS

NO.	DATE	REVISIONS	BY
2	08/24/01	GENERAL REVISION	TJH
1	04/04/01	GENERAL REVISION	TJH


RW BUILDING
 CONSULTANTS, INC.
 813.684.3831

APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE SEP 20, 2001
 BY: Shag I. Chanda
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 01-0206-26

DATE: 7/24/00
 SCALE: N.T.S.
 DWG. BY: TJH
 CHK. BY: RW
 DRAWING NO.: S-2040
 SHEET 4 OF 7




**.50" INSULATED TEMPERED GLASS
GLAZING DETAIL**
SCALE: 1/2" = 1"




**.125" TEMPERED GLASS
GLAZING DETAIL**
SCALE: 1/2" = 1"


NOTE:
THE MULTI-LITE DOOR PANEL
IS MADE UP OF TRUE
DIVIDED GLASS PANELS.




TRUE DIVIDED GLASS GLAZING STOP
SCALE: FULL



VERTICAL MUNTIN BAR DETAIL
SCALE: 1/2" = 1"



CENTER BAR DETAIL
SCALE: 1/2" = 1"



BOTTOM RAIL
SCALE: 1/2" = 1"


NOTE:
DOWELS ARE GLUED AND PRESSED 2.0" INTO
THE RAILS AND STILES AT PANEL ASSEMBLY.

NORD DOOR .50" WOOD
DOWEL x 4.0" LG., 3PLCS
MORGAN/NICOLAI DOOR .625" WOOD
DOWEL x 4.0" LG., 3PLCS


NORD DOOR .50" WOOD
DOWEL x 4.0" LG., 2PLCS
MORGAN/NICOLAI DOOR .625" WOOD
DOWEL x 4.0" LG., 2PLCS

DIMENSION "A" CHART	
OPENING FOR	DIM. "A"
1/8" GLASS	.152"
1/2" GLASS	.527"

NORD DOOR HOLE FOR .50" WOOD
DOWEL x 4.0" LG., 2PLCS
MORGAN/NICOLAI DOOR HOLES FOR
.625" WOOD DOWEL x 4.0" LG., 2PLCS



TOP RAIL
SCALE: 1/2" = 1"



SIDE STILE
SCALE: 1/2" = 1"

JELD-WEN, INC.
31725 HIGHWAY 97 NORTH
CHILOQUIN, OR. 97624
PH. 541.783.2057

PRODUCT:
WOOD STILE & RAIL DOOR
GLAZED 6-8/8-0
INSWING DOUBLR DOOR


PART OR ASSEMBLY:
GLAZING DETAILS,
& RAIL DETAILS.

NO.	DATE	REVISIONS	BY
2	08/24/01	GENERAL REVISION	TJH
1	04/04/01	GENERAL REVISION	TJH


RW BUILDING
CONSULTANTS, INC.
813.684.3831

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE SEP 20, 2001
BY Shas J. Claude
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 01-0206-26


DATE: 7/24/00
SCALE: AS NOTED
DWG. BY: TJH
CHK. BY: RW
DRAWING NO.: S-2040
SHEET 5 OF 7




WOOD FRAME




ADJUSTABLE INSWING THRESHOLD
.051" WALL THK.




EXTRUDED VINYL INSWING
DOOR BOTTOM SWEEP




SURFACE BOLT (IVES. MODEL 455 .25" STEEL)



(1) PIECE WOOD ASTRAGAL



4 x 4 DOOR HINGE



SURFACE BOLT STRIKE (IVES .125" STEEL)

JELD-WEN, INC.
31725 HIGHWAY 97 NORTH
CHILOQUIN, OR. 97624
PH. 541.783.2057


PRODUCT:
WOOD STILE & RAIL DOOR
GLAZED 6-8/8-0
INSWING DOUBLE DOOR
PART OR ASSEMBLY:
UNIT COMPONENTS

NO.	DATE	REVISIONS	BY
2	08/24/01	GENERAL REVISION	TJH
1	04/04/01	GENERAL REVISION	TJH


RW BUILDING
CONSULTANTS, INC.
813.684.3831

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE SEP 20, 2001
BY Ishaq I. Chayda
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 01-0206.26

DATE: 7/24/00
SCALE: N.T.S.
DWG. BY: TJH
CHK. BY: RW
DRAWING NO.: S-2040
SHEET 6 OF 7



8-0 DOOR MODELS
SEE NOTE THIS SHEET



6-8 DOOR MODELS N.T.S.
SEE NOTE THIS SHEET

NOTE:
THE MULTI-LITE DOOR PANEL
IS MADE UP OF TRUE DIVIDED
GLASS PANELS. THE MAX. DESIGN
PRESSURE FOR THE 6-8 DOORS W/TRUE
DIVIDED GLASS IS +65 psf -65 psf
SEE DESIGN PRESSURE TABLE SHT. 1.

JELD-WEN, INC.
31725 HIGHWAY 97 NORTH
CHILOQUIN, OR. 97624
PH. 541.783.2057

PRODUCT:
WOOD STILE & RAIL DOOR
GLAZED 6-8/8-0
INSWING DOUBLE DOORS
PART OR ASSEMBLY:
DOOR MODELS

NO	DATE	REVISIONS	BY
2	08/24/01	GENERAL REVISION	TJH
1	04/04/01	GENERAL REVISION	TJH

RW BUILDING
CONSULTANTS, INC.
813.684.3831

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE SEPTEMBER 20, 2001
BY Isheq J. Chauda
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 01-0206-26

DATE: 7/24/00
SCALE: N.T.S.
DWG. BY: TJH
CHK. BY: RW
DRAWING NO.: S-2040
SHEET 7 OF 7