



BUILDING CODE COMPLIANCE OFFICE
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

CONTRACTOR LICENSING SECTION
(305) 375-2527 FAX (305) 375-2558

CONTRACTOR ENFORCEMENT DIVISION
(305) 375-2966 FAX (305) 375-2908

PRODUCT CONTROL DIVISION
(305) 375-2902 FAX (305) 372-6339

PRODUCT CONTROL NOTICE OF ACCEPTANCE

G.A.F. Materials Corporation
1361 Alps Road.
Wayne ,NJ 07470

Your application for Notice of Acceptance (NOA) of:

Everguard Single Ply Roof Systems Over Wood Decks

under Chapter 8 of the Code of Miami-Dade County governing the use of Alternate Materials and Types of Construction, and completely described herein, has been recommended for acceptance by the Miami-Dade County Building Code Compliance Office (BCCO) under the conditions specified herein.

This NOA shall not be valid after the expiration date stated below. BCCO reserves the right to secure this product or material at any time from a jobsite or manufacturer's plant for quality control testing. If this product or material fails to perform in the approved manner, BCCO may revoke, modify, or suspend the use of such product or material immediately. BCCO reserves the right to revoke this approval, if it is determined by BCCO that this product or material fails to meet the requirements of the South Florida Building Code.

The expense of such testing will be incurred by the manufacturer.

ACCEPTANCE NO.: 01-0227.05
EXPIRES: 06/14/2006

Raul Rodriguez
Chief Product Control Division

**THIS IS THE COVERSHEET, SEE ADDITIONAL PAGES FOR SPECIFIC AND GENERAL
CONDITIONS
BUILDING CODE & PRODUCT REVIEW COMMITTEE**

This application for Product Approval has been reviewed by the BCCO and approved by the Building Code and Product Review Committee to be used in Miami-Dade County, Florida under the conditions set forth above.

Francisco J. Quintana, R.A.
Director
Miami-Dade County
Building Code Compliance Office

APPROVED: 06/14/2001

ROOFING ASSEMBLY APPROVAL

Category: Roofing
Sub-Category: PVC Single Ply

Approval Date: **June 14, 2001**

Deck Type: Wood
Maximum Design Pressure -45 psf
Fire Classification: See General Limitation #1

Expiration Date: **June 14, 2006**

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
EverGuard EGSR 40-100 Mil Membrane	78" x 108" 702 sf. roll	ASTMD 4434	40-100 mil thermoplastic alloy field membrane.
EverGuard EGSR 40-100 Mil Perimeter Sheet	39" x 108' 351 sf. roll	ASTM D 4434	40-100 mil thermoplastic alloy perimeter sheet.
EverGuard EGSR 40-100 Mil Membrane	52" x 108'	ASTM D 4434	40-100 mil thermoplastic alloy field membrane.
EverGuard EGSR Reinforced Flashing Membrane	6", 8", 12", 18" & 24" variable length rolls	ASTM D 4434	40-100 mil thermoplastic flashing membrane.
EverGuard UN-55 Unreinforced 55 Mil Membrane	24" x 30' LF 60 sf. Roll	ASTM D 4434	55 mil unreinforced flashing membrane
EverGuard Coated Metal	4' x 8' 4' x 10' sheets	US Commercial Standard CS-245-62	EverGuard membrane laminated 24 Ga. galvanized steel.
EverGuard EGFB Fleece Back 40-100 Mil Membrane	76" x 90" 570 sf. Roll	ASTM D 4434	40-100 mil thermoplastic alloy fleece back field membrane.
EverGuard EGFB Fleece Back 40-100 Mil Membrane	39" x 108' 351 sf. Roll	ASTM D 4434	40-100 mil thermoplastic alloy fleece back perimeter sheet.
EverGuard EGFB Fleece Back Reinforced Flashing Membrane	12", 18" & 24" variable length rolls	ASTM D 4434	40-100 mil thermoplastic alloy fleece back flashing membrane.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
EverGuard Universal Corners	4" x 4" x 4" 20 pcs. crtn.	ASTM D 4434	Prefabricated molded one piece corners.
EverGuard Boots	1" - 8" od 6 pcs. crtn.	ASTM D 4434	Premolded vent pipe boots.
EverGuard Bonding Adhesive	5 gallon pails	proprietary	Adhesive for fully adhered systems and membrane flashing.
EverGuard Membrane Plates	2" round	PA 117	Round 2" nylon reinforced seam plate.
EverGuard Membrane Plates	2" round	PA 117	Round 2" galvalume seam plate.
EverGuard Membrane Plates	2-3/8" round	PA 117	Round 2-3/8" galvalume seam plate.
EverGuard Insulation Plates	3" round	PA 117	Round 3" plastic plate.
EverGuard Insulation Plates	3" round	PA 117	Round 3" galvalume plate.
EverGuard EGIN Fasteners	1 5/8" - 8" #12	PA 117	Self tapping coated screw w/#3 Phillips head.
EverGuard EGHD Fasteners	1 1/4" - 16" #14	PA 117	Self tapping coated screw w/#3 Phillips head.
EverGuard Aluminum Termination Bar	1/8 x 1" x 10	PA 114	Lip termination bar.
EverGuard Masonry Anchors	1/4" x 1-2"	PA114(E) PA117	Masonry anchor with drive pin.
EverGuard Expansion Joint Cover	4"-8" x 50'		Low profile expansion joint cover.
EverGuard Standard Walkway	1/8" x 30" x 36"		Standard duty walkway pad.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
EverGuard Heavy Duty Walkway	1/4" x 30" x 36"		Heavy duty walkway pad.
EverGuard Isocyanurate Insulation	4' x 4', 4' x 8' various thicknesses		Polyisocyanurate insulation.

TRADE NAMES OF PRODUCTS MANUFACTURED BY OTHERS:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>	<u>Manufacturer</u>
ACFoam II	various	PA 110	Polyisocyanurate foam insulation.	Atlas (with current NOA)
ACFoam III	various	PA 110	Polyisocyanurate foam insulation.	Atlas (with current NOA)
E'NERG'Y PSI-25	various	PA 110	Polyisocyanurate foam insulation.	Johns Manville (with current NOA)
E'NRG'Y-2 Plus	various	PA 110	Polyisocyanurate foam insulation.	Johns Manville (with current NOA)
Fesco Foam	various	PA 110	Polyisocyanurate foam / Fescoboard insulation.	Johns Manville (with current NOA)
UltraGard Premier	various	PA 110	Polyisocyanurate foam insulation.	Johns Manville (with current NOA)
UltraGard Gold	various	PA 110	Polyisocyanurate foam insulation.	Johns Manville (with current NOA)
Hy-Tec	various	PA 110	Polyisocyanurate foam insulation.	Celotex Corp. (with current NOA)
Hy-Therm SP	various	PA 110	Polyisocyanurate foam insulation.	Celotex Corp. (with current NOA)
Hy-Therm AP	various	PA 110	Polyisocyanurate foam insulation	Celotex Corp. (with current NOA)



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>	<u>Manufacturer</u>
ISO 95+, ISO 95+ GL	various	PA 110	Polyisocyanurate foam insulation.	Firestone (with current NOA)
Multi-Max, Multi-Max FA	various	PA 110	Polyisocyanurate foam insulation.	Rmax, Inc. (with current NOA)
Thermarroof Plus	various	PA 110	Polyisocyanurate foam insulation.	Rmax, Inc. (with current NOA)
Ultra/M-II	various	PA 110	Polyisocyanurate foam insulation.	Homasote Co. (with current NOA)
Pyrox	various	PA 110	Polyisocyanurate foam insulation.	Apache Products Co. (with current NOA)
White Line	various	PA 110	Polyisocyanurate foam insulation.	Apache Products Co. (with current NOA)
Celotherm	various	PA 110	Perlite insulation board	Celotex (with current NOA)
Conperl	various	PA 110	Perlite insulation board	Conglas (with current NOA)
Fesco Board	various	PA 110	Perlite insulation board	Johns Manville (with current NOA)
High Density Fiber Board	various	PA 100	Wood fiber insulation.	Celotex Corp. (with current NOA)
Armor Board High Density	various	PA 110	Wood fiber insulation	Allied Signal (with current NOA)
GAFTEMP Permalite	various	PA 110	Perlite insulation board.	GAF (with current NOA)
GAFTEMP High Density Fiberboard	various	PA 110	Wood fiber insulation.	GAF (with current NOA)
Roof Insulation Board	various	PA 110	Wood fiber insulation.	Georgia Pacific (with current NOA)
Fiberbase HD1, HD6	various	PA 110	Wood fiber insulation.	Temple Inland (with current NOA)




Frank Zuloaga, RRC
Roofing Product Control Examiner

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>	<u>Manufacturer</u>
Structodek	various	PA 110	Wood fiber insulation.	Masonite (with current NOA)
Type X Gypsum	various		Fire resistant rated gypsum.	Generic
Dekfast Fasteners #12, #14 or #15	various	PA 114 PA 117	Insulation / membrane fasteners	Construction Fasteners Inc. (with current NOA)
Omega	various	PA 114 PA 117	Stainless steel insulation / membrane fasteners	Construction Fasteners Inc. (with current NOA)
HD Insul-Fixx Fastener	various	PA 114 PA 117	Insulation / membrane fasteners	SFS Stadler (with current NOA)
Insul-Fixx P	3" round	PA 114 PA 117	3" round polyethylene stress plate.	SFS Stadler (with current NOA)
Insul-Fixx S	3" round	PA 114 PA 117	3" round galvalume AZ55 stress plate.	SFS Stadler (with current NOA)
Insul-Fixx Fastener	various	PA 114 PA 117	Insulation fastener for steel and wood decks.	SFS Stadler (with current NOA)
Isofast Fasteners	various	PA 114 PA 117	Insulation / membrane fasteners	SFS Stadler (with current NOA)
Isofast Plate	various	PA 114 PA 117	Square or oblong galvalume steel plates for use with Isofast fasteners.	SFS Stadler (with current NOA)
Olympic Fastener #12 or #14	various	PA 114 PA 117	Insulation / membrane fasteners.	Olympic (with current NOA)

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corporation	J.I. 0X2A9.AM	Class 1 Concrete deck fully adhered.	06/26/93
	J.I. 1W1A9.AM	80 Mil Class I wood, steel, concrete.	09/11/93
	J.I. 1X3A6.AM	C3 Fleece Back fully adhered Class I steel concrete	10/03/93



Frank Zuloaga, RRC
Roofing Product Control Examiner

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
	J.I. 1W9A2.AM	C3 Fleece Back fully adhered Class I lightweight concrete.	06/15/93
	J.I. 1W2A0.AM	C3 Fleece Back fully adhered Class I lightweight concrete.	08/24/93
	J.I. 3W3A4.AM	C3 mechanically fastened steel, concrete.	11/22/93
	J.I. 0X8A9.AM	C3 Dual attachment Class I steel, wood, concrete.	06/25/93
	J.I. 1X6A5.AM	Solweld plate mechanically fastened Class I steel, concrete.	10/12/93
	J.I. 2W5A6.AM	C3 Fleece back fully adhered Class I steel, concrete.	06/01/93
Underwriters Laboratories	File R9834 (N)	Fire Classification	04/06/93



Frank Zuloaga, RRC
Roofing Product Control Examiner

APPROVED ASSEMBLIES

Deck Type II: Wood, Insulated, New Construction

Deck Description: 19/32" or greater plywood or wood plank

System Type C: All layers of insulation are mechanically attached to roof deck. Membrane is subsequently fully or partially adhered to insulation.

All General and System Limitations apply.

<u>Insulation</u> <u>(Optional) Base Layer</u>	<u>Fastener</u> <u>Type</u>	<u>Fastening</u> <u>Detail No.</u>	<u>Fasteners</u> <u>Per Board</u>	<u>Fastener</u> <u>Density</u>
---	--------------------------------	---------------------------------------	--------------------------------------	-----------------------------------

Approved Type(s): ACFoam II, Multi-Max FA, E'NRG'Y-2, PSI-25, ISO-95+, ISO + GL, Hy-Therm AP, Pyrox, EverGuard

Minimum: 1.4" x 4' x 4'	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.

<u>Insulation</u> <u>Top Layer</u>	<u>Fastener</u> <u>Type</u>	<u>Fastening</u> <u>Detail No.</u>	<u>Fasteners</u> <u>Per Board</u>	<u>Fastener</u> <u>Density</u>
---------------------------------------	--------------------------------	---------------------------------------	--------------------------------------	-----------------------------------

Approved Type(s): ACFoam II, Multi-Max FA

Minimum: 1.5" x 4' x 4'	Dekfast #14, #15	[3]	8	1:2 ft. ²
Minimum: 1.5" x 4' x 4'	Olympic #12, #14	[3]	8	1:2 ft. ²
Minimum: 1.5" x 4' x 4'	EverGuard EGID, EGHD	[3]	8	1:2 ft. ²
Minimum: 1.5" x 4' x 4'	Isofast IF2	[3]	8	1:2 ft. ²

Approved Type(s): ISO 95 +, ISO 95+GL

Minimum: 1.4" x 4' x 4'	Dekfast #14, #15	[3]	8	1:2 ft. ²
Minimum: 1.4" x 4' x 4'	Olympic #12, #14	[3]	8	1:2 ft. ²
Minimum: 1.4" x 4' x 4'	EverGuard EGID, EGHD	[3]	8	1:2 ft. ²
Minimum: 1.4" x 4' x 4'	Isofast IF2	[3]	8	1:2 ft. ²

Approved Type(s): E'NRG'Y-2, PSI-25, Hy-Therm AP, Pyrox, EverGuard

Minimum: 1.4" x 4' x 4'	Dekfast #14, #15	[3]	8	1:2 ft. ²
Minimum: 1.4" x 4' x 4'	Olympic #12, #14	[3]	8	1:2 ft. ²
Minimum: 1.4" x 4' x 4'	EverGuard EGID, EGHD	[3]	8	1:2 ft. ²
Minimum: 1.4" x 4' x 4'	Isofast IF2	[3]	8	1:2 ft. ²
Minimum: 1.4" x 4' x 4'	Insulfixx S or P	[3]	8	1:2 ft. ²

Approved Type(s): High Density Fiberboard, FM-90 High Density, Armor Board Regular, Esgard, Celotex Fiberboard, GAFTEMP Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber

Minimum: 1/2" x 4' x 4'	Dekfast #14, #15	[3]	8	1:2 ft. ²
Minimum: 1/2" x 4' x 4'	Olympic #12, #14	[3]	8	1:2 ft. ²
Minimum: 1/2" x 4' x 4'	EverGuard EGID, EGHD	[3]	8	1:2 ft. ²
Minimum: 1/2" x 4' x 4'	Isofast IF2	[3]	8	1:2 ft. ²
Minimum: 1/2" x 4' x 4'	Insulfixx S or P	[3]	8	1:2 ft. ²



Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder may be installed over the deck or the base layer of insulation.

Barrier: 1/2" or 5/8" gypsum or Dens Deck secured to the deck with the insulation.

Membrane: EverGuard EGFB Fleece Back Roof Cover fully adhered to the insulation with EverGuard Bonding Adhesive applied at the rate of 1 gal./sq., or approved mopping asphalt applied at the rate of 25 lbs./sq. Optional mechanical attachment of membrane using fasteners and plates noted in System Type D spaced 36" o.c. is permitted.

Maximum Design Pressure: -45 psf; (See General Limitation #9.)



Deck Type 1I: Wood, Insulated, New Construction

Deck Description: 19/32" or greater plywood or wood plank

System Type D: All insulation is loose laid with preliminary attachment or roof deck. Membrane is subsequently mechanically fastened through insulation to roof deck.

All General and System Limitations apply.

<u>Insulation Base Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
----------------------------------	--------------------------	---------------------------------	--------------------------------	-----------------------------

One or more layers of the Base Layer insulation covered by one layer of the insulation listed as Top Layer.

Approved Type(s): **EPS over gypsum barrier.**

Minimum: 1" x 4' x 4'	N/A	N/A	N/A	N/A
-----------------------	-----	-----	-----	-----

<u>Insulation Base or Top Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
---	--------------------------	---------------------------------	--------------------------------	-----------------------------

One or more layers of the following insulations.

Approved Type(s): **Celotherm, Conperl, GAFTEMP Permalite, FescoBoard**

Minimum: 1" x 2' x 4'	N/A	N/A	N/A	N/A
-----------------------	-----	-----	-----	-----

Approved Type(s): **Armor Board High Density, BP High Strength, FM-90 Traffic Top/High Density, ERS Redi-Deck, Riber Top C, E, S, GAFTEMP High Density, Roof Insulation Board, High Density Fiberboard, Fiber Base HD1, HD6, Structodek**

Minimum: 1" x 4' x 4'	N/A	N/A	N/A	N/A
-----------------------	-----	-----	-----	-----

Approved Type(s): **Hy-Tec, Pyrox, EverGuard, Hy-Therm AP, Whiteline, Hy-Therm SP, E'NRG'Y-2, PSI-25, Mutli-Max, Thermarroof Plus, ACFoam II, Ultra/M-11ISO/glas, ISO 95+, ISO 95+GL, Ultragard, Fesco Foam**

Minimum: 1" x 4' x 4'	N/A	N/A	N/A	N/A
-----------------------	-----	-----	-----	-----

Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder may be installed over the deck or the base layer of insulation.

Barrier: 1/2" or 5/8" gypsum or Dens Deck secured to the deck with the insulation



- Membrane: EverGuard EGSR Membrane or EverGuard EGFB Fleece Backed Membrane attached through the preliminary attached insulation as specified below.
- Fastening #1: Roof cover is rolled over the insulation and its 2" laps are sealed. Membrane is mechanically attached using SFS Isofast IF/IG-82x40 plates and IF or IG screws, Olympic ASAP/EverGuard 2" plates and Olympic Standard/EverGuard EGIN or Olympic Heavy Duty/EverGuard EGHD Screws or Dekfast #14 or #15 screws and plates spaced 6" o.c. in rows 8 ft. apart or 12" o.c. in rows 4 ft. apart. Fastener rows are stripped in with 6" wide strips of membrane or 6" diameter membrane caps, heat or solvent welded.
- Fastening #2: Membrane is mechanically attached using Olympic ASAP/EverGuard 2" plates and Olympic Standard/EverGuard EGIN or Olympic Heavy Duty/EverGuard EGHD Screws or Dekfast #14 or #15 screws and plates spaced 18" o.c. through 3" wide laps spaced 48" apart.
- Fastening #3: 78" wide membrane is mechanically attached using Olympic ASAP/EverGuard 2" plates and Olympic Standard/EverGuard EGIN or Olympic Heavy Duty/EverGuard EGHD Screws, Dekfast Omega, #14 or #15 screws and plates or HD Insulfixx S spaced 18" o.c. through 6" wide laps spaced 72" apart.
- Maximum Design Pressure: -45 (See General Limitation #7.)



Frank Zuloaga, RRC
Roofing Product Control Examiner

- Deck Type 1:** Wood, Non-insulated
- Deck Description:** 19/32" or greater plywood or wood plank decks
- System Type E:** Membrane mechanically attached to deck.

All General and System Limitations apply.

- Barrier:** 1/2" or 5/8" gypsum or Dens Deck secured to the deck with 4 approved fasteners per board.
- Membrane:** EverGuard EGSR Membrane or EverGuard EGFB Fleece Backed Membrane attached through the preliminary attached insulation as specified below.
- Fastening #1:** Roof cover is rolled over the insulation and its 2" laps are sealed. Membrane is mechanically attached using SFS Isofast IF/IG-82x40 plates and IF or IG screws, Olympic ASAP/EverGuard 2" plates and Olympic Standard/EverGuard EGIN or Olympic Heavy Duty/EverGuard EGHD Screws or Dekfast #14 or #15 screws and plates spaced 6" o.c. in rows 8 ft. apart or 12" o.c. in rows 4 ft. apart. Fastener rows are stripped in with 6" wide strips of membrane or 6" diameter membrane caps, heat or solvent welded.
- Fastening #2:** Membrane is mechanically attached using Olympic ASAP/EverGuard 2" plates and Olympic Standard/EverGuard EGIN or Olympic Heavy Duty/EverGuard EGHD Screws or Dekfast #14 or #15 screws and plates spaced 18" o.c. through 3" wide laps spaced 48" apart.
- Fastening #3:** 78" wide membrane is mechanically attached using Olympic ASAP/EverGuard 2" plates and Olympic Standard/EverGuard EGIN or Olympic Heavy Duty/EverGuard EGHD Screws, Dekfast Omega, #14 or #15 screws and plates or HD Insulfixx S spaced 18" o.c. through 6" wide laps spaced 72" apart.
- Maximum Design Pressure:** -45 (See General Limitation #7.)



Frank Zuloaga, RRC
Roofing Product Control Examiner

WOOD DECK SYSTEM LIMITATIONS:

1. A slip sheet is required with Ply 4 and Ply 6 when used as a mechanically fastened base or anchor sheet.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**



Frank Zuloaga, RRC
Roofing Product Control Examiner

NOTICE OF ACCEPTANCE STANDARD CONDITIONS

- 1 Renewal of this Acceptance (approval) shall be considered after a renewal application has been filed and the original submitted documentation, including test supporting data, engineering documents, are no older than eight (8) years.
- 2 Any and all approved products shall be permanently labeled with the manufacturer's name, city, state, and the following statement: "Miami-Dade County Product Control Approved", or as specifically stated in the specific conditions of this Acceptance.
- 3 Renewals of Acceptance will not be considered if:
 - a) There has been a change in the South Florida Building Code affecting the evaluation of this product and the product is not in compliance with the code changes;
 - b) The product is no longer the same product (identical) as the one originally approved;
 - c) If the Acceptance holder has not complied with all the requirements of this acceptance, including the correct installation of the product;
 - d) The engineer who originally prepared, signed and sealed the required documentation initially submitted, is no longer practicing the engineering profession.
- 4 Any revision or change in the materials, use, and/or manufacture of the product or process shall automatically be cause for termination of this Acceptance, unless prior written approval has been requested (through the filing of a revision application with appropriate fee) and granted by this office.
- 5 Any of the following shall also be grounds for removal of this Acceptance:
 - a) Unsatisfactory performance of this product or process;
 - b) Misuse of this Acceptance as an endorsement of any product, for sales, advertising or any other purposes.
- 6 The Notice of Acceptance number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the Notice of Acceptance is displayed, then it shall be done in its entirety.
- 7 A copy of this Acceptance as well as approved drawings and other documents, where it applies, shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at all times. The copies need not be resealed by the engineer.
- 8 Failure to comply with any section of this Acceptance shall be cause for termination and removal of Acceptance.
- 9 This Acceptance contains pages 1 through 14.

END OF THIS ACCEPTANCE



Frank Zuloaga, RRC
Roofing Product Control Examiner