



BUILDING CODE COMPLIANCE OFFICE
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

CONTRACTOR LICENSING SECTION
(305) 375-2527 FAX (305) 375-2558

CONTRACTOR ENFORCEMENT DIVISION
(305) 375-2966 FAX (305) 375-2908

PRODUCT CONTROL DIVISION
(305) 375-2902 FAX (305) 372-6339

PRODUCT CONTROL NOTICE OF ACCEPTANCE

Miami Dade Aluminum Supply, Inc.
1615 West 31 Place
Hialeah ,FL 33012

Your application for Notice of Acceptance (NOA) of:

Aluminum Screen Room

under Chapter 8 of the Code of Miami-Dade County governing the use of Alternate Materials and Types of Construction, and completely described herein, has been recommended for acceptance by the Miami-Dade County Building Code Compliance Office (BCCO) under the conditions specified herein.

This NOA shall not be valid after the expiration date stated below. BCCO reserves the right to secure this product or material at any time from a jobsite or manufacturer's plant for quality control testing. If this product or material fails to perform in the approved manner, BCCO may revoke, modify, or suspend the use of such product or material immediately. BCCO reserves the right to revoke this approval, if it is determined by BCCO that this product or material fails to meet the requirements of the South Florida Building Code.

The expense of such testing will be incurred by the manufacturer.

Raul Rodriguez
Chief Product Control Division

ACCEPTANCE NO.: 01-0410.01
EXPIRES: 04/16/2006

**THIS IS THE COVERSHEET, SEE ADDITIONAL PAGES FOR SPECIFIC AND GENERAL
CONDITIONS
BUILDING CODE & PRODUCT REVIEW COMMITTEE**

This application for Product Approval has been reviewed by the BCCO and approved by the Building Code and Product Review Committee to be used in Miami-Dade County, Florida under the conditions set forth above.

Francisco J. Quintana, R.A.
Director
Miami-Dade County
Building Code Compliance Office

APPROVED: 06/07/2001



Miami Dade Aluminum Supply

ACCEPTANCE No. : 01-0410.01

APPROVED : 06/07/2001

EXPIRES : 04/16/2006

NOTICE OF ACCEPTANCE: SPECIFIC CONDITIONS

1. SCOPE

This renews the Notice of Acceptance No. 97-0507.04, which was issued on April 16, 1998. It approves an Aluminum Screen Room, as described in Section 2 of this Notice of Acceptance, designed to comply with the South Florida Building Code, 1994 Edition for Miami-Dade County, for the locations where the pressure requirements, as determined by SFBC Chapter 23, do not exceed the Design Pressure Rating values indicated in the approved drawings.

2. PRODUCT DESCRIPTION

This Aluminum Screen Room and its components shall be constructed in strict compliance with the following documents: Drawing No. 97-07, titled "Screen Room", prepared by Tilteco, Inc., sheets 1 through 4 of 4, dated January 10, 1997, last revision #1 dated February 25, 1998, bearing the Miami-Dade County Product Control Approval and Renewal stamps with the Notice of Acceptance numbers and approval dates by the Miami-Dade County Product Control Division. These documents shall hereinafter be referred to as the approved drawings.

3. LIMITATIONS

All permanent set components, included but not limited to embedded anchor bolts must be protected against corrosion, contamination and damage at all times.

4. INSTALLATION

This Aluminum Screen Room and its components shall be installed in strict compliance with the approved drawings. The installation of this product will not require a hurricane protection system.

5. LABELING

This Aluminum Screen Room shall bear a permanent label with the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved". The label shall be placed at the bottom of the each chair rail, each beam or column, each roof panel of the screen room.


6. BUILDING PERMIT REQUIREMENTS

6.1 Application for building permit shall be accompanied by copies of the following:

6.1.1 This Notice of Acceptance.

6.1.2 Duplicate copies of the approved drawings, as identified in Section 2 of this Notice of Acceptance, clearly marked to show the components selected for the proposed installation.

6.1.3 Any other documents required by the Building Official or the South Florida Building Code (SFBC) in order to properly evaluate the installation of this system.



Helmy A. Makar, P.E., Product Control Examiner
Product Control Division


Miami Dade Aluminum Supply

ACCEPTANCE No. : 01-0410.01
APPROVED : 06/07/2001
EXPIRES : 04/16/2006


NOTICE OF ACCEPTANCE: SPECIFIC CONDITIONS

1. Renewal of this Acceptance (approval) shall be considered after a renewal application has been filed and the original submitted documents, including test-supporting data, engineering documents, are no older than eight (8) years.
2. Any and all approved products shall be permanently labeled with the manufacturer's name, city, state, and the following statement: "Miami-Dade County Product Control Approved", or as specifically stated in the specific conditions of this Acceptance.
3. Renewals of Acceptance will not be considered if:
 - a. There has been a change in the South Florida Building Code affecting the evaluation of this product and the product is not in compliance with the code changes;
 - b. The product is no longer the same product (identical) as the one originally approved;
 - c. If the Acceptance holder has not complied with all the requirements of this acceptance, including the correct installation of the product;
 - d. The engineer who originally prepared, signed and sealed the required documentation initially submitted, is no longer practicing the engineering profession.
4. Any revision or change in the materials, use, and/or manufacture of the product or process shall automatically be cause for termination of this Acceptance, unless prior written approval has been requested (through the filing of a revision application with appropriate fee) and granted by this office.
5. Any of the following shall also be grounds for removal of this Acceptance:
 - a. Unsatisfactory performance of this product or process;
 - b. Misuse of this Acceptance as an endorsement of any product, for sales, advertising or any other purposes.
6. The Notice of Acceptance number preceded by the words Miami -Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the Notice of Acceptance is displayed, then it shall be done in its entirety.
7. A copy of this Acceptance as well as approved drawings and other documents, where it applies, shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at all time. The engineer needs not reseal the copies.
8. Failure to comply with any section of this Acceptance shall be cause for termination and removal of Acceptance.
9. This Acceptance contains pages 1, 2 and this last page 3.


END OF THIS ACCEPTANCE



Helmy A. Makar, P.E.- Product Control Examiner
Product Control Division




① 2" x 3" PATIO SECTION
SCALE: 3/8" = 1"




DETAIL "A"


② 2" x 5" BEAM
SCALE: 3/8" = 1"





③ 2.931" x 2.931" COLUMN
SCALE: 3/8" = 1"




④, ④A 3" x 3" COLUMN
SCALE: 3/8" = 1"




⑤ 4" x 4" COLUMN
SCALE: 3/8" = 1"




⑦ 2" x 4" LAP COLUMN & BEAM
SCALE: 3/8" = 1"




⑧ 2" x 7" LAP BEAM
SCALE: 3/4" = 1"




⑨ CORNER COLUMN
SCALE: 3/8" = 1"




⑫ 2" x 2" 6063-T5 ALUMINUM ALLOY
SCALE: 3/8" = 1"




⑪ ROOF PAN SECTION
SCALE: 3/8" = 1"




⑮ HEADER
SCALE: 3/8" = 1"



⑩ 2" x 9" LAP BEAM
SCALE: 3/8" = 1"



⑬ GUTTER
6063-T5 ALUMINUM ALLOY
SCALE: 3/8" = 1"



⑭ FASCIA
6063-T5 ALUMINUM ALLOY
SCALE: 3/8" = 1"

GENERAL NOTES:

- THIS STRUCTURE HAS BEEN DESIGNED IN ACCORDANCE WITH CHAPTERS 23, 30 & 44 OF THE 1994 EDITION OF THE SOUTH FLORIDA BUILDING CODE. WIND VELOCITY CONSIDERED IS 110 m.p.h. DESIGN WIND LOAD AS PER SECTION 6 OF ASCE 7-88.
- DEFLECTIONS FOR COLUMNS, BEAMS AND ROOF PANELS SHALL BE AS FOLLOWS:
- L/80 FOR ROOF PROJECTIONS FROM EXISTING STRUCTURE LESS THAN OR EQUAL TO 12 FEET WHEN USED FOR RESIDENTIAL OCCUPANCY.
- L/180 FOR ALL COMMERCIAL PROJECTS AND FOR RESIDENTIAL WHEN ROOF PROJECTION FROM EXISTING STRUCTURE IS GREATER THAN 12 FEET.
- ALL EXTRUSIONS TO BE 6063-T6 ALUMINUM ALLOY UNLESS OTHERWISE NOTED.
- THE THICKNESS OF ALL EXTRUSIONS SHALL BE AS SHOWN ON THIS DRAWING WITH STANDARD TOLERANCES IN ACCORDANCE WITH THE "ALUMINUM STANDARDS AND DATA 1988 EDITION", ALUMINUM ASSOCIATION INCORPORATED, WASHINGTON, D. C.
- ALUMINUM ROOF PANEL ALLOYS SHALL BE 3105-H154.
- ALL SCREWS TO BE 304 SERIES STAINLESS STEEL OR 2024-T4 ALUMINUM ALLOY.
- ALL BOLTS TO BE A. S. T. M. A-307 GALVANIZED STEEL OR 2024-T4 ALUMINUM ALLOY.
- ALL CONCRETE SHALL DEVELOP 3000 p.s.i. COMPRESSIVE STRESS AT 28 DAYS. WELDED WIRE FABRIC SHALL COMPLY W/ ASTM A-185.
- ALL REINFORCING STEEL SHALL BE A.S.T.M. A-615 GRADE 60 DESIGNATION BARS.
- SCREEN USED ON WALLS SHALL BE 60 PERCENT MINIMUM OPEN.
- ALUMINUM MEMBERS IN CONTACT WITH CONCRETE AND WOOD SHALL BE PROTECTED BY KOPPERS BITUMINOUS PAINT ACCORDING TO S.F.B.C. SECTION 3004.4 (d) AND (e). WHEN ALUMINUM IS IN CONTACT WITH PRESSURE TREATED WOOD, IT SHALL BE IN ACCORDANCE WITH THE S.F.B.C. SECTION 3004.4 (f).
- IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO VERIFY THE SOUNDNESS OF THE STRUCTURE WHERE SCREEN ROOM/CANOPY IS TO BE ATTACHED TO INSURE PROPER ANCHORAGE.
- MINIMUM SOIL BEARING CAPACITY TO BE 2000 p.s.f.
- CONCRETE AND MASONRY ANCHORS SHALL BE TAPCON TYPE ANCHORS, AS MANUFACTURED BY I.T.W./RAMSET OR ELCO INDUSTRIES, INC., OR RED HEAD WEDGE ANCHORS, AS MANUFACTURED BY I.T.W./RAMSET. DIAMETERS AND LENGTHS SHALL BE AS SPECIFIED ON DRAWINGS. MINIMUM PENETRATION INTO MASONRY IS 1 1/4". MINIMUM PENETRATION INTO CONCRETE IS 1 3/4". MINIMUM PENETRATION IS IN ADDITION TO ANY ADDED LENGTH REQUIRED TO PENETRATE EXISTING PRECAST STONE, PRECAST CONCRETE PANELS, PAVERS OR TILES THAT COULD BE COVERING THE CONCRETE OR MASONRY WALL OR FLOOR.
- THIS STRUCTURE SHALL BE CONSTRUCTED ATTACHED TO A C.B.S. WITH MEAN ROOF HEIGHT EQUAL OR LESS THAN 60'-0". NOTIFY THIS ENGINEER IF THE ABOVE CONDITION IS NOT COMPLIED WITH. THIS STRUCTURE SHALL BE INSTALLED LESS THAN 15'-0" HIGH ABOVE GROUND LEVEL.


PRODUCT RENEWED

APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE
ACCEPTANCE No. 01-0410-01 DATE APRIL 16 1998
EXPIRATION DATE 04/16/2000 BY Helmut A. Mahr
PRODUCT CONTROL DIVISION BUILDING CODE COMPLIANCE OFFICE
BUILDING CODE COMPLIANCE OFFICE ACCEPTANCE NO. 97-0507-04
DADE COUNTY

TILECO INC.
TILLIT TESTING & ENGINEERING COMPANY
6595 N.W. 38th St., Ste. 217, VIRGINIA GARDENS, FL 33169
Phone: (305)871-1530 Fax: (305)871-1531
WALTER A. TILLIT Jr., P. E.
FLORIDA Lic. 44167

SCREEN ROOM						AS SHOWN SCALE
MIAMI DADE ALUMINUM SUPPLY						1/10/97 DATE
1815 WEST 31st. PLACE HIALEAH, FLORIDA 33012						97 - 07 DRAWING No
REV. NO	DESCRIPTION	DATE	REV. No	DESCRIPTION	DATE	SHEET 1 OF 4
1	NOTE # 1	2/25/98	3			
2			4			


Handwritten signature and date: 2/25/98




**ROOF PLAN-MONOSLOPE ROOF
(SCREEN ROOM/CANOPY)**

NOTE: SEE BEAM & COLUMN SCHEDULE ON SHEET 4 OF 4.

N. T. S.



**ELEVATION-MONOSLOPE ROOF
SCREEN ROOM (W/ OR W/O SCREEN)** N. T. S.



SECTION A N. T. S.

PRODUCT RENEWED


ACCEPTANCE No. 01-0410.01
 EXPIRATION DATE 04/16/2006
 By *Helmy A. Meher*
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE

APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE
 DATE *APRIL 16* 19 *98*
 BY *Helmy A. Meher*
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE No. *97-0507.04*


DADE COUNTY

 TILLIT TESTING & ENGINEERING COMPANY 6595 N.W. 36th St., Ste. 217, VIRGINIA GARDENS, FL 33166 Phone: (305)871-1530 Fax: (305)871-1531 WALTER A. TILLIT Jr., P. E. FLORIDA Lic. # 44167		SCREEN ROOM		AS SHOWN SCALE	
		MIAMI DADE ALUMINUM SUPPLY		1/10/97 DATE	
		1815 WEST 31st PLACE HIALEAH, FLORIDA 33012		97 - 07	
				DRAWING No	
				SHEET 2 OF 4	
REV. NO	DESCRIPTION	DATE	REV. No	DESCRIPTION	DATE
1	GENERAL	2/25/98	3		
2			4		


David [Signature]
 4/10/98



DETAIL 1 : HEADER CONNECTION TO TIE BEAM. N. T. S.




Alu. BEAM/Col. CONNECTION DETAIL N. T. S.




DETAIL 3 : BRACING CONNECTION DETAIL (ELEVATION)

N. T. S.

NOTE : THIS DETAIL IS ONLY REQUIRED FOR SCREEN ROOMS FRONT WALLS.



CASE 1



CASE 2

COLUMN CONNECTION TO FOOTING

N. T. S.

PRODUCT RENEWED

ACCEPTANCE No. 01-0410-01

EXPIRATION DATE 04/16/2006

By Helmut A. Meier
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE

APPROVED AS COMPLYING WITH THE

SOUTH FLORIDA BUILDING CODE

DATE APRIL 16, 1998

By Helmut A. Meier

PRODUCT CONTROL DIVISION

BUILDING CODE COMPLIANCE OFFICE

ACCEPTANCE No. 97-0507.04

DADE COUNTY

David [Signature]
2/20/98

 TILECO INC. TILLIT TESTING & ENGINEERING COMPANY 6565 N.W. 36th St., Ste. 217, VIRGINIA GARDENS, FL 33166 Phone : (305)871-1530 . Fax : (305)871-1531 WALTER A. TILLIT Jr., P. E. FLORIDA Lic. # 44167		SCREEN ROOM		AS SHOWN SCALE	
		MIAMI DADE ALUMINUM SUPPLY		1/10/97 DATE	
		1815 WEST 31st. PLACE HIALEAH, FLORIDA 33012		97 - 07 DRAWING No	
REV. NO	DESCRIPTION	DATE	REV. No	DESCRIPTION	DATE
1	GENERAL	2/25/98	3		
2			4		
					SHEET 3 OF 4

BEAM SCHEDULE MAXIMUM SPAN FOR A GIVEN TRIBUTARY WIDTH *

L/80
L/180

BEAM TYPE	TRIBUTARY WIDTH *							MAXIMUM BEAM OVERHANG
	3'-0"	4'-0"	5'-0"	6'-0"	7'-0"	8'-0"	9'-0"	
①	5'-8"	4'-11"	4'-5"	4'-0"	-	-	-	1'-6"
	4'-10"	4'-4"	4'-0"	3'-10"	-	-	-	1'-6"
②	12'-6"	10'-10"	9'-8"	8'-10"	8'-2"	7'-8"	7'-3"	3'-6"
	9'-8"	8'-9"	8'-2"	7'-8"	7'-3"	7'-0"	6'-8"	3'-0"
⑦	8'-10"	7'-7"	6'-10"	6'-3"	-	-	-	2'-0"
	7'-2"	6'-6"	6'-0"	5'-8"	-	-	-	2'-0"
⑧	17'-2"	14'-10"	11'-3"	12'-2"	11'-3"	10'-6"	9'-11"	4'-0"
	13'-9"	12'-6"	11'-8"	10'-11"	10'-5"	10'-0"	9'-7"	4'-0"
⑩ **	19'-2"	16'-6"	14'-10"	13'-6"	12'-6"	11'-9"	11'-0"	4'-6"
	16'-3"	14'-9"	13'-9"	12'-11"	12'-3"	11'-9"	11'-0"	4'-6"

* TRIBUTARY WIDTH: - ROOF SPAN (FROM WALL TO FRONT BEAM)/2 + OVERHANG FOR ROOFS ATTACHED TO BUILDING.
- ROOF SPAN (FROM BEAM TO BEAM) FOR ROOFS ATTACHED TO BUILDING WITH MULTIPLE BAYS.

** ⑩ 2" x 9" BEAM SHALL ONLY BE USED JOINTLY WITH COLUMNS ④, ④A OR ⑤.

COLUMN SCHEDULE


MAXIMUM COLUMN SPACING (Ft.) * FOR A GIVEN HEIGHT,

TYPE OF COLUMN AND TYPE OF STRUCTURE WHERE COLUMN IS LOCATED

COLUMN TYPE	ROOF ATTACHED TO PERMANENT BUILDING					
	WITH SCREEN WALLS			W/O SCREEN WALLS		
	7'-0"	7'-6"	8'-0"	8'-0"	9'-0"	10'-0"
⑩	4'-10"	4'-6"	3'-9"	8'-4"	6'-7"	-
⑦	-	-	-	8'-4"	6'-7"	-
③	7'-0"	7'-0"	7'-0"	17'-10"	14'-2"	-
	7'-0"	7'-0"	6'-2"	17'-10"	14'-2"	-
④	-	-	-	13'-7"	12'-8"	-
	-	-	-	13'-7"	12'-8"	-
④A	-	-	-	**	**	**
⑤	-	-	-	**	**	**

- N/A
* Max. COLUMN SPACING SHALL NOT EXCEED Max. BEAM SPAN AS PER BEAM SCHEDULE FOR A GIVEN BEAM TYPE.
** LIMITED BY BEAM SPAN AS PER BEAM SCHEDULE.

* COLUMN MAY ALSO BE CLIPPED ANGLE TO FOOTING INSTEAD OF EMBEDDING, APPLICABLE TO ROOFS ATTACHED TO PERMANENT BUILDING.



MAXIMUM SPAN TABLE FOR A GIVEN TRIBUTARY AREA

ROOF AREA BEARING OR COLUMN (Ft.²)*	REQUIRED FOOTING SIZE IN SAND/ROCK	REINFORCING STEEL EQUALLY SPACED EACH WAY. SAND/ROCK
120	5'-4" x 5'-4"	5 # 4 REBARS
	3'-0" x 3'-0"	4 # 4 REBARS
90	4'-7" x 4'-7"	4 # 4 REBARS
	2'-5" x 2'-5"	3 # 4 REBARS
60	3'-9" x 3'-9"	4 # 4 REBARS
	2'-0" x 2'-0"	3 # 4 REBARS
40	3'-0" x 3'-0"	3 # 4 REBARS
	2'-0" x 2'-0"	3 # 4 REBARS
25	2'-4" x 2'-4"	3 # 4 REBARS
	2'-0" x 2'-0"	3 # 4 REBARS

* ROOF PANEL SPAN x BEAM SPAN (INTERIOR COLUMNS) OR (ROOF PANEL SPAN/2 + O. H.) x BEAM SPAN (END COLUMNS)

Max. ROOF PANEL SPAN SCHEDULE


SPAN CONDITION	Max. SPAN "L"	
	L/80	L/180
	4'-0"	4'-0"
	4'-10"	4'-10"
	5'-4"	5'-4"
	5'-6"	5'-6"

STRAP (17) SCHEDULE

(REQ'D ONLY AT SCREEN ROOM)

ROOF PROJECTION P (ft.)	TOTAL NUMBER OF STRAPS AT FRONT WALL
10'-8" OR LESS	2
>10'-8" TO 21'-4" Max.	4

P = DISTANCE FROM EXISTING WALL TO FRONT SCREEN WALL



PRODUCT RENEWED

ACCEPTANCE No. 01-0410-01

EXPIRATION DATE 04/16/2006

By *Helmy A. Moker*
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE

APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE

DATE APRIL 16 1998

BY *Helmy A. Moker*
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 97-0507.04

DADE COUNTY

David...
2/25/98

 TILLIT TESTING & ENGINEERING COMPANY 6695 N.W. 39th. St., Ste. 217, VIRGINIA GARDENS, FL 33169 Phone : (305)871-1530 . Fax : (305)871-1531 WALTER A. TILLIT Jr., P. E. FLORIDA Lic. 44167	SCREEN ROOM MIAMI DADE ALUMINUM SUPPLY 1815 WEST 31st. PLACE HIALEAH, FLORIDA 33012	SCALE 1/10/97 DATE 97 - 07 DRAWING No
	REV. NO. DESCRIPTION DATE REV. No. DESCRIPTION DATE 1 CONCRETE STRENGTH 2/25/98 3 2 - - - 4	SHEET 4 OF 4