MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING

BUILDING CODE COMPLIANCE OFFICE
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

CONTRACTOR LICENSING SECTION
(305) 375-2527 FAX (305) 375-2558

CONTRACTOR ENFORCEMENT DIVISION
(305) 375-2966 FAX (305) 375-2908

PRODUCT CONTROL DIVISION
(305) 375-2902 FAX (305) 372-6339

PRODUCT CONTROL NOTICE OF ACCEPTANCE

Elk Corporation of Alabama
P.O. Box 031190 4600 Stillman Boulevard
Tusaloosa ,AL 35403-5190

Your application for Notice of Acceptance (NOA) of:
Prestique Plus 40
under Chapter 8 of the Code of Miami-Dade County governing the use of Alternate Materials and Types of Construction, and completely described herein, has been recommended for acceptance by the Miami-Dade County Building Code Compliance Office (BCCO) under the conditions specified herein.

This NOA shall not be valid after the expiration date stated below. BCCO reserves the right to secure this product or material at any time from a jobsite or manufacturer's plant for quality control testing. If this product or material fails to perform in the approved manner, BCCO may revoke, modify, or suspend the use of such product or material immediately. BCCO reserves the right to revoke this approval, if it is determined by BCCO that this product or material fails to meet the requirements of the South Florida Building Code.

The expense of such testing will be incurred by the manufacturer.

ACCEPTANCE NO.: 01-0411.09
EXPIRES: 10/02/2003

Raul Rodriguez
Chief Product Control Division

THIS IS THE COVERSHEET, SEE ADDITIONAL PAGES FOR SPECIFIC AND GENERAL CONDITIONS
BUILDING CODE & PRODUCT REVIEW COMMITTEE

This application for Product Approval has been reviewed by the BCCO and approved by the Building Code and Product Review Committee to be used in Miami-Dade County, Florida under the conditions set forth above.

Francisco J. Quintana, R.A.
Director
Miami-Dade County
Building Code Compliance Office

APPROVED: 07/12/2001

ROOFING SYSTEM APPROVAL

Category:	Roofing		
Sub Category:	Shingles	Approval Date:	**July 12, 2001**
Materials:	Laminate	Expiration Date:	**October 02, 2003**

1. SCOPE

This renews EIK Prestique Plus 40 Fiberglass manufactured by EIK Corporation of Alabama described in Section 2 of this Notice of Acceptance, designed to comply with the South Florida Building Code, 1994 Edition for Miami-Dade County.

2. PRODUCT DESCRIPTION

Product	Dimensions	Test Specifications	Product Description
EIK Prestique Plus 40	13 $^1/_4$" x 39 $^3/_8$"	PA 110	A heavy weight laminated asphalt shingle with a propriatery profile.

3 LIMITATIONS

3.1 Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.

3.2 Shall not be installed on roof mean heights in excess of 33 ft.

4 INSTALLATION

4.1 Shingles shall be installed in compliance with Miami-Dade County Product Control Shingle Installation Procedure No. 115.

4.2 Flashings shall be in accordance with Section 9.3 Option "B" (Step-flashings) of Miami-Dade County Product Control Shingle Installation Procedure No. 115

4.3 The manufacturer shall provide clearly written application instructions.

4.4 Exposure and course layout shall be in compliance with Detail 'A', attached.

4.5 Nailing shall be in compliance with Detail 'B', attached.

5 LABELING

5.1 Shingles shall be labeled with the Miami-Dade Logo or the wording "Miami-Dade County-Dade Product Control Approved".

6 BILDING PERMIT REQUIREMENTS

6.1 Application for building permit shall be accompanied by copies of the following:

6.1.1 This Notice of Acceptance.

Any other documents required by the Building Official or the Applicable Building Code in order to properly evaluate the installation of this system

Frank Zuloaga
Roofing Product Control Examiner

DETAIL A



DETAIL B



Frank Zuloaga
Roofing Product Control Examiner

NOTICE OF ACCEPTANCE STANDARD CONDITIONS

1 Renewal of this Acceptance (approval) shall be considered after a renewal application has been filed and the original submitted documentation, including test supporting data, engineering documents, are no older than eight (8) years.

2 Any and all approved products shall be permanently labeled with the manufacturer's name, city, state, and the following statement: "Metro-Dade County Product Control Approved", or as specifically stated in the specific conditions of this Acceptance.

3 Renewals of Acceptance will not be considered if:

a) There has been a change in the South Florida Building Code affecting the evaluation of this product and the product is not in compliance with the code changes;

b) The product is no longer the same product (identical) as the one originally approved;

c) If the Acceptance holder has not complied with all the requirements of this acceptance, including the correct installation of the product;

d) The engineer who originally prepared, signed and sealed the required documentation initially submitted, is no longer practicing the engineering profession.

4 Any revision or change in the materials, use, and/or manufacture of the product or process shall automatically be cause for termination of this Acceptance, unless prior written approval has been requested (through the filing of a revision application with appropriate fee) and granted by this office.

5 Any of the following shall also be grounds for removal of this Acceptance:

a) Unsatisfactory performance of this product or process;

b) Misuse of this Acceptance as an endorsement of any product, for sales, advertising or any other purposes.

6 The Notice of Acceptance number preceded by the words Metro-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the Notice of Acceptance is displayed, then it shall be done in its entirety.

7 A copy of this Acceptance as well as approved drawings and other documents, where it applies, shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at all times. The copies need not be resealed by the engineer.

8 Failure to comply with any section of this Acceptance shall be cause for termination and removal of Acceptance.

9 This Acceptance contains pages 2 through 4.

END OF THIS ACCEPTANCE

Frank Zuloaga
Roofing Product Control Examiner

NOTICE OF ACCEPTANCE:EVIDENCE SUBMITTED
(For File ONLY. Not part of NOA.)

EVIDENCE SUBMITTED

Test Agency	Test Identifier	Test Name/Report	Date
Center for Applied Engineering	PA 100	Uplift and wind driven rain resistance.	07/13/94
Underwriters Laboratories, Inc.	PA 107	Wind uplift resistance	05/27/94

C.CALCULATIONS: <enter calculations received for use of coefficients>

D.MATERIAL CERTIFICATIONS: NONE

E.STATEMENTS: NONE

F. OTHER

1. Association member <enter name of association and its approval document number>
Notice of Acceptance number 00-0720.02

Frank Zuloaga
Roofing Product Control Examiner