



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

---

**GAMMA, U. S. A.  
15407 West Dixie Highway  
N. Miami, FL 33162**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee (BCPRC) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The BCCO (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BCPRC reserves the right to revoke this acceptance, if it is determined by BCCO that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the South Florida Building Code, 1994 Edition for Miami-Dade County or Florida Building Code.

**DESCRIPTION: Series "Aldora" Aluminum Sliding Glass Door (OXXO)**

**APPROVAL DOCUMENT:** Drawing No. SGD17SI, titled "Series 17 Aluminum Sliding Glass Door", sheets 1 through 4 of 4, prepared by manufacturer, dated 08-07-00 and last revised on 01-31-02, signed and sealed by Farrokh Rasekhi, P. E., bearing the Miami-Dade County Product Control Approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division.

**MISSILE IMPACT RATING: Small Missile Impact Resistant**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **01-0612.05** and consists of this page 1 as well as approval document mentioned above. The submitted documentation was reviewed by **Ishaq I. Chanda, P. E.**



**NOA No 01-0612.05  
Expiration Date: March 07, 2007  
Approval Date: March 07, 2002  
Page 1**

17 ALDORA 3 OXXO 48 108 90 SI-14





**Gamma**

15407 West Dixie Highway,  
North Miami Beach, FL 33162  
Phone: (305) 987-7004 FAX: (305) 987-7006



**ALDORA**

PROJECT:	SERIES:17 ALUMINUM SLIDING GLASS DOOR	DATE:	08-07-00
	DWG. NAME: SGD17SI	PROJECT #	0004
TITLE:	TYPICAL ELEVATION	SCALE:	03-14-01



*Farrokh Rasekhi*  
Farrokh Rasekhi, P.E.  
Consulting Struct. Engineer  
FL. REG. NO. 38001  
2/7/02

**TYPICAL ELEVATION**

EXTERIOR VIEW  
APPROVED AS COMPLYING WITH THE  
SOUTH FLORIDA BUILDING CODE  
DATE March 7, 2002  
BY Shag I. Chanda  
PRODUCT CONTROL DIVISION  
BUILDING CODE COMPLIANCE OFFICE  
ACCEPTANCE NO. 01-0612.05

SHUTTER REQUIREMENTS:  
1- INSTALLATION OF THIS UNIT ABOVE  
30 FT ABOVE GRADE WILL NOT  
REQUIRE SHUTTERS  
2- MIAMI DADE COUNTY APPROVED  
SHUTTERS WILL BE REQUIRED FOR  
BELOW 30 FT ABOVE THE GRADE

SMALL IMPACT TEST  
DESIGN PRESSURE + 90 psf  
DESIGN PRESSURE - 90 psf

R4 01-24-02	R5 01-31-02	PHILIPPE MICHAUD	L.F.	P0004SGD1
R2 03-26-01	R3 01-11-02			
REVISION:		DRAWN BY:	CHECKED BY:	CAD NAME:
1				4

17 ALDORA 3 OXXO 48 108 90 SI-14

**Gamma**


15407 West Dixie Highway,  
North Miami Beach, FL 33162  
Phone: (305) 957-7004 FAX: (305) 957-7008



**ALDORA**

PROJECT:	SERIES: 17 ALUMINUM SLIDING GLASS DOOR	DATE:	08-07-00
	DWG. NAME: SGD17SI	PROJECT #	0004
TITLE:	TYPICAL DETAILS	SCALE:	

*Farrokh Rasekhi*  
Farrokh Rasekhi, P.E.  
Consulting Struct. Engineer  
FL. REG. NO. 38001  
2/7/02



R4 01-24-02	R5 01-31-02	R3 01-11-02	PHILIPPE MICHAUD	L.F.	P0004SGD1
R2 03-26-01					
REVISION:			DRAWN BY:	CHECKED BY:	CAD NAME:
APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE			DATE <u>March 07, 2002</u>		
BY <u>Isaac I. Chaudh</u>			PRODUCT CONTROL DIVISION		
BUILDING CODE COMPLIANCE OFFICE			ACCEPTANCE NO. <u>01-0612-05</u>		
2			4		

17 ALDORA 3 OXXO 48 108 90 SI-14


**Gamma**

15407 West Dixie Highway,  
North Miami Beach, FL 33162  
Phone: (305) 957-7004 FAX: (305) 957-7008




**ALDORA**


PROJECT:	SERIES: 17 ALUMINUM SLIDING GLASS DOOR	DATE:	08-07-00
	DWG. NAME: SGD17SI	PROJECT #	0004
TITLE:	TYPICAL DETAILS 001 TO 004	SCALE:	



detail 004



detail 003



detail 002

FRAME CORNERS SEALED WITH SPECTREM II WHITE COLORED SEALANT AS INDICATED  
PANEL CORNERS SEAM SEALED WITH CLEAR GUTTERSEAL SEALANT AS INDICATED

APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE  
DATE March 07, 2002  
BY Shaq I. Chayde  
PRODUCT CONTROL DIVISION  
BUILDING CODE COMPLIANCE OFFICE  
ACCEPTANCE NO. 01-0612-05

*Farrokh Rasekhi*  
Farrokh Rasekhi, P.E.  
Consulting Struct. Engineer  
FL. REG. NO. 38001  
2/7/02

detail 001

R4 01-24-02	R5 01-31-02	R3 01-11-02	PHILIPPE MICHAUD L.F.	P0004SGD1
R2 03-26-01				
REVISION:	3			
DRAWN BY:				
CHECKED BY:				
CAD NAME:				

17 ALDORA 3 OXXO 48 108 90 SI-14



15407 West Dixie Highway,  
North Miami Beach, FL 33162  
Phone: (305) 957-7004 FAX: (305) 957-7008



**ALDORA**

PROJECT:	SERIES:17 ALUMINUM SLIDING GLASS DOOR	DATE:	08-07-00
	DWG. NAME: SGD17SI	PROJECT #	0004
TITLE:	DESCRIPTION LIST	SCALE:	

**DESCRIPTION**

1	ALUMINUM FRAME ( JAMB # XA-90636) AL 6063 T6	36	#8 F.H. STS METAL SCREW 1" LONG (3 1/2, 19 3/4, 37 1/2, 55 1/8, 65, 72 1/8, 86 1/8, 101 3/4" FROM BOTTOM)
2	ALUMINUM SASH (TOP & BOTTOM RAIL # 997904) AL 6063 T6	37	Ø1/4-20 FH STS X 1" LONG
3	1/4" H.S. GLASS +0.060" SAFLEX /KEEPSAFE PVB BY SOLUTIA + 1/4" H.S. GLASS LAMINATED BY PRELCO	38	#12 x 3/4" PH STS METAL SCREW
4	ALUMINUM FRAME (TOP# XA-92256) AL 6063 T6 HEAD	39	4 1/8" PLASTIC SHIM (2 PER INTERLOCK)
5	ASTRAGLE METTING RAIL DIE # 997905 AL 6063 T6	40	ALUM. FOLDING 1/8" THICK. x 17/32" x 3/4" x 17/32" x 0'-3" LONG. (FOR HEAD & JAMBS)
6	METTING RAIL DIE # 997906 AL 6063 T6	41	ALUM. FOLDING 1/8" THICK. x 5/8" x 3/4" x 5/8" x 0'-3" LONG. (FOR SILL)
7	TAPCON SCREW 1/4" DIA. 2 3/4" LONG. (min. 1 3/4" embedment)		
8	TPR EXTRUDED GASKET TP116		
9	SCCELLANT SPECTREM2 (TREMCO)		
10	TRUTH PLASTIC HANDLE # 40 STYLINE AND SINGLE POINT MORTISE LOCK #11487		
11	POLYFLEX GASKET		
12	TRUTH ROLLER # 39.20 (2 SETS PER SASH)		
13	ALUMINUM EXTRUDED ASTRAGAL # XA-90643 AL 6063 T6		
14	EPDM GASKET BUL # DIE 8915B TREMCO		
15	CONTINUOUS MOHAIR # DIE FS7635-187 SCHLEGEL		
16	ALUMINUM FIXED SASH (JAMB # 997908) AL 6063 T6		
17	STAINLESS STEEL ASSEMBLY SCREWS 1/4" X 20 X 1" LONG (8 PER SASH)(12 PER FRAME)		
18	SEALANT GUTTER SEAL		
19	DRAINING OUTSIDE RAIL (8X) SLOTS 1/4"X2"		
20	METTING RAIL DIE # 997907 AL 6063 T6		
21	PLASTIC MOULDING FOR MOHAIR AT HEAD & SILL FIXED WITH 2 #8 x1/2" RH SST SCREWS		
22	ALUMINUM ANGLE AT HEAD AND SILL 2"X3 1/4"X2 1/4"X1/4" THICK (SEAL WITH SPECTREM2)		
23	1/4"-20 X 1 1/2" LONG. STAINLESS STEEL SCREW ( 2 PER ANGLE)		
25	ALUMINUM FRAME (BOTTOM #947476) SILL.		
26	ALUMINUM ANGLE 2"X1 5/16"X1/4" X 3"LONG		
27	FOAM UNDER FIXED PANEL 1/2" X 3/4"X 49"		
28	DRAINING INSIDE RAIL (4X) SLOTS 1/4"X2"		
29	MOHAIR PAD AT METTING RAIL (1X4" BELOW ASTRAGALE STILE, 1 1/2"X3" BELOW INTERLOCK STILE, 1X3" BELOW MOVING PANEL INTERLOCK STILE)		
30	4" PLASTIC EXTRUSION SUPPORT FOR FIXED SASH # 51022000 (2 PER FIXED PANEL)		
31	PLASTIC BLOC AT MEETING RAIL		
32	1/4 " REINFORCEMENT ALUMINUM ANGLE 7" LONG ( AT METTING RAIL ONLY)		
33	REINFORCEMENT 1 1/2" X 1 1/2" X 3/16" THICK X 99 1/2" LONG. ASTM A500-GRADE B		
34	PVC DOOR STOPPER		
35	#8 F.H. STAINLESS STEEL METAL SCREW 3/4" LONG (2 PER REINFORCEMENT)		

*Farrokh Rasekhi*  
Farrokh Rasekhi, P.E.  
Consulting Struct. Engineer  
FL. REG. NO. 38001  
2/7/02

APPROVED AS COMPLYING WITH THE  
SOUTH FLORIDA BUILDING CODE  
DATE March 07, 2002  
BY Shag I. Chanda  
PRODUCT CONTROL DIVISION  
BUILDING CODE COMPLIANCE OFFICE  
ACCEPTANCE NO. 01-0612.05

NOTE: SEAL EXTERIOR AND ALL BELOW 5" INSTALLATION FASTENER HEADS, WITH SILICONE SCEALENT SPECTREM2  
FRAME CORNER, PERIMETER ANGLES ARE SEALED WITH SILICONE SEALANT SPECTREM2  
PANEL CORNER SEAMS ARE SEALED WITH GUTTER SEAL

R4 01-24-02	R5 01-31-02	REVISION:	4
R2 03-26-01	R3 01-11-02	DRAWN BY:	4
		CHECKED BY:	
		CAD NAME:	

PHILIPPE MICHAUD  
L.F.  
P0004SGD1