



**BUILDING CODE COMPLIANCE OFFICE**  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908

**CONTRACTOR LICENSING SECTION**  
(305) 375-2527 FAX (305) 375-2558

**CONTRACTOR ENFORCEMENT DIVISION**  
(305) 375-2966 FAX (305) 375-2908

**PRODUCT CONTROL DIVISION**  
(305) 375-2902 FAX (305) 372-6339

**PRODUCT CONTROL NOTICE OF ACCEPTANCE**

**Inland Southern Corporation**  
**2141 2nd Avenue S.W.**  
**Cullman ,AL 35055**

Your application for Notice of Acceptance (NOA) of:

**0.024" (min.) Galvanized Steel "Dyna-Rib" Roof Panel**

under Chapter 8 of the Code of Miami-Dade County governing the use of Alternate Materials and Types of Construction, and completely described herein, has been recommended for acceptance by the Miami-Dade County Building Code Compliance Office (BCCO) under the conditions specified herein.

This NOA shall not be valid after the expiration date stated below. BCCO reserves the right to secure this product or material at any time from a jobsite or manufacturer's plant for quality control testing. If this product or material fails to perform in the approved manner, BCCO may revoke, modify, or suspend the use of such product or material immediately. BCCO reserves the right to revoke this approval, if it is determined by BCCO that this product or material fails to meet the requirements of the South Florida Building Code.

The expense of such testing will be incurred by the manufacturer.

Raul Rodriguez  
Chief Product Control Division

**ACCEPTANCE NO.: 01-0614.16**  
**EXPIRES: 10/29/2006**

**THIS IS THE COVERSHEET, SEE ADDITIONAL PAGES FOR SPECIFIC AND GENERAL  
CONDITIONS  
BUILDING CODE & PRODUCT REVIEW COMMITTEE**

This application for Product Approval has been reviewed by the BCCO and approved by the Building Code and Product Review Committee to be used in Miami-Dade County, Florida under the conditions set forth above.

Francisco J. Quintana, R.A.  
Director  
Miami-Dade County  
Building Code Compliance Office

**APPROVED: 09/13/2001**

**Inland Southern Corporation**

**ACCEPTANCE No. :** 01-0614.16

**APPROVED :** 09/13/2001

**EXPIRES :** 10/29/2006

**NOTICE OF ACCEPTANCE: SPECIFIC CONDITIONS**

**1. SCOPE**

This renews the Notice of Acceptance No. 97-0731.09, which was issued on October 29, 1998. It approves a 0.024" (min.) Structural Galvanized Steel Roof Panel, as described in Section 2 of this Notice of Acceptance, designed to comply with the South Florida Building Code, 1994 Edition for Miami-Dade County, for the locations where the load requirements, as determined by SFBC Chapter 23, do not exceed the design load values indicated in the approved drawings.

**2. PRODUCT DESCRIPTION**

This 0.024" (min.) Structural Galvanized Steel Roof Panel and its components shall be constructed in strict compliance with the following documents: Drawing No. 962-752, titled "Dyna Rib Roof Panel", prepared by Keith Shedd, P.E., dated October 1998, sheet 1 of 2, and July 31, 2001 sheet 2 of 2, signed and sealed by Keith Shedd, P.E., bearing the Miami-Dade County Product Control renewal stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Division. These documents shall hereinafter be referred to as the approved drawings.

**3. LIMITATIONS**

All permanent set components must be protected against corrosion, contamination and damage at all times.

**4. INSTALLATION**

This 0.024" (min.) Structural Galvanized Steel Roof Panel and its components shall be installed in strict compliance with the approved drawings.

**5. LABELING**

Each panel shall bear a permanent label with the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved".

**6. BUILDING PERMIT REQUIREMENTS**

**6.1** Application for building permit shall be accompanied by copies of the following:

**6.1.1** This Notice of Acceptance.

**6.1.2** Duplicate copies of the approved drawings, as identified in Section 2 of this Notice of Acceptance, clearly marked to show the components selected for the proposed installation.

**6.1.3** Any other documents required by the Building Official or the South Florida Building Code (SFBC) in order to properly evaluate the installation of this system.



Helmy A. Makar, P.E.- Product Control Examiner  
Product Control Division

**Inland Southern Corporation**

**ACCEPTANCE No. :** 01-0614.16


**APPROVED :** 09/13/2001


**EXPIRES :** 10/29/2006

**NOTICE OF ACCEPTANCE: STANDARD CONDITIONS**

1. Renewal of this Acceptance (approval) shall be considered after a renewal application has been filed and the original submitted documents, including test-supporting data, engineering documents, are no older than eight (8) years.
2. Any and all approved products shall be permanently labeled with the manufacturer's name, city, state, and the following statement: "Miami-Dade County Product Control Approved", or as specifically stated in the specific conditions of this Acceptance.
3. Renewals of Acceptance will not be considered if:
  - a. There has been a change in the South Florida Building Code affecting the evaluation of this product and the product is not in compliance with the code changes.
  - b. The product is no longer the same product (identical) as the one originally approved.
  - c. If the Acceptance holder has not complied with all the requirements of this acceptance, including the correct installation of the product.
  - d. The engineer, who originally prepared, signed and sealed the required documentation initially submitted, is no longer practicing the engineering profession.
4. Any revision or change in the materials, use, and/or manufacture of the product or process shall automatically be cause for termination of this Acceptance, unless prior written approval has been requested (through the filing of a revision application with appropriate fee) and granted by this office.
5. Any of the following shall also be grounds for removal of this Acceptance:
  - a. Unsatisfactory performance of this product or process.
  - b. Misuse of this Acceptance as an endorsement of any product, for sales, advertising or any other purposes.
6. The Notice of Acceptance number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the Notice of Acceptance is displayed, then it shall be done in its entirety.
7. A copy of this Acceptance as well as approved drawings and other documents, where it applies, shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at all times. The engineer needs not reseal the copies.
8. Failure to comply with any section of this Acceptance shall be cause for termination and removal of Acceptance.
9. This Notice of Acceptance consists of pages 1, 2 and this last page 3.

**END OF THIS ACCEPTANCE**

  
\_\_\_\_\_  
Helmy A. Makar, P.E.- Product Control Examiner  
Product Control Division



NO.	DATE	BY	REVISION
2	10/98	KJP	TOP VIEW SCREWS
1	3/96	KJP	NOTE 2" TEK OPTION

DADE COUNTY, FLORIDA  
 DYNA RIB ROOF PANEL  
 ERECTION DETAILS  
 (JUL90)  
 (CHAPLET STYLE TRIM)

2141 2ND AVE SW  
 CULLMAN, AL 35055



SCALE:	DATE:
DRAWN:	
CHECKED:	9-10-98
FLORIDA REGISTERED ENGINEER	
KEITH SHEDD	
PE No. 48014	
<i>Keith Shedd</i>	
JOB NO.	SHEET NO. 1
DWG. NO.	962-752

- NOTES**
1. WALL PANEL SHOULD BE INSTALLED PRIOR TO ROOF PANEL INSTALLATION.
  2. MAKE SURE YOU USE THE CORRECT EAVE DETAIL FOR YOUR JOB.
  3. INSTALL EAVE FLASH PRIOR TO ROOF PANEL IF CHAPLET GUTTER IS REQ'D.
  4. CHECK PROJECT DRAWING FOR ANY SPECIAL CONDITIONS.
  5. ERECTION SEQUENCE SHOWN IS FROM RIGHT TO LEFT.
  6. MAINTAIN 36" PANEL COVERAGE,  $\phi$  TO  $\phi$  OF RIBS, DURING ERECTION.
  7. LENGTH & FINISH OF TEKS SUPPLIED. LL = LONG LIFE. 1 1/4" TEK IS STD., 2" TEK IS OPTIONAL.
  8. SWEEP PANELS DAILY, FILINGS RUST QUICKLY AND MAR THE PANEL FINISH.

**PRODUCT RENEWED**  
 ACCEPTANCE No. 01-0614.16  
 EXPIRATION DAT. 10/29/2006  
 By *Helmut A. Meier*  
 PRODUCT CONTROL DIVISION  
 BUILDING CODE COMPLIANCE OFFICE

