



**BUILDING CODE COMPLIANCE OFFICE**  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908

**CONTRACTOR LICENSING SECTION**  
(305) 375-2527 FAX (305) 375-2558

**CONTRACTOR ENFORCEMENT DIVISION**  
(305) 375-2966 FAX (305) 375-2908

**PRODUCT CONTROL DIVISION**  
(305) 375-2902 FAX (305) 372-6339

**PRODUCT CONTROL NOTICE OF ACCEPTANCE**

**Dow Chemical U.S.A.**  
**1605 Joseph Street, 200 Larkin Center**  
**Midland ,MI 48674**

Your application for Notice of Acceptance (NOA) of:

**Fast 100 P2 Spray N' Grip Polyurethane Foam Adhesive**

under Chapter 8 of the Code of Miami-Dade County governing the use of Alternate Materials and Types of Construction, and completely described herein, has been recommended for acceptance by the Miami-Dade County Building Code Compliance Office (BCCO) under the conditions specified herein.

This NOA shall not be valid after the expiration date stated below. BCCO reserves the right to secure this product or material at any time from a jobsite or manufacturer's plant for quality control testing. If this product or material fails to perform in the approved manner, BCCO may revoke, modify, or suspend the use of such product or material immediately. BCCO reserves the right to revoke this approval, if it is determined by BCCO that this product or material fails to meet the requirements of the South Florida Building Code.

The expense of such testing will be incurred by the manufacturer.

**ACCEPTANCE NO.: 01-0712.21**  
**EXPIRES: 09/17/2006**

Raul Rodriguez  
Chief Product Control Division

**THIS IS THE COVERSHEET, SEE ADDITIONAL PAGES FOR SPECIFIC AND GENERAL  
CONDITIONS  
BUILDING CODE & PRODUCT REVIEW COMMITTEE**

This application for Product Approval has been reviewed by the BCCO and approved by the Building Code and Product Review Committee to be used in Miami-Dade County, Florida under the conditions set forth above.

Francisco J. Quintana, R.A.  
Director  
Miami-Dade County  
Building Code Compliance Office

**APPROVED: 09/17/2001**

<b><u>Category:</u></b>	Roofing	<b><u>Approval Date:</u></b>	<b><u>09/17/01</u></b>
<b><u>Sub-Category:</u></b>	Cements-Adhesives and Coatings		
<b><u>Material:</u></b>	Polyurethane	<b><u>Expiration Date:</u></b>	<b><u>09/17/06</u></b>

**1. SCOPE:**

This approves **FAST 100 P2 Spray N' Grip Polyurethane Foam Adhesive** as manufactured by **Dow Chemical U.S.A.**, as described in Section 2 of this Notice of Acceptance. The use of this acceptance is limited to those roof assemblies **FAST 100 P2 Spray N' Grip Polyurethane Foam Adhesive** is specifically listed as an accepted component.

**2. PRODUCT DESCRIPTION:**

FAST™ 100P & "Spray N' Grip" Spray Polyurethane Foam Adhesive" with the properties described below:

<b>Description</b>	<b>Test</b>	<b>Properties</b>
<b>FAST™ 100P</b>		
Flame Spread Index	ASTM E84	10
Smoke Develop Index	ASTM E84	10
Flash Ignition Temperature	ASTM D1929-91	896° F
<b>Spray N' Grip</b>		
Flame Spread Index	ASTM E84	5
Smoke Develop Index	ASTM E84	10
Flash Ignition Temperature	ASTM D1929-91	752° F
Self Ignition Temperature	ASTM D1929-91	860° F

**3. LIMITATIONS:**

FAST 100P2 Spray N' Grip Polyurethane Foam Adhesive shall have a quality control testing program by an approved independent listing agency having unannounced follow-up visits. Follow up test results shall be made available to BCCO upon request.

**4. INSTALLATION:**

FAST 100 P2 Spray N' Grip Polyurethane Foam Adhesive shall be installed in strict compliance with the roof assembly's assemblies Notice of Acceptance, and manufacturer's published literature.

**5. LABELING:**

FAST 100 P2 Spray N' Grip Polyurethane Foam Adhesive containers shall comply with the Standard Conditions listed herein.

**6. BUILDING PERMIT REQUIREMENTS**

As required by the Building Official or the applicable Building Code in order to properly evaluate the installation of this system. This Notice of Acceptance on its own cannot be used to obtain a building permit.




Frank Zuloaga, RRC  
Product Control Examiner  
Product Control Division

**NOTICE OF ACCEPTANCE: STANDARD CONDITIONS**

1. Renewal of this Acceptance (approval) shall be considered after a renewal application has been filed and the original submitted documents, including test-supporting data, engineering documents, are no older than eight (8) years.
2. Any and all approved products shall be permanently labeled with the manufacturer's name, city, state, and the following statement: "Miami-Dade County Product Control Approval", or as specifically stated in the specific conditions of this Acceptance.
3. Renewals of Acceptance will not be considered if:
  - a. There has been a change in the South Florida Building Code affecting the evaluation of this product and the product is not in compliance with the code changes.
  - b. The product is no longer the same product (identical) as the one originally approved.
  - c. If the Acceptance holder has not complied with all the requirements of this acceptance, including the correct installation of the product.
  - d. The engineer who originally prepared, signed and sealed the required documentation initially submitted, is no longer practicing the engineering profession.
4. Any revision or change in the materials, use, and/or manufacture of the product or process shall automatically be cause for termination of this Acceptance, unless prior written approval has been requested (through the filing of a revision application with appropriate fee) and granted by this office.
5. Any of the following shall also be grounds for removal of this Acceptance:
  - a. Unsatisfactory performance of this product or process.
  - b. Misuse of this Acceptance as an endorsement of any product, for sales, advertising or any other purposes.
6. The Notice of Acceptance number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the Notice of Acceptance is displayed, then it shall be done in its entirety.
7. A copy of this Acceptance as well as approved drawings and other documents, where it applies, shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at all time. The engineer need not reseal the copies.
8. Failure to comply with any section of this Acceptance shall be cause for termination and removal of Acceptance.
9. This Notice of Acceptance consists of pages 2 through 3.

**END OF THIS ACCEPTANCE**



Frank Zuloaga, RRC  
Product Control Examiner  
Product Control Division

Dow Chemical U.S.A.

ACCEPTANCE No. : 01-0712.21

APPROVED: 09/17/2001

EXPIRES: 09/17/2006

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED  
(For File ONLY. Not part of NOA.)

A. DRAWINGS: NONE


B. TESTS:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Underwriters Laboratories Inc.	98NK29392	UL 723 ASTM E 84 ASTM D 1929	08/26/98

C. CALCULATIONS NONE

D. MATERIAL CERTIFICATIONS: NONE

E. STATEMENTS: NONE



Frank Zuloaga, RRC  
Product Control Examiner  
Product Control Division