



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

## **NOTICE OF ACCEPTANCE (NOA)**

---

**GAMMA, U. S. A.  
15407 West Dixie Highway  
N. Miami, FL 33162**

### **SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee (BCPRC) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The BCCO (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BCPRC reserves the right to revoke this acceptance, if it is determined by BCCO that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the South Florida Building Code, 1994 Edition for Miami-Dade County or Florida Building Code.

### **DESCRIPTION: Series 35.2 Aluminum Sliding Glass Door (OX)**

**APPROVAL DOCUMENT:** Drawing No. **SGD35.2SI**, titled "Series 35.2 Aluminum Sliding glass Door S. I. ", sheets 1 through 4 of 4, prepared by manufacturer, dated 16-07-01 and last revised on 2-7-02, signed and sealed by Farrokh Rasekhi, P. E., bearing the Miami-Dade County Product Control Approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division.

### **MISSILE IMPACT RATING: Small Missile Impact Resistant**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **01-0921.03** and consists of this page 1 as well as approval document mentioned above. The submitted documentation was reviewed by **Ishaq I. Chanda, P. E.**



**NOA No 01-0921.03  
Expiration Date: March 07, 2007  
Approval Date: March 07, 2002  
Page 1**

35.2 ALDORA 3 XO 48 120 90 SI




**Gamma**

15407 West Dixie Highway,  
North Miami Beach, FL 33162  
Phone: (305) 957-7004 FAX: (305) 957-7006



**ALDORA**

PROJECT:	SERIES 35.2 ALUMINUM SLIDING GLASS DOOR S.I.	DATE:	16-07-01
	DWG. NAME: SGD35.2SI	PROJECT #	0113
TITLE:	TYPICAL ELEVATION(FTL #3180)	SCALE:	



*Farrokh Rasekhi*  
Farrokh Rasekhi, P.E.  
Consulting Struct. Engineer  
FL. REG. NO. 38001  
2/7/02

**SHUTTER REQUIREMENTS:**  
1- INSTALLATION OF THIS UNIT ABOVE 30 FT ABOVE GRADE WILL NOT REQUIRE SHUTTERS  
2- MIAMI DADE COUNTY APPROVED SHUTTERS WILL BE REQUIRED FOR BELOW 30 FT ABOVE THE GRADE

**NOTES:**  
1- MAX SHIM SPACE OF 1/4"  
2- REFER TO BILL OF MATERIAL FOR COMPLETE DESCRIPTION

APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE  
DATE March 07, 2002  
BY Shaqi Chanda  
PRODUCT CONTROL DIVISION  
BUILDING CODE COMPLIANCE OFFICE  
ACCEPTANCE NO. 01-0921-03

**SMALL IMPACT TEST**  
DESIGN PRESSURE + 90 psf  
DESIGN PRESSURE - 90 psf

**TYPICAL ELEVATION**  
EXTERIOR VIEW

W/ 9/16" LAMINATED GLASS: 1/4"TEMP + 0.060 SAFLEX/ KEEP SAFE PVB BY SOLUTIA +1/4" TEMP. LAMINATED BY PRELCO.

R3 1-10-02	R4 2-7-02
R1 08/03/01	R2 08/29/01
J. D'HONDT	
REVISION:	D0113SGD2
DRAWN BY:	
CHECKED BY:	
CAD NAME:	
1	4

35.2 ALDORA 3 XO 48 120 90 SI

**Gamma**


15407 West Dixie Highway,  
North Miami Beach, FL 33162  
Phone: (305) 957-7004 FAX: (305) 957-7008



**ALDORA**

PROJECT:	SERIES 35.2 ALUMINUM SLIDING GLASS DOOR S.I.	DATE:	16-07-01
	DWG. NAME: SGD35.2SI	PROJECT #	0113
TITLE:	SECTIONS 005 TO007	SCALE:	1/2" = 1"

*Farrokh Rasekhi*  
Farrokh Rasekhi, P.E.  
Consulting Struct. Engineer  
FL. REG. NO. 38001  
2/7/02



NOTES:  
1- MAX SHIM SPACE OF 1/4"  
2- REFER TO BILL OF MATERIAL FOR COMPLETE DESCRIPTION

detail 007

EXTERIOR

detail 006

detail 005

APPROVED AS COMPLYING WITH THE  
SOUTH FLORIDA BUILDING CODE  
DATE March 07, 2002  
BY Isaac J. Chanda  
PRODUCT CONTROL DIVISION  
BUILDING CODE COMPLIANCE OFFICE  
ACCEPTANCE NO. 01-0921-03

R3 1-10-02	R4 2-7-02		
R1 08/03/01	R2 08/29/01	J. D'HONDT	
REVISION:	DRAWN BY:	CHECKED BY:	CAD NAME:
			D0113SGD2
2		4	



35.2 ALDORA 3 XO 48 120 90 SI



15407 West Dixie Highway,  
North Miami Beach, FL 33162  
Phone: (305) 887-7004 FAX: (305) 887-7008



**ALDORA**

DESCRIPTION	
1	ALUMINUM FRAME ( JAMB # XA-90636) AL 6063 T6
2	ALUMINUM SASH (TOP & BOTTOM RAIL # 997904) AL 6063 T6
3	9/16" LAMINATED GLASS GLASS BITE: 0.690 1/4" CLEAR TEMPERED GLASS (EXT) 0.060" PVB SAFLEX KEEPSAFE BY SOLUTIA LAMINATED BY PRELCO 1/4" CLEAR TEMPERED GLASS (INT)
4	ALUMINUM HEAD FRAME (TOP# XA-92256) AL 6063 T6
6	METTING RAIL DIE # 997906 AL 6063 T6
7	ELCO TAPCON SCREW 1/4" DIA. 2 1/4" LONG. (min. 1 1/4" embedment)
8	TPR EXTRUDED GASKET TP116
9	SCCELLANT SPECTREM2 (TREMCO)
10	TRUTH PLASTIC HANDLE # 40 STYLINE AND SINGLE POINT MORTISE LOCK #11487
11	POLYFLEX GASKET
12	TRUTH ROLLER # 39.20 (2 SETS PER PANEL)
13	#8 X 1" PH STS SCREW (5 PER FIXED PANEL)
14	THREE PLY STEEL HOOK LOCK TRUTH # 2300-1063
15	CONTINUOUS MOHAIR # DIE FS7635-187 SCHLEGEL
16	ALUMINUM FIXED SASH (TOP & BOTTOM RAIL # 997904) AL 6063 T6
17	STAINLESS STEEL ASSEMBLY SCREWS 1/4" -20 X 1" LONG (12 PER FRAME) 1/4"-20 SS SCREW
18	STAINLESS STEEL ASSEMBLY SCREWS 1/4" - 20 X 1 1/4" LONG (8 PER MOVING PANEL) (4 PER FIX PANEL)
19	DRAINING OUTSIDE RAIL (4X) SLOTS 1/4"X2"
20	METTING RAIL DIE # 997907 AL 6063 T6
21	PLASTIC MOULDING FOR MOHAIR AT HEAD & SILL
22	ALUMINUM ANGLE AT HEAD AND SILL 2"X2 3/4"X2 1/4" THICK (SEAL WITH SPECTREM2)
23	1/4"-20 X 1 1/2" LONG. STAINLESS STEEL SCREW ( 4 PER ANGLE)
25	ALUMINUM FRAME SILL (BOTTOM #947476) AL 6063 T6
27	FOAM UNDER FIXED PANEL 1/2" X 3/4"X 49"
28	DRAINING INSIDE RAIL (2X) SLOTS 1/4"X2"
29	MOHAIR PAD AT METTING RAIL (1 1/2"X3 13/16" BELOW INTERLOCK STILE, 1X3" BELOW MOVING PANEL INTERLOCK STILE)
30	2 X 4" PLASTIC EXTRUSION SUPPORT FOR FIXED PANEL # 51022000
31	PLASTIC BLOC AT MEETING RAIL
33	REINFORCEMENT 1 1/2" X 1 1/2" X 3/16" THICK X 111 1/2" LONG STEEL TUBE ASTM A500-GRADE B
34	PVC DOOR STOPPER
35	#8 F.H. STAINLESS STEEL METAL SCREW 1" LONG (2 PER REINFORCEMENT)
36	#8 x 3/4" PH STS/ST METAL SCREW
39	3" PLASTIC SHIM (2 PER INTERLOCK)
41	#14 x 3/4" F.H. STS METAL SCREW TOP AND BOTTOM
42	ALUM. SASH (STILES)FIX OPERABLE #997908 AL 6063 T6
43	ALUM. FOLDING 1/8"THICKx 5/8"x3/4"x5/8"x0'-3" LONG (FOR SILL)
44	ALUM. FOLDING 1/8"THICKx 17/32"x3/4"x17/32"x0'-3" LONG (FOR HEAD & JAMBS)

PROJECT:	SERIES 35.2 ALUMINUM SLIDING GLASS DOOR S.I.	DATE:	16-07-01
TITLE:	DESCRIPTION LIST	PROJECT #	0113
		SCALE:	

*Farrokh Rasekhi*  
Farrokh Rasekhi, P.E.  
Consulting Struct. Engineer  
FL. REG. NO. 38001  
2/7/02

APPROVED AS COMPLYING WITH THE  
SOUTH FLORIDA BUILDING CODE  
DATE March 07, 2002  
BY Ishaq I. Chanda  
PRODUCT CONTROL DIVISION  
BUILDING CODE COMPLIANCE OFFICE  
ACCEPTANCE NO. 01-0921.03

R3 1-10-02	R4 2-7-02		
R1 08/03/01	R2 08/29/01	J. D'HONDT	D0113SGD2
REVISION:	DRAWN BY:	CHECKED BY:	CAD NAME:
4			
			4

NOTE: SEAL INSTALLATION FASTENER HEADS, WITH SILICONE SEALANT SPECTREM2  
FRAME CORNER, PERIMETER ANGLES ARE SEALED WITH SILICONE SEALANT SPECTREM2  
PANEL CORNER SEAMS ARE SEALED WITH GUTTER SEAL