



MIAMI-DADE
BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

GAMMA, U. S. A.
15407 West Dixie Highway Inc.
N. Miami, FL 33162

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Series G-100 Aluminum S.H. Window Muller Together

APPROVAL DOCUMENT: Drawing No. P0104G1, titled "Single Hung Window G-100 Series", sheets 1 through 3 of 3, prepared by Farrokh Rasekhi, P. E., dated 1/16/02, bearing the Miami-Dade County Product Control Approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: Large and Small Missile Impact Test

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of this page 1 as well as approval document mentioned above.
 The submitted documentation was reviewed by **Raul Rodriguez**.



NOA No 01-0926.08
Expiration Date: March 21, 2007
Approval Date: March 21, 2002
Page 1

24 SINGLE HUNG 2 XX 42 78 110 LI

Gamma
USA

15407 West Dixie Highway,
North Miami Beach, FL 33162
Phone: (305) 957-7004 FAX: (305) 957-7006

WINDOW


PROJECT: SINGLE HUNG WINDOW G-100 SERIES

DATE: 05-23-01


PROJECT # 0104

TITLE: TYPICAL DETAILS 101-103


SCALE:



detail 103



detail 102



detail 101

Farrokh Rasekhi
1/16/02
Farrokh Rasekhi, P.E.
Consulting Struct. Engineer
FL. REG. NO. 38001

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE March 21, 2002
BY *[Signature]*
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 01-0926.08

FRAME CORNERS, MEETING RAIL SEAM SEALED WITH CLEAR SEALANT AS INDICATED

REVISION:	R2 07/25/01	R3 12/18/01
DRAWN BY:	PHILIPPE MICHAUD	
CHECKED BY:		
CAD NAME:	P01004G1	


2
3

24 SINGLE HUNG 2 XX 42 78 110 LI


Gamma
USA
15407 West Dixie Highway,
North Miami Beach, FL 33162
Phone: (305) 957-7004 FAX: (305) 957-7006

WINDOW


PROJECT:	SINGLE HUNG WINDOW G-100 SERIES	DATE:	05-23-01
TITLE:	TYPICAL DETAILS 104 - 107	PROJECT #	0104
		SCALE:	




detail 107



detail 106



detail 105



detail 104

Farrokh Rasekhi
1/16/02
Farrokh Rasekhi, P.E.
Consulting Struct. Engineer
FL. REG. NO. 38001

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE March 21, 2002
BY [Signature]
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 01-0926-08

REVISION:	R3 12/18/01	R2 07/25/01
DRAWN BY:	R1 07/06/01	PHILIPPE MICHAUD
CHECKED BY:		
CAD NAME:		P0104G1

3
3