



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Antonio Ramon Borjas S.A. (A.R.B.)
Plaza de la Cova S/N
Alicante, Spain**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The BCCO (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BCCO reserves the right to revoke this acceptance, if it is determined by BCCO that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the South Florida Building Code, 1994 Edition for Miami-Dade County or Florida Building Code.

DESCRIPTION: Antonio Ramon Borjas Two-piece mission barrel, tapered, clay roof tile

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.
The submitted documentation was reviewed by Frank Zuloaga, RRC



**NOA No.: 01-1005.02
Expiration Date: 11/26/06
Approval Date: 11/26/01
Page 1 of 3**

ROOFING ASSEMBLY APPROVAL

Category: Roofing
Sub Category: Roofing Tiles
Material: Clay

1. SCOPE

This new roofing system using Antonio Ramon Borjas Two-piece mission barrel, tapered, clay roof tile, as manufactured Coma Cast Corporation described in Section 2 of this Notice of Acceptance, designed to comply with the South Florida Building Code, 1994 Edition for Miami-Dade County. For the locations where the pressure requirements, do not exceed the design pressure values obtain by calculations in compliance with RAS 127 using the values listed in section 4 herein. The attachment calculations shall be done as a moment based system.

2. PRODUCT DESCRIPTION

<u>Manufactured by Applicant</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
A.R.B. Two-piece mission barrel, tapered, clay roof tile	l = 18" w = 8 1/4" - 6 1/4" 1/2" thick	ASTM C 1167	High profile two-piece mission barrel clay tile
Trim Pieces	l = varies w = varies varying thickness	ASTM C 1167	Accessory trim, clay roof pieces for use at hips, rakes, ridges and valley terminations.

2.1 COMPONENTS OR PRODUCTS MANUFACTURED BY OTHERS

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>	<u>Manufacturer</u>
Polypro® Expanding Urethane	N/A	PA 123	Two component expanding polyurethane adhesive	Polyfoam Products, Inc.

3. LIMITATIONS

- 3.1 Fire classification is not part of this acceptance.
- 3.2 For mortar or adhesive set tile applications, a static field uplift test shall be performed in accordance with RAS 106.
- 3.3 Applicant shall retain the services of a Miami-Dade County Certified Laboratory to perform quarterly test in accordance with PA 112, appendix 'A'. Such testing shall be submitted to the Building Code Compliance Office for review.
- 3.4 Minimum underlayment shall be in compliance with the applicable Roofing Applications Standards listed section 4.1 herein.
- 3.5 30/90 hot mopped underlayment applications may be installed perpendicular to the roof slope unless stated otherwise by the underlayment material manufacturers published literature.
- 3.6 This acceptance is for wood deck applications. Minimum deck requirements shall be in compliance with applicable building code.

4. INSTALLATION



NOA No.: 01-1005.02
Expiration Date: 11/26/06
Approval Date: 11/26/01
Page 2 of 3

- 4.1 Antonio Ramon Borjas Two-piece mission barrel, tapered, clay roof tile and its components shall be installed in strict compliance with Roofing Application Standard RAS 120.
- 4.2 Data For Attachment Calculations

Table 1: Average Weight (W) and Demensions (l x w) From PA 101 Testing			
Tile Profile	Weight-W (lbf)	Length-l (ft)	Width-w (ft)
A.R.B. two-piece mission barrel clay roof tile (Adhesive Set)	5.0	1.5	0.675


Table 2: Aerodynamic Multipliers - λ (ft³)	
Tile Profile	λ (ft ³) Direct Deck Application
A.R.B. two-piece mission barrel clay roof tile (Adhesive Set)	0.22

Table 3: Restoring Moments due to Gravity - M_g (ft-lbf)						
Tile Profile	2":12"	3":12"	4":12"	5":12"	6":12"	7":12"
	Direct Deck	DirectDeck	Direct Deck	Direct Deck	Direct Deck	Direct Deck
A.R.B. two-piece mission barrel clay roof tile (Adhesive Set)	3.61	3.55	3.47	3.38	3.27	3.16

Table 4: Attachment Resistance Expressed as a Moment - M_f (ft-lbf) for Adhesive Set Systems		
Tile Profile	Tile Application	Attachment Resistance
A.R.B. two-piece mission barrel clay roof tile	Adhesive Set ¹	223.2*

*Avg. patty weight 19.5grams (0.0435lbf)

PROFILE DRAWINGS



A.R.B. 2 PIECE MISSION BARREL TILE



NOA No.: 01-1005.02
 Expiration Date: 11/26/06
 Approval Date: 11/26/01
 Page 3 of 3

A. TESTS:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Celotex Corporation Testing Services	258258-A	Static Uplift Testing PA 101-95 (Adhesive Set)	March 1998
Celotex Corporation Testing Services	258415	Physical Properties ASTM C 1167	February 1998

B. OTHER

1. Notice of Acceptance number 01-1005.02