



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Desa International Inc.
2701 Industrial Drive.
Bowling Green, KY 42101**

SCOPE: This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Power Activated Drive Pins.

APPROVAL DOCUMENT: Drawing No. **ES26**, Sheets 1 of 1, titled "Remington Low-Velocity Power-Actuated Fasteners" dated 12/07/98 with last revision on 01/07/99, prepared by Desa International, signed and sealed by H. Wiewel, PE., bearing the Miami-Dade County Product Control Approval stamp with the Notice of Acceptance (NOA) number and expiration date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: None

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA # 98-1103.01 and consists of this page 1 as well as approval document mentioned above.

The submitted documentation was reviewed by **Candido F. Font PE.**



**NOA No: 01-1120.09
Expiration Date: April 8, 2007
Approval Date: July 11, 2002
Page 1**

Desa International Inc.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

(For File ONLY. Not part of NOA)

A. DRAWINGS

- 1 Drawing No. B-ES26, Sheets 1 of 1, titled "Remington Low-Velocity Power-Actuated Fastener," dated 12/07/98, with last revision 01/07/99, prepared by Desa International Inc., signed and sealed by H. Wiewel, P.E.

B. TESTS

1. Test report on Corrosion Testing of Fasteners per PA 114 Appendix E, prepared by Sub Tropical Testing Service, Test No. DSA-1A (P.O. # 69502), dated 05/19/98, signed and sealed by M. Mosbat PE.
2. Report of Results for Remington Power-Actuated Fasteners Tests, prepared by Techmar, Inc. Test Report No. TR-998, dated September 1998, signed and sealed by H. Wiewel PE.

C. CALCULATION

N/A

D. MATERIAL CERTIFICATIONS

N/A

E. STATEMENTS

1. Confirmation that H. Wiewel is an active Florida Professional Engineer.
2. No change letter issued by Odesa International Incorporated on 06/12/02 and signed by D. Roher.



Candido F. Font PE.
Sr. Product Control Examiner
NOA No 01-1120.09
Expiration Date: April 8, 2007
Approval Date: July 11, 2002

