



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**GAF Materials Corporation
1361 Alps Road
Wayne, NJ 07470**

SCOPE: This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The BCCO (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BCCO reserves the right to revoke this acceptance, if it is determined by BCCO that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the South Florida Building Code, 1994 Edition for Miami-Dade County or Florida Building Code.

DESCRIPTION: GAF Cobra Exhaust Vent for Roof Ridge.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.
The submitted documentation was reviewed by Frank Zuloaga, RRC.



**NOA No. 01-1129.01
Expiration Date: 11/09/03
Approval Date: 02/14/02
Page 1 of 3**

ROOFING ASSEMBLY APPROVAL

Category: Roofing
Sub-Category: 07720 Static Roof Vent
Materials: Plastic

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

| <u>Product</u> | <u>Dimensions</u> | <u>Test Specification</u> | <u>Product Description</u> |
|-------------------------------------|----------------------|---------------------------|--|
| COBRA RIDGE VENT | 3/4" x 10 1/2" x 20' | PA-100 | Low pro file attic ridge vent for installation under ridge shingles. |
| COBRA RIDGE VENT (For nail guns) | 5/8" x 10 1/2" x 20' | PA-100 | Low pro file attic ridge vent for installation under ridge shingles. |

EVIDENCE SUBMITTED:

| <u>Test Agency/Identifier</u> | <u>Name</u> | <u>Report</u> | <u>Date</u> |
|--------------------------------------|-----------------------|---------------|-------------|
| Center for Applied Engineering, Inc. | PA 110 | 07-07-00-67 | 04/25/94 |
| ETL Testing Laboratories | ASTM D 1929 | 509852 | 08/20/91 |
| ETL Testing Laboratories | ASHEAE Standard 52-76 | 509907 | 08/23/91 |



NOA No. 01-1129.01
Expiration Date: 11/09/03
Approval Date: 02/14/02
Page 2 of 3

APPROVED APPLICATIONS

- Tradename:** COBRA RIDGE VENT
- System Type C:** Mechanical attachment of ridge vent under composition ridge shingle.
- Slot:** Cut a 2" slot along the apex of the roof by cutting 1" on each side of the ridge. The 2" slot shall terminate approximately 6" from the rake edge.
- Installation:** Roll out ridge vent centered over the void, and secured 36" o.c. on each side of the ridge to hold it in place until ridge shingles can be installed. Extend to the rake edge. Roll ends or cut joints shall be butted together and caulked with an approved polyurethane sealant.
- Ridge Shingle:** Install pre-manufactured or field cut ridge shingles over the ridge vent in compliance with the shingle manufacturers Notice of Acceptance (NOA) and the installation instructions using 2" ring shank galvanized nails.
- Net Free Area:** Refer to manufacturers published literature
- Minimum Slope:** 3:12

LIMITATIONS:

1. Refer to applicable Building Code for required ventilation.
2. Ridge vent ventilators shall not be installed on roof mean heights greater than 33 ft.

END OF THIS ACCEPTANCE

