



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**GAF Materials Corp.
1361 Alps Rd.
Wayne, NJ 07470**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The BCCO (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BCCO reserves the right to revoke this acceptance, if it is determined by BCCO that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the South Florida Building Code, 1994 Edition for Miami-Dade County or Florida Building Code.

DESCRIPTION: GAF Slateline Shingle

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.
The submitted documentation was reviewed by Frank Zuloaga, RRC



**NOA No.:01-1203.06
Expiration Date: 06/07/06
Approval Date: 02/14/02
Page 1 of 3**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: 07310 Asphalt Shingles
Material: 5-Tab

1. SCOPE:

This revises GAF Slateline as manufactured by GAF Materials Corp described in this Notice of Acceptance, designed to comply with the South Florida Building Code, 1994 Edition for Miami-Dade County.

2. PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
GAF Slateline Shingle	17" x 40"	PA 110	Fiberglass reinforced Asphalt five tab shingle. All shingles shall be labeled on the underside with the Miami Dade insignia.

3. LIMITATION:

- 3.1 Fire Classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 3.2 GAF Slateline shall not be installed on roof mean heights in excess of 33 ft.

4. INSTALLATION:

- 4.1 Shingles shall be installed in compliance with Miami-Dade County Product Control Shingles Installation Procedure No.115
- 4.2 Flashing shall be in accordance with Section 9.3 Option "B" (step-flashings) of Miami-Dade County Product Control Shingle Installation Procedure No.115.
- 4.3 The manufacturer shall provide clearly written application instruction.
- 4.4 Exposure and course layout shall be in compliance with Detail "A", attached.
- 4.5 Nailing shall be in compliance with Detail "B", attached.

5. LABELING:

- 5.1 Shingles shall be labeled with the Miami-Dade Logo or the wording "Miami-Dade County Product Control Approved"


6. BUILDING PERMIT REQUIREMENTS:

- 6.1 Application for building permit shall be accompanied by copies of the following:
 - 6.1.1 This Notice of Acceptance
 - 6.1.2 Any other documents required by the Building Official or the applicable building code in order to properly evaluate the installation of this system.




NOA No.:01-1203.06
Expiration Date: 06/07/06
Approval Date: 02/14/02
Page 2 of 3

DETAIL A



DETAIL B



Nailing Pattern

END OF THIS ACCEPTANCE



NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED
(For File ONLY. Not part of NOA.)

A. TESTS

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Center for Applied Engineering	MDC - 134	PA 100	08/95
Center for Applied Engineering	257387	ASTM D3462	09/08/95
Underwriters Laboratories, Inc.	99NK9632	PA 107	10/11/95
Underwriters Laboratories, Inc.		UL 790	
Underwriters Laboratories, Inc.	01NK43792	PA 107	11/14/01

B. OTHER

1. Notice of Acceptance number 01-1203.06