



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

Continental Window & Door of Fl.
1985 NW 18th St.
Pompano Beach, Fl, 33069

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee (BCPRC) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The BCCO (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BCPRC reserves the right to revoke this acceptance, if it is determined by BCCO that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the South Florida Building Code, 1994 Edition for Miami-Dade County or Florida Building Code.

DESCRIPTION: Series "0001" PVC Frame Projected Windows

APPROVAL DOCUMENT: Drawing No. WO1-60, titled "Series-0001 PVC Frame Projected Windows," sheets 1 through 4, prepared, signed and sealed by Humayoun Farooq, P.E., dated 9/12/01, bearing the Miami-Dade County Product Control Approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: Large and Small Missile Impact

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of this page 1 as well as approval document mentioned above
The submitted documentation was reviewed by **Raul Rodriguez**.



NOA No 01-1206.02
Expiration Date: February 28, 2007
Approval Date: February 28, 2002
Page 1

MAXIMUM DESIGN LOAD RATING = + 65.0 PSF
 (FOR SIZES SHOWN OR SMALLER) - 65.0 PSF


WINDOWS GLAZED WITH LAMINATED GLASS RATED FOR
 LARGE MISSILE IMPACT AND REQUIRE NO SHUTTERS.

THIS PRODUCT IS DESIGNED AS PER THE SOUTH FLORIDA BUILDING
 CODE 1994 EDITION FOR DADE COUNTY. ALSO FOR WIND LOADS
 AS PER ASCE 7 USING CORRESPONDING LOADS.


WOOD BUCKS BY OTHERS, MUST BE ANCHORED PROPERLY TO TRANSFER
 LOADS TO THE STRUCTURE.

ANCHORS SHALL BE AS LISTED, SPACED AS SHOWN ON DETAILS.
 ANCHOR EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL
 DRESSING OR STUCCO.

ANCHORING OR LOADING CONDITIONS NOT SHOWN IN THESE DETAILS
 ARE NOT PART OF THIS APPROVAL.



7/16" THICK NOMINAL
 IMPACT RESISTANT GLASS
 LAMINATED BY 'GUARDIAN'
 SHUTTERS NOT REQUIRED




TYPICAL ELEVATIONS
 TESTED UNITS

Engr: DR. HUMAYOON FAROOQ
 STRUCTURES
 FLA. PE # 16557

NOV 19 2001

APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE February 28, 2002
 BY *[Signature]*
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 01-1206.02



AL-FAROOQ CORPORATION
 ENGINEERS, PLANNERS & PRODUCT DESIGN
 1235 SW 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W01-60CWF




S-0001 PVC FRAME PROJECTED WINDOWS
 CONTINENTAL WINDOWS & DOORS OF FLORIDA
 1985 N.W. 18TH STREET
 POMPANO BEACH, FL. 33069
 TEL. (954) 917-5380 FAX (954) 917-3472

revisions:	no	date	by	description

date: 09-12-01
 scale: 1/2" = 1"
 dr. by: HAMID
 chk. by:

drawing no.
W01-60

sheet 1 of 4



WOOD BUCKS NOT BY CONTINENTAL WINDOWS, MUST SUSTAIN LOADS IMPOSED BY GLAZING SYSTEM AND TRANSFER THEM TO THE BUILDING STRUCTURE.

TYPICAL ANCHORS: SEE ELEV. FOR SPACING

3/16" TAPCONS

INTO WOOD BUCKS OR WOOD STRUCTURE
 1-1/2" MIN. PENETRATION INTO WOOD
 THRU WOOD BUCKS INTO MASONRY OR DIRECTLY INTO MASONRY
 1-1/4" MIN. EMBED INTO CONC. OR MASONRY

#14 SMS OR 1/4" SELF DRILLING SCREWS

INTO METAL STRUCTURES (1/8" MIN. THICKNESS)
 INTO STEEL OR ALUMINUM MULLIONS

WEEPS:

W1 = 1/4" DRAIN HOLE AT 4-1/4" FROM ENDS
 W2 = 3/4" X 3/16" WEEP SLOT AT 4-1/4" FROM ENDS

Engr: DR. HUMAYOUN FAROOQ
 STRUCTURES
 FLA. PE # 16557
 NOV 19 2001

APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE February 28, 2002
 BY: [Signature]
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 01-1206.02

afc



AL-FAROOQ CORPORATION
 ENGINEERS, PLANNERS & PRODUCT DESIGN
 1235 SW 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W01-60CWF

S-0001 PVC FRAME PROJECTED WINDOWS
CONTINENTAL WINDOWS & DOORS OF FLORIDA
 1985 N.W. 18TH STREET
 POMPANO BEACH, FL. 33069
 TEL. (954) 917-5380 FAX (954) 917-3472

revisions:	no	date	by	description

date: 09-12-01	scale: 1/2" = 1"	dr. by: HAMID	chk. by:
----------------	------------------	---------------	----------

drawing no. **W01-60**
 sheet 2 of 4



ITEM	PART #	QUANTITY	DESCRIPTION	MATERIAL	MANF./SUPPLIER/REMARKS
1	1103	4	FRAME	PVC	CONTINENTAL EXTRUSIONS
2	1206	4	VENT	PVC	CONTINENTAL EXTRUSIONS
3	5804	AS REQD.	GLAZING STOP	PVC	PH TECH
4	-	-	IMPOST	PVC	CONTINENTAL EXTRUSIONS
5	-	AS REQD.	VENT WEATHERSTRIPPING	-	-
6	-	AS REQD.	FRAME WEATHERSTRIPPING	-	-
7	-	-	-	-	-
8	16271	-	'J' SHAPED REINFORCEMENT	ALUMINUM	-
9	-	-	BAR REINFORCEMENT	ALUMINUM	-
10	-	-	CHANNEL REINFORCEMENT	ALUMINUM	-
11	30744/31133/40942-A	2/ VENT	2 BAR CONCEALED HINGE	STEEL	TRUTH, AT 19" FROM BOTTOM
12	40618/40651	2/ VENT	SURFACE MOUNT LEVER TYPE LOCK	STEEL	TRUTH, AT JAMBS 6" FROM BOTTOM
13	21089	2/ VENT	LOCK KEEPER, AT FRAME JAMB FACING LOCK	STEEL	TRUTH, FASTENED WITH #8 X 1/2" PH SMS
14	453601/30897A	1	DUAL ARM OPERATOR	STEEL	TRUTH
15	-	OPTIONAL	SCREEN	-	-

AL-FAROOQ CORPORATION
 ENGINEERS, PLANNERS & PRODUCT DESIGN
 1235 SW 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W01-60CWF


S-0001 PVC FRAME PROJECTED WINDOWS
CONTINENTAL WINDOWS & DOORS OF FLORIDA
 1985 N.W. 18TH STREET
 POMPANO BEACH, FL. 33069
 TEL. (954) 917-5380 FAX (954) 917-3472

no	date	by	description


Engr: DR. HUMAYOON FAROOQ
 STRUCTURES
 FLA. PE # 16557
 NOV 19 2001

APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE February 28, 2002
 BY [Signature]
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 017266-02


date: 09-12-01
 scale: 1/2" = 1"
 dr. by: HAMID
 chk. by:
 drawing no.
W01-60
 sheet 3 of 4




FRAME




VENT




GLAZING STOP




IMPOST




REINFORCEMENTS



FRAME CORNER



IMPOST CORNER



VENT CORNER

Engr: DR. HUMAYOUN FAROOQ
STRUCTURES
FLA. PE # 16557

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE

DATE February 28, 2002

BY [Signature]

PRODUCT CONTROL DIVISION

BUILDING CODE COMPLIANCE OFFICE

ACCEPTANCE NO. 01-1206.02

NOV 19 2001

af

AL-FAROOQ CORPORATION
ENGINEERS, PLANNERS & PRODUCT DESIGN
1235 SW 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978
COMP-ANL\W01-60CWF

S-0001 PVC FRAME PROJECTED WINDOWS
CONTINENTAL WINDOWS & DOORS OF FLORIDA
1985 N.W. 18TH STREET
POMPANO BEACH, FL. 33069
TEL. (954) 917-5380 FAX (954) 917-3472

revisions:
no. date by description

date: 09-12-01

scale: 1/2" = 1"

dr. by: HAMID

chk. by:

drawing no.

W01-60

sheet 4 of 4