



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Elk Corporation of Alabama
4600 Stillman Blvd.
Tuscaloosa, AL 35401**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The BCCO (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BCCO reserves the right to revoke this acceptance, if it is determined by BCCO that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the South Florida Building Code, 1994 Edition for Miami-Dade County or Florida Building Code.

DESCRIPTION: Prestique Gallery Collection 40, Prestique Gallery Collection, or Prestique Plus

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.

The submitted documentation was reviewed by Frank Zuloaga, RRC



**NOA No.: 01-1226.03
Expiration Date: 07/12/06
Approval Date: 02/14/02
Page 1 of 3**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub Category: Shingles
Materials: Laminate

1.SCOPE

This renews EIK Prestique Gallery Collection 40 Fiberglass manufactured by EIK Corporation of Alabama described in Section 2 of this Notice of Acceptance, designed to comply with the South Florida Building Code, 1994 Edition for Miami-Dade County.

2. PRODUCT DESCRIPTION

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
EIK Prestique Gallery Collection 40, Prestique Gallery, or Prestique Plus	13 ¹ / ₄ " x 39 ³ / ₈ "	PA 110	A heavy weight laminated asphalt shingle with a propriatery profile.

3 LIMITATIONS

- 3.1 Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 3.2 Shall not be installed on roof mean heights in excess of 33 ft.

4 INSTALLATION

- 4.1 Shingles shall be installed in compliance with Miami-Dade County Product Control Shingle Installation Procedure No. 115.
- 4.2 Flashing shall be in accordance with Section 9.3 Option "B" (Step-flashing) of Miami-Dade County Product Control Shingle Installation Procedure No. 115
- 4.3 The manufacturer shall provide clearly written application instructions.
- 4.4 Exposure and course layout shall be in compliance with Detail 'A', attached.
- 4.5 Nailing shall be in compliance with Detail 'B', attached.

5 LABELING

- 5.1 Shingles shall be labeled with the Miami-Dade Logo or the wording "Miami-Dade County-Dade Product Control Approved".


6 BILDING PERMIT REQUIREMENTS

- 6.1 Application for building permit shall be accompanied by copies of the following:
 - 6.1.1 This Notice of Acceptance.
 - 6.1.2 Any other documents required by the Building Official or the Applicable Building Code in order to properly evaluate the installation of this system




NOA No.: 01-1226.03
Expiration Date: 07/12/06
Approval Date: 02/14/02
Page 2 of 3

DETAIL A



DETAIL B

39 3/8" Prestique Gallery Collection 40, Prestique Gallery Collection, Prestique Plus



END OF THIS ACCEPTANCE



NOA No.: 01-1226.03
Expiration Date: 07/12/06
Approval Date: 02/14/02
Page 3 of 3

NOTICE OF ACCEPTANCE:EVIDENCE SUBMITTED

(For File ONLY. Not part of NOA.)

EVIDENCE SUBMITTED

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Center for Applied Engineering	PA 100	Uplift and wind driven rain resistance.	07/13/94
Underwriters Laboratories, Inc.	PA 107	Wind uplift resistance	05/27/94

C.CALCULATIONS: <enter calculations received for use of coefficients>

D.MATERIAL CERTIFICATIONS: NONE

E.STATEMENTS: NONE

F. OTHER

1. Association member <enter name of association and its approval document number>
Notice of Acceptance number 00-0720.02