



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Nachon Enterprises, Inc.
350 West 23rd Street
Hialeah, FL 33010**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Series "2130" Outswing Raised Panel Wood Door

APPROVAL DOCUMENT: Drawing No. 99001, titled "FBMA Series 2130 Door", sheets 1 through 3, prepared by manufacturer, dated 6/17/99, bearing the Miami-Dade County Product Control Renewal stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: None

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.


INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **renews NOA # 98-1013.04** and, consists of this page 1 as well as approval document mentioned above. The submitted documentation was reviewed by **Raul Rodriguez**.



**NOA No 02-0125.05
Expiration Date: October 20, 2006
Approval Date: May 2, 2002
Page 1**


DOOR AND FRAME SYSTEM				
ITEM #	DESCRIPTION	ALTERNATE 1	ALTERNATE 2	ALTERNATE 3
1	DOOR MODEL 2130-MANUFACTURER(S)	ROGUE VALLEY		SIMPSON
2	JR300 T-ASTRAGAL WITH (2) 1/8" SCHED 40x 8 1/4" LONG STL PIPE SLEEVES BORED TO CLEAR #3. WITH GLUE, 7/16" X 2" STAPLES 15" OC, & (16) #6 X 2" FHWS (4 EA SIDE OF SLEEVE). WEATHERSTRIP - SCHLEGEL #QDS-650			
3	EXTENSION FLUSH BOLTS - QUALITY MFG #1358			
4	SINGLE SURFACE DEAD BOLTS - MFR & MODEL #.	SCHLAGE #B180N	KWKSET #666	SCHLAGE #B180N
	WITH A MODIFIED M.A.G. ENG. LOCK REINFORCER #20-PB			
5	PASSAGE LOCK - MFR & MODEL #.	SCHLAGE #F10N	KWKSET #200E	SCHLAGE #F10N
	CENTER 36" FROM BOTTOM OF DOOR.			
6	SINGLE CYLINDER DEAD BOLT - MFR & MODEL #.	SCHLAGE #B160N (5.5")	KWKSET #660 (12")	SCHLAGE #B160N (12")
	(CENTER ABOVE PASSAGE LOCK).			
7	4" X 4" BUTT HINGE WITH SAFETY STUD - HAGER #1843 & PENROD #MH40AJAC (MIXED). CENTER 6-3/4" AND 84" FROM TOP OF DOOR. SCREWS - TO DOOR: (4) #9 X 1/4" FHWS. TO JAMB: (3) #9 X 1/4" FHWS & (1) #9 X 2-1/2" FHWS.			
8	4" X 4" BUTT HINGE - HAGER #1841 & PENROD #MH40AUWS (MIXED). CENTER 31-3/4" AND 58" FROM TOP OF DOOR. SCREWS - TO DOOR: (4) #9 X 3/4" FHWS. TO JAMB: (3) #9 X 3/4" FHWS & (1) #9 X 2-1/2" FHWS.			
9	THRESHOLD-MODEL #JR100 (DEPTH X NOSE HEIGHT) WTHRSTRIP-SCHLEGEL MODEL #	2-1/2" X 1-1/8" #QDS-650	2-1/2" X 7/8" #QDS-650	3" X 1-1/8" #QEB-928
10	FRAME - 1-1/4" X	4 9/19"		5-1/4"
	RABBETED AND KERFED FOR WEATHERSTRIP. EACH CORNER WAS CAULKED AND ATTACHED WITH (3) 7/16" X 2" GUN DRIVEN STAPLES. WEATHERSTRIP - SCHLEGEL #QDS-650.			
11	HEADER TO MATCH FRAME - WITH 3/8" PLYWOOD ATTACHED WITH GLUE & 3/4" STAPLES 1" TO 1-1/4" FROM EACH EDGE & 8-3/4" (AVG) O.C.			
	WEATHERSTRIP - SCHLEGEL MODEL #	#QDS-650		QEB-928
12	2" X 3" X 0.007" VINYL FLAP GLUED TO BOTTOM OF ASTRAGAL.			
13	FRAME SCREWS TO 2X WOOD BUCK - #10 X 2-1/2" FHWS. 6" FROM CORNERS & 24" OC (MAX). FRAME JAMBS AND HEAD.			
14	PEMCO #588 SELF ADHESIVE WEATHERSTRIP AT OUTSIDE EDGE AT TOP OF BOTH DOORS.			
14	PEMCO #588 AT OUTSIDE EDGE AT LOCK STILE OF ACTIVE DOOR.			OMITTED
15	PEMCO #345AV RAIN DRIP & SWEEP.			
16	PAD/DIVERTER AT BOTTOM OF EACH JAMB.	1" X 2" X 3/16"		
16	PAD/DIVERTER AT BOTTOM OF ASTRAGAL.	SELF ADHESIVE PILE PAD.		




DESIGN PRESSURE RATING
+48.3 PSF
-63.4 PSF

THESE DOORS REQUIRE MIAMI DADE COUNTY APPROVED SHUTTERS.

ITEM #2
J-R #300 ASTRAGAL W/ SLEEVES & KERFED FOR WEATHERSTRIP




ITEM #9
J-R #100 THRESHOLD
WOOD & ALUM W/ QDS WEATHERSTRIP




PRODUCT RENEWED
as complying with the Florida Building Code
Acceptance No. 02-0125.05
Expiration Date October 20, 2006
By: *[Signature]*
Miami Dade Product Control Division


Drawn by: E.D. & D.
Date: 6/17/99
Revisions:
Drawing #99001
Drawing Title:
FBMA SERIES 2130 DOOR
Page 1 of 3




SECTION C-C



SECTION A-A



SECTION B-B



ITEM #4

LOCK REINFORCER BY M.A.G. ENG. MODIFIED

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No 02-0125.05
Expiration Date October 20, 2006

By *[Signature]*
Miami Dade Product Control
Division

Drawn by: E.D. & D.

Date: 5/17/99

Revisions:

Drawing #99001

Drawing Title:
FBMA SERIES 2130 DOOR


Page 2 of 3

1 3/4 FRONT ENTRANCE DOORS (EXTERIOR) — MODEL 2130


MAXIMUM PANEL WIDTH 36"

Minimum Dimensions


Stiles & top rail.....	4-1/2"
Lock rail.....	7-1/2"
Intermediate rail & mullion.....	2-1/8"
Bottom rail.....	9"
Panels Raised.....	3/4"




FLORENTINE 4101




TANGIER 4104




AZTEC 4105




BRITANNIA 4108




MARINER 4109




2060




2010




2130




2011




2009




FLORENTINE 4401



TANGIER 4404




AZTEC 4405




BRITANNIA 4408




MARINER 4409




Duadrille 4080




Grandee 4115




Colonial VI 3130




Colonial VIII 3010




Madrid 4112




FLORENTINE 4201




TANGIER 4204




AZTEC 4205




BRITANNIA 4208



MARINER 4209



Colonial IV 3044
6'-8" ONLY



Chateau 4180
6'-8" ONLY

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 02-0125.05
Expiration Date: October 24, 2006
By: 
Miami Dade Product Control
Division

Drawn by: E.D. & D.

Date: 6/17/99

Revisions:

Drawing #99001

Drawing Title:

FBMA SERIES 2130 DOOR