



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Glasswall and Doors, Inc.
3945 NW 32 Avenue
Miami, FL 33142**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Series 101 Aluminum Window Wall – Small Missile Impact

APPROVAL DOCUMENT: Drawing No. **02-0160**, dated 02/11/02, with revision #2 dated 6/29/02, titled "Series: 101 Aluminum Window Wall Small Missile Impact", sheets 1 through 4, prepared by Kelvyn A. Whitfield, Mechanical Engineer, signed and sealed by Kelvyn A. Whitfield, P.E., bearing the Miami-Dade County Product Control Approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.


INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **revises NOA # 01-0402.02** and consists of this page 1 as well as approval document mentioned above. The submitted documentation was reviewed by **Manuel Perez, P.E.**




**NOA No 02-0429.04
Expiration Date: Sept. 27, 2006
Approval Date: July 25, 2002
Page 1**

GLASSWALL, SERIES 101 WINDOW WALL, BASED ON CONSTRUCTION TESTING CORPORATION No. 01-002.




Design Load Capacity (P. S. F.)	
Positive	Negative
110.0	110.0

(4) #14 x 1' S.M.S. (INTERNALLY) TYPICAL
 (8) #14 x 1' S.M.S. (INTERNALLY) TYPICAL



DETAIL 2



DETAIL 1

NOTES:

1. USE DOUBLE ROW OF FASTENERS FOR HEAD
2. THIS WINDOW SYSTEM IS DESIGNED AND TESTED TO COMPLY WITH THE REQUIREMENTS OF THE 1994 DADE COUNTY EDITION OF THE FLORIDA BUILDING CODE (S.F.B.C.) CHAPTER 4, 23 & 35, UNDER THE SPECIFIC CONDITIONS SHOWN ON THIS DRAWING
3. ALL EXTRUSIONS ARE ALUMINIUM, 6005-T5 ALLOY
4. BASED ON REPORT LABORATORY No. 3349 FENESTRATION TESTING LAB., INC.
5. REVISION OF WINDOW WALL SYSTEM NOA 01-0402.02

Approved as complying with the Florida Building Code
 Date July 13, 2006
 NOA# 02-0429.04
 Miami Dade Product Control Division
 By [Signature]

KELVYN A. WHITFIELD
 MECHANICAL ENGINEER
 1002 N.E. 116 ST- MIAMI FL. 33161
 TEL. (305) 659 1230
 FAX. (305) 895 9976

GLASS WALL
 3550 N.W. 49 St
 MIAMI, FL. 33142
 PHONE: (305) 638-5151

SERIES: 101 ALUMINUM WINDOW WALL
 SMALL MISSILE IMPACT

JOB NO.: 02-0160
 DWG. NO.: 02-0160


REVISIONS DESCRIPTION

NO.	DATE	DESCRIPTION
1	5/25/02	AS PER DADE COUNTY REQUIREMENTS
2	8/20/02	AS PER DADE COUNTY REQUIREMENTS


DATE: 02/11/02
 SCALE:
 DWG. BY: D.M
 SHEET 1 OF 4

KELVYN A. WHITFIELD
 MECH. ENGINEER.
 FLA. PE # 24140


6/21/02




101-002 Jamb
HALF SCALE




101-003 Male Vertical Mull
HALF SCALE




101-004 Female Vertical Mull
HALF SCALE




101-006 Snap Cover
HALF SCALE



101-007 Glazing Bead
HALF SCALE



101-005 Glazing Bead
HALF SCALE



Mullion 101-008
HALF SCALE

KELVYN A. WHITFIELD
MECHANICAL ENGINEER
1002 NE 116 ST- MIAMI FL. 33161
TEL. (305) 659 1230
FAX. (305) 895 9976

GLASS WALL
3550 N.W. 49 St
MIAMI, FL. 33142
PHONE: (305) 638-5151

SERIES: 101 ALUMINUM
WINDOW WALL
SMALL MISSILE IMPACT

JOB NO.: 02-0160
DWG. NO.: 02-0160


REVISIONS DESCRIPTION

NO.	DATE	DESCRIPTION
1	5/25/02	AS PER DADE COUNTY REQUIREMENTS
2	6/20/02	AS PER DADE COUNTY REQUIREMENTS



DATE: 02/11/02
SCALE:
DWG. BY: D.M
SHEET 2 OF 4

KELVYN A. WHITFIELD
MECH. ENGINEER.
FLA. PE # 24140

6/21/02
[Signature]



SECTION A



SMALL MISSILE GLAZING DETAIL
0.504" LAMINATED GLASS

KELVYN A. WHITFIELD
MECHANICAL ENGINEER
1002 N.E. 116 ST- MIAMI FL. 33161
TEL. (305) 659 1230
FAX. (305) 895 9976

GLASS WALL
3550 N.W. 49 St
MIAMI, FL. 33142
PHONE: (305) 638-5151

SERIES: 101 ALUMINUM
WINDOW WALL
SMALL MISSILE IMPACT

JOB NO.: 02-0160
DWG. NO.: 02-0160

REVISIONS DESCRIPTION

NO.	DATE	DESCRIPTION
1	5/25/02	AS PER DADE COUNTY REQUIREMENTS
2	6/20/02	AS PER DADE COUNTY REQUIREMENTS

DATE: 02/11/02
SCALE:
DWG. BY: D.M
SHEET 3 OF 4


KELVYN A. WHITFIELD
MECH. ENGINEER.
FLA. PE # 24140

6/21/02
[Signature]

Approved as complying with the
Florida Building Code
Date July 6, 2002
NOAH 02-0429.04
Miami Dade Product Control
Division
By *[Signature]*


SECTION B

SECTION E




Head Receptor # 100-011

HALF SCALE



Head Receptor Reinforcement # 100-010
18' Long

HALF SCALE



101-001 Head & Sill

HALF SCALE

KELVYN A. WHITFIELD

MECHANICAL ENGINEER
1002 NE 116 ST- MIAMI FL. 33161
TEL. (305) 659 1230
FAX. (305) 895 9976

GLASS WALL
3550 N.W. 49 St
MIAMI, FL. 33142
PHONE: (305) 638-5151

SERIES: 101 ALUMINUM
WINDOW WALL
SMALL MISSILE IMPACT

JOB NO.: 02-0160

DWG. NO.: 02-0160

REVISIONS DESCRIPTION

NO.	DATE	DESCRIPTION
1	5/25/02	AS PER DADE COUNTY REQUIREMENTS
2	6/20/02	AS PER DADE COUNTY REQUIREMENTS

DATE: 02/11/02

SCALE:

DWG. BY: D.M

SHEET 4 OF 4

KELVYN A. WHITFIELD
MECH. ENGINEER.
FLA. PE # 24140

6/21/02

Approved as complying with the
Florida Building Code
Date July 5, 2002
NOA# 02-0429.04
Miami Dade Product Control
Division
By: Mamuel Perez

Item Number	Part Number	Part Name	Remarks
1	101-001	Head & Sill	Frame
2	101-002	Jamb	Frame
3	101-003	Male Vertical Mull	Frame
4	101-004	Female Vertical Mull	Frame
5	101-005	Glazing Bead	Frame
6	101-006	Snap Cover	Frame
7	101-007	Glazing Bead	Frame
8	101-008	Mullion	Frame
9	100-011	Head Receptor	Frame
10	100-010	H/R Reinforcement	Frame 18" Long.
11	679-FP-688B	Gasket	Gasket for Small Missile
12	7P-448	Gasket	Part # 568-61279 - 00914-18701 Prototype Plastics
13		# 14 x 1 PH-PH-SMS	Screw # 14 x 1 PH-PH-SMS
14		Setting Block	EPDM 1/4 X 3/4 X 4' LG.