



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Tamko Roofing Products, Inc.
P.O. Box 1404
Joplin, MO 64802**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: TAMKO ASTM Heritage 30, 40 & 50 Roof Shingles

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This consists of pages 1 through 4.

The submitted documentation was reviewed by Frank Zuloaga, RRC



**NOA No.: 02-0501.03
Expiration Date: 03/21/07
Approval Date: 05/30/02
Page 1 of 4**

ROOFING ASSEMBLY APPROVAL

Category:	Roofing
Sub-Category:	07310 Composition Shingles
Materials	Dimensional
Deck Type:	Wood

1. SCOPE:

This approves **Tamko ASTM Heritage 30 AR, Heritage 40 AR and Heritage 50 AR** Asphalt Shingles, manufactured by **Tamko Roofing Products, Inc.** as described in this Notice of Acceptance.

2. PRODUCT DESCRIPTION

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
ASTM Heritage 30 AR	12" x 37"	PA 110	A heavy weight, 240lb/sq, dimensional asphalt shingle.
Heritage 40 AR	12" x 36"	PA 110	A heavy weight, 275lb/sq, dimensional asphalt shingle.
Heritage 50 AR	12" x 36"	PA 110	A heavy weight, 305lb/sq, dimensional asphalt shingle.

3. LIMITATIONS

- 3.1 Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 3.2 Shall not be installed on roof mean heights in excess of 33 ft.

4. INSTALLATION

- 4.1 Shingles shall be installed in accordance with Roofing Application Standard RAS 115.
- 4.2 The manufacturer shall provide clearly written application instructions.
- 4.3 Exposure and course layout shall be in compliance with Detail 'A', attached.
- 4.4 Nailing shall be in compliance with Detail 'B', attached.

5. LABELING

- 5.1 Shingles shall be labeled with the Miami-Dade Logo or the wording "Miami-Dade County-Product Control Approved".

6. BUILDING PERMIT REQUIREMENTS


- 6.1 Application for building permit shall be accompanied by copies of the following:
 - 6.1.1 This Notice of Acceptance.
 - 6.1.2 Any other documents required by the Building Official or the applicable Building Code in order to properly evaluate the installation of this system.



DETAIL A


ASTM HERITAGE 30

All dimensions are in inches.



HERITAGE 40 & 50

All dimensions are in inches.




DETAIL B

ASTM HERITAGE 30

12" x 37" LAMINATED SHINGLE


All dimensions are in inches.



HERITAGE 40 & 50

12" x 36" LAMINATED SHINGLE

All dimensions are in inches.



END OF THIS ACCEPTANCE



NOA No.: 02-0501.03
Expiration Date: 03/21/07
Approval Date: 05/30/02
Page 4 of 4

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED
(For File ONLY. Not part of NOA.)

A. EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Underwriters Laboratories, Inc.	PA 107	01NK409172	12/04/01
Underwriters Laboratories, Inc.	Letter ASTM D3462	R2919	02/25/02
PRI Asphalt Technologies, Inc.	PA 100	TAP-052-02-01 TAP-053-02-01 TAP-054-02-01	11/28/01 11/29/01 11/29/01

B. OTHER

1. Notice of Acceptance number 02-0130.02