



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**GAF Material Corporation
1361 Alps Road
Wayne, NJ 07470**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: GAF EverGuard TPO Single Ply Roofing System over Concrete Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 6.
The submitted documentation was reviewed by Frank Zuloaga, RRC.



**NOA No: 02-0507.10
Expiration Date: 07/13/08
Approval Date: 07/17/03
Page 1 of 6**

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	TPO, Single Ply Roofing
Deck Type:	Concrete
Maximum Design Pressure	-67.5 psf
Fire Classification:	See General Limitation #1

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
EverGuard TPO White Membrane (Grey and Tan)	Various	ASTMD 4434	ThermoPlastic Olefin reinforce membrane.
EverGuard TPO EX -White Membrane (Grey)	Various	ASTMD 4434	ThermoPlastic Olefin reinforce membrane.
EverGuard TSR-45 Utility Flashing Membrena	Various	ASTMD 4434	Reinforced flashing membrane.
EverGuard UN-60 Detailing Membrena	Various	ASTMD 4434	60 mil unreinforced flashing membrane.
EverGuard XHD Fasteners	1=2"-14"	PA 114	Self tapping coated screw w/#3 Phillips head.
EverGuard EGX plate	2-3/8" dia	PA 114	AZ55 Galvaluve coated barber steel plate used with fastener.
EverGuard EGHD plate	2" dia	PA 114	AZ55 Galvaluve coated barber steel plate used with fastener.
EverGuard Coated Metal	4' x 8' 4' x 10' sheets	US Commercial Standard CS- 245-62	EverGuard membrane laminated 24 Ga. galvanized steel.
EverGuard Universal Corners	4" x 4" x 4" 20 pcs. crtn.	ASTM D 4434	Prefabricated molded one piece corners.
EverGuard Boots	1" - 8" od 6 pcs. crtn.	ASTM D 4434	Premolded vent pipe boots.
EverGuard Bonding Adhesive	5 gallon pails	proprietary	Adhesive for fully adhered systems and membrane flashing.
EverGuard H ₂ O Bonding Adhesive (TACC FA656)	5 gallons	Proprietary	Water based rubberized adhesive for fully adhered TPO systems and membrane flashing.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
EverGuard TPO Bondind Adhesive	5 gallons	Proprietary	Solvent based rubberized adhesive for fully adhered TPO systems and membrane flashing.
EverGuard Cut Edge Sealant	1 quart squeeze tube	Proprietary	Solvent based sealant for TPO cut edges.
EverGuard Aluminum Termination Bar	1/8 x 1" x 10	PA 114	Lip termination bar.
EverGuard Masonry Anchors	Various	PA 117	Masonry anchor with drive pin.
EverGuard Expansion Joint Cover	4"-8" x 50'		Low profile expansion joint cover.
EverGuard Drain Inserts	3", 4", 5" & 6" dia.	PA 117	Rigid molded TPO drain inserts.
EverGuard Standard Walkway	1/8" x 30" x 36"		Standard duty walkway pad.
EverGuard Heavy Duty Walkway	1/4" x 30" x 36"		Heavy duty walkway pad.

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
EverGuard Isocyanurate	Polyisocyanurate foam insulation	GAF Materials Corp.
GAFTEMP® Isotherm R, RA	Polyisocyanurate foam insulation	GAF Materials Corp.
GAFTEMP Permalite	Perlite insulation board.	GAF Materials Corp.
GAFTEMP High Density Fiberboard	Wood fiber insulation.	GAF Materials Corp.
BMCA EnergyGuard, RA	Polyisocyanurate foam insulation	BMCA
BMCA Composite EnergyGuard	Polyisocyanurate/wood fiberboard composite	BMCA
PYROX	Polyisocyanurate foam insulation	Apache Products Co.
ACFoam II	Polyisocyanurate foam insulation	Atlas Energy Products
Dens Deck	Gypsum Insulation Board	Georgia Pacific



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	EverGuard Concrete Spike Fasteners	Concrete insulation fasteners.	Various	GAF Materials Corp.
2.	EverGuard Insulation Plates	Round 3" plastic plate.	3" round	GAF Materials Corp.
3.	EverGuard Insulation Plates	Round 3" galvalume plate.	3" round	GAF Materials Corp.
4.	EverGuard Membrane Plates	Round 2" nylon reinforced seam plate.	2" round	GAF Materials Corp.

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corporation	3003617	FM 4470	12/20/99
Underwriters Laboratories	File R1306	Fire Classification	05/20/99
IRT-Arcon	02-001, 002, 003, 004	TAS 114	01/17/02



APPROVED ASSEMBLIES:

Deck Type 3I: Concrete Decks, Insulated, New Construction

Deck Description: 2500 psi structural concrete.

System Type D: Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EverGuard Isocyanurate, GAFTEMP Isothem R, Isothem RA, Pyrox, AC Foam II, BMCA EnergyGuard Minimum 1" thick	N/A	N/A

Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder may be installed over the deck or the base layer of insulation.

Barrier: (Optional) 1/2" or 5/8" gypsum or Dens Deck secured to the deck with the insulation.

Membrane: EverGuard TPO or EverGuard TPO-EX Membrane attached through the preliminary attached insulation as specified below.

Fastening #1: Membrane is mechanically attached using EverGuard XHD Fasteners and EverGuard EGX Plates spaced 6" o.c. within minimum 5" wide laps. Laps are spaced at maximum 114.5" o.c. and sealed with a minimum 1.5" wide heat weld. **Maximum Design Pressure –45 psf (See General Limitation #7)**

Fastening #2: Membrane is mechanically attached using EverGuard XHD Fasteners and EverGuard EGHD Plates spaced 6" o.c. within minimum 5" wide laps. Laps are spaced at maximum 114" o.c. and sealed with a minimum 5" wide heat weld. **Maximum Design Pressure –67.5 psf (See General Limitation #7)**

Maximum Design Pressure: See Fastening Above.



CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117, calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**

END OF THIS ACCEPTANCE



NOA No: 02-0507.10
Expiration Date: 07/13/08
Approval Date: 07/17/03
Page 6 of 6