



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

---

**Kensington Windows, Inc.  
One Kiski Valley Industrial Park, RD #1  
Vandergrift, PA 15690**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: PVC Frame Double Hung Windows**

**APPROVAL DOCUMENT:** Drawing No. **W02-24**, dated 03/19/02, titled "PVC Frame Double Hung Windows", sheets 1 through 4, prepared by Al-Farooq Corporation, signed and sealed by Humayoun Farooq, P.E., bearing the Miami-Dade County Product Control Approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division.

**MISSILE IMPACT RATING: Large and Small Missile Impact**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.



**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

The submitted documentation was reviewed by **Jaime Eisen, P.E.**




**NOA No 02-0523.04  
Expiration Date: August 15, 2007  
Approval Date: August 15, 2002  
Page 1**



MAX. DESIGN LOAD RATING = + 58.0 PSF  
 ( FOR SIZE SHOWN ABOVE OR SMALLER ) - 67.0 PSF

MAX. DESIGN LOAD RATING = + 50.0 PSF  
 ( FOR SIZE SHOWN ABOVE OR SMALLER ) - 55.0 PSF

TYPICAL ELEVATION  
 TESTED UNITS



7/8" OVERALL LAM. INSUL. GLASS  
 LARGE MISSILE IMPACT RESISTANT  
 MANF. BY 'PROTECTIVE GLASS IND.'

**PVC FRAME DOUBLE HUNG WINDOW**

WINDOWS GLAZED WITH LAMINATED INSULATED GLASS RATED FOR LARGE MISSILE IMPACT AND REQUIRE NO SHUTTERS.

THIS PRODUCT IS DESIGNED TO COMPLY WITH THE HIGH VELOCITY HURRICANE ZONE OF THE 2001 FLORIDA BUILDING CODE. ALSO FOR WIND LOADS AS PER ASCE 7 USING CORRESPONDING LOADS.

WOOD BUCKS BY OTHERS, MUST BE ANCHORED PROPERLY TO TRANSFER LOADS TO THE STRUCTURE.

ANCHORS SHALL BE AS LISTED, SPACED AS SHOWN ON DETAILS. ANCHOR EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.

ANCHORING OR LOADING CONDITIONS NOT SHOWN IN THESE DETAILS ARE NOT PART OF THIS APPROVAL.

Engr. DR. HUMAYOUN FAROOQ  
 STRUCTURES  
 F.L.A. PE # 16557

MAX 17 2002

Approved as complying with the  
 Florida Building Code  
 Date AUGUST 16 02  
 NOAH 02-0523-04  
 Miami Dade Product Control  
 Division  
 By: *[Signature]*




*afc*  
**AL-FAROOQ CORPORATION**  
 ENGINEERS, PLANNERS & PRODUCT DESIGN  
 1235 SW 87 AVE  
 MIAMI, FLORIDA 33174  
 TEL. (305) 264-8100 FAX. (305) 262-6978  
 COMP-ANL\W02-24(KW)

PVC FRAME DOUBLE HUNG WINDOWS  
**KENSINGTON WINDOWS INC.**  
 ONE KISKI VALLEY IND. PARK, RD #1  
 VANDERGRIFT, PA. 15690  
 TEL. (724) 845-8133 FAX (724) 845-2615

no.	date	by	description

date: 03-19-02  
 scale: 1/2"=1'-0"  
 dr. by: HAMID  
 chk. by:   
 drawing no. **W02-24**  
 sheet 1 of 4





ITEM #	PART #	REQD.	DESCRIPTION	MATERIAL	MANF./SUPPLIER/REMARKS
1	VS160	1	FRAME HEAD	PVC	DOMINION PLASTICS INC.
2	VS161	1	FRAME SILL	PVC	DOMINION PLASTICS INC.
3	VS330	2	FRAME JAMB	PVC	DOMINION PLASTICS INC.
4	VS294	1	VENT TOP RAIL	PVC	DOMINION PLASTICS INC.
5	VS142	1	VENT BOTTOM RAIL	PVC	DOMINION PLASTICS INC.
6	D412	1	VENT SASH CAP	PVC	DOMINION PLASTICS INC.
7	VS295	1	VENT OUT-BOARD MTG. RAIL	PVC	DOMINION PLASTICS INC.
8	D488	1	INTERLOCK	PVC	DOMINION PLASTICS INC.
9	VS144	1	VENT IN-BOARD MTG. RAIL	PVC	DOMINION PLASTICS INC.
10	VS607	2	VENT OUT-BOARD SIDE RAIL	PVC	DOMINION PLASTICS INC.
11	VS143	2	VENT IN-BOARD SIDE RAIL	PVC	DOMINION PLASTICS INC.
12	HGX 14694	1	MTG. RAIL REINFORCEMENT	6063-T6	FULL LENGTH
13	D429	AS REQD.	GLASS STOP	-	DOMINION PLASTICS INC.
13A	-	-	ALT. GLASS STOP	-	DOMINION PLASTICS INC.
14	VS554	AS REQD.	LIFT RAIL GLASS STOP	-	DOMINION PLASTICS INC.
15	-	-	-	-	-
16	100-290-250	AS REQD.	FIN SEAL PILE WEATHERSTRIP	-	HOPE ALLERGARD
17	-	-	-	-	-
18	-	AS REQD.	SETTING BLOCK	-	3/4" X 1" X 3/16"
19	-	AS REQD.	GLAZING COMPOUND	SILICONE	NOVAFLEX

Approved as complying with the  
Florida Building Code  
Date AUGUST 15, 02  
NOA# 02-0523.04  
Miami Dade Product Control  
Division  
By *[Signature]*

Engr: DR. HUMAYOON FAROOQ  
STRUCTURES  
FLA. FE # 16587

MAY 17 2002

*afc*

AL-FAROOQ CORPORATION  
ENGINEERS, PLANNERS & PRODUCT DESIGN  
1235 SW 87 AVE  
MIAMI, FLORIDA 33174  
TEL. (305) 264-8100 FAX. (305) 262-6978  
COMP-ANL\W02-24KWI


PVC FRAME DOUBLE HUNG WINDOWS  
KENSINGTON WINDOWS INC.  
ONE KISKI VALLEY IND. PARK, RD #1  
VANDERGRIFT, PA. 15690  
TEL. (724) 845-8133 FAX (724) 845-2615

revisions:	no	date	by	description


date: 03-19-02  
scale: 1/2" = 1"  
dr. by: HAMID  
chk. by:

drawing no.  
W02-24


sheet 3 of 4




FRAME HEAD




VENT TOP RAIL




VENT BOTTOM RAIL




SASH CAP




INTERLOCK




MTG. RAIL REINFORCEMENT




FRAME JAMB




VENT OUT-BOARD MEETING RAIL




VENT IN-BOARD MEETING RAIL




FRAME SILL



VENT OUT-BOARD SIDE RAIL




VENT IN-BOARD SIDE RAIL




GLASS STOP

LIFT RAIL GLASS STOP



VENT CORNERS



FRAME CORNERS

Approved as complying with the Florida Building Code  
 Date AUGUST 15, 02  
 NOA# 02-0523-04  
 Miami Dade Product Control Division  
 By *[Signature]*

Engr: DR. HUMAYOUN FAROOQ  
 STRUCTURES  
 FLA. PE # 16557  
 /MAY 17 2002

**AL-FAROOQ CORPORATION**  
 ENGINEERS, PLANNERS & PRODUCT DESIGN  
 1235 SW 87 AVE  
 MIAMI, FLORIDA 33174  
 TEL. (305) 264-8100 FAX. (305) 262-6978  
 COMP-ANL\W02-24KW

PVC FRAME DOUBLE HUNG WINDOWS  
**KENSINGTON WINDOWS INC.**  
 ONE KISKI VALLEY IND. PARK, RD #1  
 VANDERGRIFT, PA. 15690  
 TEL (724) 845-8133 FAX (724) 845-2615

no	date	description

date: 03-19-02  
 scale: 1/2" = 1"  
 dr. by: HAMID  
 chk. by:

drawing no.  
**W02-24**  
 sheet 4 of 4