



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

---

**Napco Inc.  
150 bonnie Drive  
Butler PA 16002**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Vinyl Siding & Soffit**

**APPROVAL DOCUMENT:** Drawing No. 1150008, 09, 10, 11 & 12, titled "Vinyl Siding Soffit", sheets 1 through 5, prepared, by Napco Inc, dated 08/2002, with no revisions, signed and sealed R. Boyette, PE, bearing the Miami-Dade County Product Control Approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division.

**MISSILE IMPACT RATING: Large and Small Missile Impact**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of this page 1 as well as approval document mentioned above.

The submitted documentation was reviewed by **Candido Font, PE.**



**NOA No 02-0610.03  
Expiration Date: October 31, 2007  
Approval Date: November 7, 2002  
Page 1**

**Napco, Inc.**

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

(For File ONLY. Not part of NOA)

**A. DRAWINGS**

1. Drawing prepared by Napco, Inc, titled "Vinyl Siding Soffit", drawing No.1150008, 09, 10, 11,& 12, dated 08/2002, with no revisions, signed and sealed by R. Boyette, PE.

**B. TESTS**

Laboratory Report	Test	Date	Signature
1. ATI-17925	PA 202 & 203	09/12/96	A.N. Reeves, PE
2. ATI 17929	PA 202 & 203	09/12/96	A.N. Reeves, PE
3. ATI 17926	PA 202 & 203	09/12/96	A.N. Reeves, PE
4. ATI 17931	PA 202 & 203	09/12/96	A.N. Reeves, PE
5. ATI 17930	PA 202 & 203	09/12/96	A.N. Reeves, PE
6. ATI 17927	PA 202 & 203	09/12/96	A.N. Reeves, PE
7. RADCO-C4009	ASTM D3679	May/99	R. F. Tucker, PE

**C. CALCULATIONS**

N/A

**D. MATERIAL CERTIFICATIONS**

N/A




**F. OTHER**

1. Code Compliance letter issued by R. Boyette, dated 10/23/98, signed and sealed by R. Boyette, PE.
2. Authorization and Acknowledgment issued by Variform, Inc. and Napco, Inc. on 9/23/02 and signed by J. Wayne president of both companies.



**Candido F. Font, PE**  
**Product Control Division**  
**NOA No 02-0610. 03**

**Expiration Date: October 31, 2007**  
**Approval Date: November 7, 2002**



NAME	DWG#	EXPOSURE INCHES	THICKNESS -0.001 INCHES	DESIGN PRESSURE P.S.F.	NAME	DWG#	EXPOSURE INCHES	THICKNESS -0.001 INCHES	DESIGN PRESSURE P.S.F.
AMERICAN TRADITION	01	DOUBLE 4	.042	46.6	AMERICAN TRADITION	03	DOUBLE 5	.042	40.0
AMERICAN SPLENDOR	42	DOUBLE 4	.046	46.6	AMERICAN SPLENDOR	44	DOUBLE 5	.046	40.0
AMERICAN HERALD	50	DOUBLE 4	.044	46.6	AMERICAN HERALD	52	DOUBLE 5	.044	40.0
SUNNY BROOK	56	DOUBLE 4	.044	46.6	SUNNY BROOK	58	DOUBLE 5	.044	40.0
OLDE PROVIDENCE	60	DOUBLE 4	.040	46.6	OLDE PROVIDENCE	62	DOUBLE 5	.040	40.0
AMERICAN COMFORT	63	DOUBLE 4	.040	46.6	AMERICAN COMFORT	64	DOUBLE 5	.040	40.0
AMERICAN 76 COLLECTION	67	DOUBLE 4	.044	46.6					


NOTE 1.- NAPCO INC. VINYL SIDING/SOFFIT IS MANUFACTURED FROM A FORMULATED P.V.C. POWDER COMPOUND MEETING THE SPECIFICATIONS OF ASTM D3679  
 2.- WALLS AND SOFFIT RECEIVING VINYL SIDING/SOFFIT SHALL BE CHECKED FOR STRUCTURAL ADEQUACY CRACKS OR DEFECTS THAT SHALL BE ELIMINATED  
 3.- WALLS SHALL BE WATER PROOFED WITH EQUIVALENT OF 15 POUND FELT AS DESCRIBED IN SECTION 2704.6 (b) OF THE SFBC

4.- WALLS AND SOFFIT WHERE VINYL SIDING/SOFFIT WILL BE INSTALLED SHALL BE DESIGNED BY AN ENGINEER OR ARCHITECT PER THE SFBC AND THE REQUIREMENTS OF THESE NOA  
 5.- INSTALLATION OF SIDING/SOFFIT ACCESORIES SUCH AS CORNER POSTS, STARTER STRIPS, TRIMS AROUND OPENINGS SHALL BE DONE IN ACCORDANCE WITH THE MANUFACTURES INSTRUCTIONS AND THE SFBC

Approved as comply tag with the  
 Florida Building Code  
 Code 02-0610.03  
 DATE 11/07/02  
 Richard Boyette, PE  
 Professional Engineer/Control


**RICHARD BOYETTE**  
 FL Civil PE #42485  
 4031 Coconut Blvd  
 Royal Palm Bch FL 33411  
 (561) 790-5766 Voice / Fax  
*Richard Boyette*  
 10/26/02 02-1014

NAPCO INC. 150 BONNIE DRIVE BUTLER, PA 16002		COMPANY NAME <b>NAPCO INC.</b>	
UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN INCHES		DRAWN LRB	DATE 8/02
TOLERANCES DECIMALS .010 FRACTIONS 1/32 ANGULAR ± 1° DO NOT SCALE DRAWING		TITLE VINYL SIDING SOFFIT	
DESIGN ACTIVITY		SIZE B	DWG NO. 1150008
		SHEET	



D/4  
DUTCH LAP


APPROVED MODELS



D/5  
DUTCH LAP

APPROVED MODELS

TYPICAL INSTALLATION  
VINYL SIDING/SOFFIT



NAME	DWG#	EXPOSURE INCHES	THICKNESS -0.001 INCHES	DESIGN PRESSURE P.S.F.	NAME	DWG#	EXPOSURE INCHES	THICKNESS -0.001 INCHES	DESIGN PRESSURE P.S.F.
SUNNY BROOK	04	DOUBLE 4	.044	46.6	SUNNY BROOK	05	DOUBLE 5	.044	40.0
AMERICAN HERALD	53	DOUBLE 4	.044	46.6	AMERICAN HERALD	54	DOUBLE 5	.044	40.0

NOTE 1.- NAPCO INC. VINYL SIDING/SOFFIT IS MANUFACTURED FROM A FORMULATED P.V.C. POWDER COMPOUND MEETING THE SPECIFICATIONS OF ASTM D3679  
 2.- WALLS AND SOFFIT RECEIVING VINYL SIDING/SOFFIT SHALL BE CHECKED FOR STRUCTURAL ADEQUACY CRACKS OR DEFECTS THAT SHALL BE ELIMINATED  
 3.- WALLS SHALL BE WATER PROOFED WITH EQUIVALENT OF 15 POUND FELT AS DESCRIBED IN SECTION 2704.6 (b) OF THE SFBC


4.- WALLS AND SOFFIT WHERE VINYL SIDING/SOFFIT WILL BE INSTALLED SHALL BE DESIGNED BY AN ENGINEER OR ARCHITECT PER THE SFBC AND THE REQUIREMENTS OF THESE NOA  
 5.- INSTALLATION OF SIDING/SOFFIT ACCESSORIES SUCH AS CORNER POSTS, STARTER STRIPS, TRIMS AROUND OPENINGS SHALL BE DONE IN ACCORDANCE WITH THE MANUFACTURES INSTRUCTIONS AND THE SFBC

Approved as complying with the  
 Florida Building Code  
 Date 02-0610.03  
 NOA# 11/07/02  
 Miami Dade Building Control  
 Division  
 By

**RICHARD BOYETTE**  
 FL Civil PE #42485  
 4031 Coconut Blvd  
 Royal Palm Bch FL 33411  
 561-700-5766 Voice / Fax


10/19/02

NAPCO INC. 150 BONNIE DRIVE BUTLER, PA. 16002		COMPANY NAME <b>NAPCO INC.</b>	
UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN INCHES TOLERANCES: DECIMALS ± 0.10 ANGULAR ± 1° XXX ± .005 DO NOT SCALE DRAWING		DRAWN LRB	DATE 8/02
DESIGN ACTIVITY		SIZE B	DWG NO. 1150009
		SHEET	



6 1/2"  
HORIZONTAL


APPROVED MODELS



T/3  
HORIZONTAL

APPROVED MODELS

TYPICAL INSTALLATION  
VINYL SIDING/SOFFIT



NAME	DWG#	EXPOSURE INCHES	THICKNESS -0.001 INCHES	DESIGN PRESSURE P.S.F.	NAME	DWG#	EXPOSURE INCHES	THICKNESS -0.001 INCHES	DESIGN PRESSURE P.S.F.
AMERICAN 76 COLLECTION	68	SINGLE 6 1/2	.044	60.0	OLDE PROVIDENCE	40	TRIPLE 3	.040	40.0
					AMERICAN COMFORT	41	TRIPLE 3	.040	40.0
					AMERICAN 76 SMOOTH	66	TRIPLE 3	.044	40.0


NOTE 1.- NAPCO INC. VINYL SIDING/SOFFIT IS MANUFACTURED FROM A FORMULATED P.V.C. POWDER COMPOUND MEETING THE SPECIFICATIONS OF ASTM D3679  
 2.- WALLS AND SOFFIT RECEIVING VINYL SIDING/SOFFIT SHALL BE CHECKED FOR STRUCTURAL ADEQUACY CRACKS OR DEFECTS THAT SHALL BE ELIMINATED  
 3.- WALLS SHALL BE WATER PROOFED WITH EQUIVALENT OF 15 POUND FELT AS DESCRIBED IN SECTION 2704.6 (b) OF THE SFBC

4.- WALLS AND SOFFIT WHERE VINYL SIDING/SOFFIT WILL BE INSTALLED SHALL BE DESIGNED BY AN ENGINEER OR ARCHITECT PER THE SFBC AND THE REQUIREMENTS OF THESE NOA  
 5.- INSTALLATION OF SIDING/SOFFIT ACCESORIES SUCH AS CORNER POSTS, STARTER STRIPS, TRIMS AROUND OPENINGS SHALL BE DONE IN ACCORDANCE WITH THE MANUFACTURES INSTRUCTIONS AND THE SFBC

Approved as complying with the  
 Florida Building Code  
 Date: 02-0610.03  
 No. 11/07/02  
 Richard Boyette Control  
 Extension  
 By:


**RICHARD BOYETTE**  
 FL Civil PE #42485  
 4031 Coconut Blvd  
 Palm Beach FL 33411  
 5766 Voice / Fax

NAPCO INC. 150 BONNIE DRIVE BUTLER, PA. 16002		DRAWN LRB DATE 8/02		COMPANY NAME <b>NAPCO INC.</b>	
UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN INCHES TOLERANCES DECIMALS ± .010 ANGULAR ± 1° XXX ± .005 DO NOT SCALE DRAWING		TITLE <b>VINYL SIDING SOFFIT</b>		SIZE <b>B</b>	
DESIGN ACTIVITY		DWG NO. <b>1150010</b>		SHEET	



D/5  
VERTICAL/SOFFIT


APPROVED MODELS



.D/5  
LANCED  
SOFFIT

APPROVED MODELS

TYPICAL INSTALLATION  
VINYL SIDING/SOFFIT



NAME	DWG#	EXPOSURE INCHES	THICKNESS -0.001 INCHES	DESIGN PRESSURE P.S.F.
SVS	70	DOUBLE 5	.044	40.0
AMERICAN SPLENDOR	1120400	DOUBLE 5	.046	40.0

NAME	DWG#	EXPOSURE INCHES	THICKNESS -0.001 INCHES	DESIGN PRESSURE P.S.F.
LVS	71	DOUBLE 5	.044	40.0

NOTE 1.- NAPCO INC. VINYL SIDING/SOFFIT IS MANUFACTURED FROM A FORMULATED P.V.C. POWDER COMPOUND MEETING THE SPECIFICATIONS OF ASTM D3679  
 2.- WALLS AND SOFFIT RECEIVING VINYL SIDING/SOFFIT SHALL BE CHECKED FOR STRUCTURAL ADEQUACY CRACKS OR DEFECTS THAT SHALL BE ELIMINATED  
 3.- WALLS SHALL BE WATER PROOFED WITH EQUIVALENT OF 15 POUND FELT AS DESCRIBED IN SECTION 2704.6 (b) OF THE SFBC


4.- WALLS AND SOFFIT WHERE VINYL SIDING/SOFFIT WILL BE INSTALLED SHALL BE DESIGNED BY AN ENGINEER OR ARCHITECT PER THE SFBC AND THE REQUIREMENTS OF THESE NOA  
 5.- INSTALLATION OF SIDING/SOFFIT ACCESORIES SUCH AS CORNER POSTS, STARTER STRIPS, TRIMS AROUND OPENINGS SHALL BE DONE IN ACCORDANCE WITH THE MANUFACTURES INSTRUCTIONS AND THE SFBC

Approved in accordance with the Florida Building Code  
 Date: 02-06-03  
 11/07/02  
 Division  
 By: *[Signature]*

**RICHARD BOYETTE**  
 FL Civil PE #42485  
 4031 Coconut Blvd  
 Royal Palm Beach FL 33411  
 561-5766 Voice / Fax

*[Signature]*  
 12/9/02

NAPCO INC. 150 BONNIE DRIVE BUTLER, PA. 16002		COMPANY NAME <b>NAPCO INC.</b>	
UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN INCHES TOLERANCES: DECIMALS ± .010 ANGULAR ± 1° DO NOT SCALE DRAWING		DRAWN LRB	DATE 8/02
		TITLE VINYL SIDING SOFFIT	
DESIGN ACTIVITY		SIZE B	DWG NO. 1150011
		SHEET	




D/4.5  
DUTCH LAP

APPROVED MODELS

NAME	DWG#	EXPOSURE INCHES	THICKNESS -0.001 INCHES	DESIGN PRESSURE P.S.F.
AMERICAN TRADITION	02	DOUBLE 4.5	.042	40.0
AMERICAN SPLENDOR	43	DOUBLE 4.5	.046	40.0
OLDE PROVIDENCE	61	DOUBLE 4.5	.040	40.0
AMERICAN COMFORT	65	DOUBLE 4.5	.040	40.0

TYPICAL INSTALLATION  
VINYL SIDING/SOFFIT



NOTE 1.- NAPCO INC. VINYL SIDING/SOFFIT IS MANUFACTURED FROM A FORMULATED P.V.C. POWDER COMPOUND MEETING THE SPECIFICATIONS OF ASTM D3679  
 2.- WALLS AND SOFFIT RECEIVING VINYL SIDING/SOFFIT SHALL BE CHECKED FOR STRUCTURAL ADEQUACY CRACKS OR DEFECTS THAT SHALL BE ELIMINATED  
 3.- WALLS SHALL BE WATER PROOFED WITH EQUIVALENT OF 15 POUND FELT AS DESCRIBED IN SECTION 2704.6 (b) OF THE SFBC

4.- WALLS AND SOFFIT WHERE VINYL SIDING/SOFFIT WILL BE INSTALLED SHALL BE DESIGNED BY AN ENGINEER OR ARCHITECT PER THE SFBC AND THE REQUIREMENTS OF THESE NOA  
 5.- INSTALLATION OF SIDING/SOFFIT ACCESORIES SUCH AS CORNER POSTS, STARTER STRIPS, TRIMS AROUND OPENINGS SHALL BE DONE IN ACCORDANCE WITH THE MANUFACTURES INSTRUCTIONS AND THE SFBC

Approved working with the  
 Florida Building Code  
 Date 02-0610.03  
 BY 11/07/02  
 Richard Boyette, PE  
 Division Control  
 By [Signature]

**RICHARD BOYETTE**  
 FL Civil PE #42485  
 4031 Coconut Blvd  
 Royal Palm Bch FL 33411  
 700-5766 Voice / Fax

NAPCO INC. 150 BONNIE DRIVE BUTLER, PA. 16002		DATE <u>8/02</u>		COMPANY NAME <b>NAPCO INC.</b>	
UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN INCHES		DRAWN <u>LRB</u>		TITLE VINYL SIDING SOFFIT	
TOLERANCES DECIMALS ± .010 ANGULAR ± 1° XXX ± .005 DO NOT SCALE DRAWING		DATE		SIZE <b>B</b>	
DESIGN ACTIVITY		DWG NO. 1150012		SHEET	