



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Lawson Industries, Inc.
8501 NW 90th Street
Medley, FL 33166**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Series "PW 6200" Aluminum Fixed Window

APPROVAL DOCUMENT: Drawing No. W02-55, titled "PW-6200 Aluminum Fixed Window", sheets 1 through 5, prepared by Al Farooq Corporation, dated 6/6/02, signed and sealed by Humayoun Farooq, P.E., bearing the Miami-Dade County Product Control Approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: Large and Small Missile Impact

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.


INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of this page 1 as well as approval document mentioned above.


The submitted documentation was reviewed by **Theodore Berman, P.E.**




**NOA No 02-0701.01
Expiration Date: August 22, 2007
Approval Date: August 22, 2002
Page 1**




TYPICAL ELEVATION
TESTED UNIT




GLASS TYPE 'A'




GLASS TYPE 'B'




GLASS TYPE 'C'



GLASS TYPE 'D'







GLASS TYPE 'E1'



GLASS TYPE 'E2'

GLAZING OPTIONS

LARGE MISSILE IMPACT RESISTANT GLASS, SHUTTERS ARE NOT REQUIRED
SEE SHEETS 2 & 3 FOR CAPACITIES



NOTES:

1. THIS PRODUCT IS DESIGNED TO COMPLY WITH THE HIGH VELOCITY HURRICANE ZONE OF THE 2001 FLORIDA BUILDING CODE. ALSO FOR WIND LOADS AS PER ASCE 7 USING CORRESPONDING LOADS.
2. WOOD BUCKS BY OTHERS, MUST BE ANCHORED PROPERLY TO TRANSFER LOADS TO THE STRUCTURE.
3. ANCHORS SHALL BE AS LISTED, SPACED AS SHOWN ON DETAILS. ANCHOR EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.

Approved as complying with the Florida Building Code

Date: 08/22/02

NOA# 02-0701.01

Miami Dade Product Control

Division
By: *Cherisse Roman*

AL-FAROOQ CORPORATION
ENGINEERS, PLANNERS & PRODUCT DESIGN
1235 SW 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978


PW-6200 ALUMINUM FIXED WINDOW (IMPACT)
LAWSON INDUSTRIES
8501 N.W. 90TH STREET
MEDLEY, FL. 33160
TEL. (305) 696-8660 FAX (305) 696-8006

no.	date	description


date: 06-06-02
scale: 1/2" = 1"
dr. by: HAMID
chk. by:

Engr: DR. HUMAYOUN FAROOQ
STRUCTURES
FLA. PE # 16557
JUN 24 2002


drawing no.
W02-55
sheet 1 of 5




TYPICAL ELEVATION
TESTED UNIT




GLAZING STOP (3/8" GLASS)



GLAZING STOP (7/16" GLASS)



FRAME HEAD/SILL



FRAME JAMB

NOTES:

1. THIS PRODUCT IS DESIGNED TO COMPLY WITH THE HIGH VELOCITY HURRICANE ZONE OF THE 2001 FLORIDA BUILDING CODE. ALSO FOR WIND LOADS AS PER ASCE 7 USING CORRESPONDING LOADS.
2. WOOD BUCKS BY OTHERS, MUST BE ANCHORED PROPERLY TO TRANSFER LOADS TO THE STRUCTURE.
3. ANCHORS SHALL BE AS LISTED, SPACED AS SHOWN ON DETAILS. ANCHOR EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.

Approved as complying with the Florida Building Code


Date 08/22/02

NOA# 02-0701.01

Miami Dade Product Control

Division

By *Cherisse Berman*



GLAZING OPTIONS

LARGE MISSILE IMPACT RESISTANT GLASS, SHUTTERS ARE NOT REQUIRED
SEE SHEETS 2 & 3 FOR CAPACITIES

Engr: DR. HUMAYOON FAROOQ
STRUCTURES
FLA. PE # 16557

JAN 24 2002



AL-FAROOQ CORPORATION
ENGINEERS, PLANNERS & PRODUCT DESIGN
1235 SW 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978


PW-6200 ALUMINUM FIXED WINDOW (IMPACT)
LAWSON INDUSTRIES
8501 N.W. 90TH STREET
MEDLEY, FL. 33160
TEL (305) 696-8660 FAX (305) 696-6006

no.	date	by	description

date: 06-06-02
scale: 1/2" = 1"
dr. by: HAMID
chk. by:

drawing no.
W02-55
sheet 1 of 5

DESIGN LOAD CAPACITY - PSF															
WINDOW DIMS.		3/16" ANCHORS								1/4" ANCHORS					
		GLASS TYPE 'A'		GLASS TYPE 'B'		GLASS TYPE 'C'		GLASS TYPE 'D'		GLASS TYPE 'E1'&'E2'		GLASS TYPE 'D'		GLASS TYPE 'E1'&'E2'	
WIDTH	LENGTH	EXT. (+)	INT. (-)	EXT. (+)	INT. (-)	EXT. (+)	INT. (-)	EXT. (+)	INT. (-)						
19-1/8"	26"	65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
26-1/2"		65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
37"		65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
48"		65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
53-1/8"		65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
19-1/8"	38-3/8"	65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
26-1/2"		65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
37"		61.9	61.9	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
48"		58.7	58.7	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
53-1/8"		X	X	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
19-1/8"	50-5/8"	65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
26-1/2"		65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
37"		48.1	48.1	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
48"		X	X	56.6	56.6	68.0	65.9	65.0	65.0	78.0	65.9	65.0	65.0	78.0	78.0
53-1/8"		X	X	X	X	64.4	64.4	65.0	65.0	78.0	74.4	65.0	65.0	78.0	78.0
19-1/8"	58"	65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
26-1/2"		61.3	61.3	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
37"		X	X	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
48"		X	X	X	X	X	X	65.0	65.0	78.0	71.9	65.0	65.0	78.0	78.0
53-1/8"		X	X	X	X	X	X	65.0	65.0	78.0	65.0	65.0	65.0	65.0	78.0
19-1/8"	63"	65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
26-1/2"		60.3	60.3	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
37"		X	X	67.7	67.7	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
48"		X	X	X	X	X	X	65.0	65.0	78.0	66.2	65.0	65.0	78.0	78.0
53-1/8"		X	X	X	X	X	X	65.0	59.8	78.0	59.8	65.0	65.0	78.0	78.0
19-1/8"	74"	65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
26-1/2"		X	X	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
37"		X	X	X	X	62.8	62.8	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
48"		X	X	X	X	X	X	65.0	65.0	78.0	67.6	65.0	65.0	78.0	78.0
53-1/8"		X	X	X	X	X	X	65.0	61.1	78.0	61.1	65.0	65.0	78.0	78.0
19-1/8"	74-1/4"	65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
26-1/2"		X	X	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
37"		X	X	X	X	X	X	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
48"		X	X	X	X	X	X	65.0	65.0	78.0	67.4	65.0	65.0	78.0	78.0
53-1/8"		X	X	X	X	X	X	65.0	60.9	78.0	60.9	65.0	65.0	78.0	78.0



NOTE:
WIDTH AND LENGTH DIMENSIONS CAN BE ORIENTED
VERTICALLY OR HORIZONTALLY AS SHOWN ABOVE.

afc

AL-FAROQ CORPORATION
ENGINEERS, PLANNERS & PRODUCT DESIGN
1235 SW 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6378
COMP-ANL\W02-55LI

PW-6200 ALUMINUM FIXED WINDOW (IMPACT)
LAWSON INDUSTRIES
8501 N.W. 90TH STREET
MEDLEY, FL. 33160
TEL. (305) 696-8660 FAX (305) 696-6006

Approved as complying with the
Florida Building Code
Date 08/22/02
NOA# 02-0701-01
Miami Dade Product Control
Division
By: *Aladdin Kawan*

Engr: DR. HUMAYOUN FAROOQ
STRUCTURES
FLA. PE # 16557

JUN 24 2002

revisions:	no	date	by	description


date: 06-06-02
scale: 1/2" = 1"
dr. by: HAMID
chk. by:

drawing no.
W02-55

sheet 2 of 5

DESIGN LOAD CAPACITY - PSF

WINDOW DIMS.		3/16" ANCHORS										1/4" ANCHORS			
		GLASS TYPE 'A'		GLASS TYPE 'B'		GLASS TYPE 'C'		GLASS TYPE 'D'		GLASS TYPE 'E1' & 'E2'		GLASS TYPE 'D'		GLASS TYPE 'E1' & 'E2'	
WIDTH	LENGTH	EXT. (+)	INT. (-)	EXT. (+)	INT. (-)	EXT. (+)	INT. (-)	EXT. (+)	INT. (-)						
24"	36"	65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
30"		65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
36"		65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
42"		57.9	57.9	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
48"		51.4	51.4	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
54"		X	X	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
60"	X	X	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0	
24"	48"	65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
30"		61.8	61.8	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
36"		51.4	51.4	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
42"		X	X	64.7	64.7	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
48"		X	X	56.6	56.6	68.0	68.0	65.0	65.0	78.0	69.5	65.0	65.0	78.0	78.0
54"		X	X	56.6	56.6	68.0	68.0	65.0	65.0	78.0	77.2	65.0	65.0	78.0	78.0
60"	X	X	X	X	X	X	65.0	65.0	78.0	69.5	65.0	65.0	78.0	78.0	
24"	60"	65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
30"		49.9	49.9	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
36"		X	X	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
42"		X	X	64.7	64.7	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
48"		X	X	X	X	X	X	65.0	65.0	78.0	69.5	65.0	65.0	78.0	78.0
54"		X	X	X	X	X	X	65.0	61.8	78.0	61.8	65.0	65.0	78.0	78.0
60"	X	X	X	X	X	X	65.0	55.6	78.0	55.6	65.0	65.0	78.0	78.0	
24"	72"	65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
30"		X	X	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
36"		X	X	65.5	65.5	66.9	66.9	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
42"		X	X	X	X	X	X	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
48"		X	X	X	X	X	X	65.0	65.0	78.0	69.5	65.0	65.0	78.0	78.0
54"		X	X	X	X	X	X	65.0	61.8	78.0	61.8	65.0	65.0	78.0	78.0
60"	X	X	X	X	X	X	65.0	55.6	78.0	55.6	65.0	65.0	78.0	78.0	
24"	74"	65.0	65.0	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
30"		X	X	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
36"		X	X	64.9	64.9	65.1	65.1	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
42"		X	X	X	X	X	X	65.0	65.0	78.0	77.3	65.0	65.0	78.0	78.0
48"		X	X	X	X	X	X	65.0	65.0	78.0	67.6	65.0	65.0	78.0	78.0
54"		X	X	X	X	X	X	65.0	60.1	78.0	60.1	65.0	65.0	78.0	78.0
60"	X	X	X	X	X	X	65.0	54.1	78.0	54.1	65.0	65.0	78.0	78.0	
24"	84"	X	X	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
30"		X	X	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
36"		X	X	X	X	X	X	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
42"		X	X	X	X	X	X	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
48"		X	X	X	X	X	X	65.0	65.0	78.0	69.5	65.0	65.0	78.0	78.0
24"	96"	X	X	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
30"		X	X	X	X	X	X	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
36"		X	X	X	X	X	X	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
42"		X	X	X	X	X	X	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
24"	108"	X	X	68.0	68.0	75.0	75.0	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
30"		X	X	X	X	X	X	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
36"		X	X	X	X	X	X	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
24"	120"	X	X	X	X	X	X	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
30"		X	X	X	X	X	X	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0
36"		X	X	X	X	X	X	65.0	65.0	78.0	78.0	65.0	65.0	78.0	78.0



NOTE:
WIDTH AND LENGTH DIMENSIONS CAN BE ORIENTED VERTICALLY OR HORIZONTALLY AS SHOWN ABOVE.

Approved as complying with the Florida Building Code
Date 06/22/02
NOA# 02-0701.01
Miami Dade Product Control
By *Alfredo Berman*

Engr: DR. HUMAYOUN FAROOQ
STRUCTURES
FLA. PE # 16557
JUN 24 2002

afc

AL-FAROOQ CORPORATION
ENGINEERS, PLANNERS & PRODUCT DESIGN
1235 SW 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978
COMP-ANL\W02-55LI


PW-6200 ALUMINUM FIXED WINDOW (IMPACT)

LAWSON INDUSTRIES
8501 N.W. 90TH STREET
MEDLEY, FL. 33160
TEL. (305) 686-8660 FAX (305) 686-6006




revisions:	no	date	by	description

date: 06-06-02
scale: 1/2" = 1"
dr. by: HAMID
chk. by:

drawing no.
W02-55
sheet 3 of 5



METAL STRUCTURES
(STEEL OR ALUM. 1/8" MIN. THICK)
STEEL : $F_y = 36$ KSI MIN.
ALUMINUM : 6063-T5 MIN.



WOOD BUCKS NOT BY LAWSON, MUST SUSTAIN LOADS IMPOSED BY GLAZING SYSTEM AND TRANSFER THEM TO THE BUILDING STRUCTURE.

TYPICAL ANCHORS: SEE ELEV. FOR SPACING

3/16" TAPCONS

INTO 2BY WOOD BUCKS OR WOOD STRUCTURE
1-3/8" MIN. PENETRATION INTO WOOD
THRU 1BY WOOD BUCKS INTO MASONRY OR DIRECTLY INTO MASONRY
1-1/4" MIN. EMBED INTO MASONRY OR CONC.

3/16" DRILLFLEX OR EQUIV. SELF DRILLING SCREWS

INTO METAL STRUCTURES (1/8" MIN. THICKNESS)

1/4" TAPCONS

INTO 2BY WOOD BUCKS OR WOOD STRUCTURE
1-1/2" MIN. PENETRATION INTO WOOD
THRU 1BY WOOD BUCKS INTO MASONRY OR DIRECTLY INTO MASONRY
1-1/4" MIN. EMBED INTO MASONRY OR CONC.

1/4" DRILLFLEX OR EQUIV. SELF DRILLING SCREWS

INTO METAL STRUCTURES (1/8" MIN. THICKNESS)

#10 X 3/4" SMS

INTO APPROVED MULLIONS (NO SHIM SPACE)

SEALANTS:

FRAME AND VENT CORNERS AND INSTALLATION SCREWS AT SILL SEALED WITH WHITE/ALUMINUM COLORED SEALANT.

Approved as complying with the
Florida Building Code
Date 08/22/02
NOA# 02-0701.01
Miami Dade Product Control
Division
By *Edward Egan*

Engr: DR. HUMAYOON FAROOQ
STRUCTURES
FLA. PE # 16557

JUN 24 2002

afc

AL-FAROOQ CORPORATION
ENGINEERS, PLANNERS & PRODUCT DESIGN
1235 SW 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978
COMP-ANL\W02-55LI

PW-6200 ALUMINUM FIXED WINDOW (IMPACT)

LAWSON INDUSTRIES
8501 N.W. 90TH STREET
MEDLEY, FL. 33160
TEL. (305) 696-8660 FAX (305) 696-6006



revisions:	no	date	by	description

date: 06-06-02	scale: 1/2" = 1"	dr. by: HAMID	chk. by:
----------------	------------------	---------------	----------


drawing no. **W02-55**

sheet 4 of 5

ITEM	PART #	QUANTITY	DESCRIPTION	MATERIAL	MANF./SUPPLIER/REMARKS
1	L-4201	2	FRAME HEAD/SILL	6063-T5	-
2	L-4201	2	FRAME JAMB	6063-T5	-
3	L-7708	4	GLAZING BEAD (3/8" GLASS)	6063-T5	-
4	L-7708 TRIMMED	4	GLAZING BEAD (7/16" GLASS)	6063-T5	-
5	#8 X 3/4"	2/ CORNER	ASSEMBLY SCREWS	-	P.H. PHILLIPS
6	-	-	-	-	-
7	VWS-004	AS REQD.	GLAZING GASKET	SOFT PVC	-



TYPICAL CORNER CONSTRUCTION



Approved as complying with the
 Florida Building Code
 Date 08/22/02
 NOAH# 02-0701-01
 Miami Dade Product Control
 Division
 By: *Alfredo Belman*

Engr: DR. HUMAYOUN FAROOQ
 STRUCTURES
 FLA. PE # 16557
 JUN 24 2002

afsc
AL-FAROOQ CORPORATION
 ENGINEERS, PLANNERS & PRODUCT DESIGN
 1235 SW 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANI\W02-55LI

PW-6200 ALUMINUM FIXED WINDOW (IMPACT)
LAWSON INDUSTRIES
 8501 N.W. 90TH STREET
 MEDLEY, FL. 33160
 TEL (305) 696-8660 FAX (305) 696-6006

revisions:	no	date	by	description

date: 06-06-02
 scale: 1/2" = 1"
 dr. by: HAMID
 chk. by:

drawing no.
W02-55
 sheet 5 of 5