



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

---

**Golden Pharos USA, Inc.  
700 Atlantis Road Bldg.101  
Melbourne, FL 32904**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Series "F-1518" Outswing Wood French Door Slab w/18 lite Muntins-FBMA Component**

**APPROVAL DOCUMENT:** Drawing titled "Project FLBMDA #95-0001" series F1518 18-Lite French Door", sheets D1 through D7 of 7, prepared by the manufacturer dated 7/14/98 and last revised on 08-13-02, bearing the Miami-Dade County Product Control Renewal stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Division.

**MISSILE IMPACT RATING: None**

**LABELING:** Each unit shall bear a permanent label, issued by FBMA (FLBMDA) with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.


**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA # 98-1229.02 and, consists of this page 1 as well as approval document mentioned above. The submitted documentation was reviewed by Ishaq I. Chanda, P.E.






**NOA No 02-0805.01  
Expiration Date: August 19, 2007  
Approval Date: August 19, 2002  
Page 1**



F-1518  
 18-Light Single Glazed French  
 36" x 134"


**PRODUCT RENEWED**  
 as complying with the Florida  
 Building Code  
 Acceptance No. 02-0805-01  
 Expiration Date AUG 19, 2007  
 By Ishqat Chande  
 Miami Dade Product Control  
 Division



5/32" (1 min Tempered Safety Glass)

Section Drawings  
 Not to Scale

5/8" x 5"  
 Hardwood Dowels  
 (Typical)



**Wood Species**

- Vertical Grain Douglas Fir (Pseudotsuga Taxfolia)
- American Red Oak (Quercus Rubis)
- Nyatoh (Sapotaceae)
- Meranti Bakau (Shorea Ulliginosa)

**General Notes:**

1. This component is approved as equal alternate to the Series 1518 Out-swing 18-Lite French Door, per NWWDA I.S. 6-91, to be used, interchangeably only, in out-swing door systems with approvals under the auspices of FLBMDA's (FBMA) system: 95-0001(b).
2. Single door units shall include all components described in the active leaf of system approval.
3. Installation of this product will require HVZ approved hurricane protection system.

- REVISION: 3/30/99 ADDED DESIGN PRESSURE;  
 REDUCED TO 8-1/2" X 11" FORMAT  
 REVISION: 4/15/99 DESIGN PRESSURE CORRECTED  
 TO +48.3 -59.9 PSF  
 REVISION: 8/13/02 ADD NOTES

Prepared: 14 July 1998

Golden Pharos USA, Inc.  
700 Atlantis Road, Unit 101, Bldg. A. • Melbourne, Fla. 32904  
Phone (407)676-1615 • Fax (407)676-6551

Design Pressure: +48.3psf -59.9psf

**BILL OF MATERIALS**

**PRODUCT TYPE AND SERIES**

Golden Pharos USA, Inc.

F-1518 Eighteen Lite Exterior French Door  
Vertical Grain Douglas Fir  
Veneer Construction

M-1518 Meranti Veneer Construction

N-1518 Nyatoh Veneer Construction

R-1518 Red Oak Veneer Construction

P-1518 Okoume Veneer Construction

**CONFIGURATION:**

Single Slab Door

Dimensions: 1 3/4" X 36" X 96"

**CORNER CONSTRUCTION:**

Top Rail: 1 3/4" X 6 1/2" X 27 5/8"  
Two (2) 5/8" X 5" Dowels at each end.  
2 7/8" Penetration into the rail.

Bottom Rail: 1 3/4" X 9 11/16" X 27 5/8"  
Four (4) 5/8" X 5" Dowels at each end.  
2 7/8" Penetration into the rail.

Stiles: 1 3/4" X 4 1/2" X 96"

Muntin Bars: Five (5) 1 3/4" X 1 1/4" X 27 5/8"  
Twelve (12) - 1 3/4" X 1 1/4" X 13"

Glass Sizes: Eighteen (18) 5/32" (4mm) X 8 3/4" (222mm) X 12 7/8" (327mm)

PRODUCT RENEWED  
as complying with the Florida  
Building Code  
Acceptance No. 02-0805.01  
Expiration Date Aug 19, 2007  
By Ishag I. Chanda  
Miami Dade Product Control  
Division

APPROVED AS COMPLYING WITH THE  
SOUTH FLORIDA BUILDING CODE  
DATE September 09, 19 99  
BY Ishag I. Chanda  
PRODUCT CONTROL DIVISION  
BUILDING CODE COMPLIANCE OFFICE  
ACCEPTANCE NO. 98-1229-02

Revision: 3/20/99: Added design pressure; Reduced to 8 1/2" x 11" format  
Revision: 4/18/99: Design pressure corrected to +48.3-59.9

Prepared: 14 July 1998


Project

FLBMDA #95-0001

F1518 18-Lite French Door

(7 Pages: D1-D7)

Page No:  
**D2**




**Dowel Penetration  
 (Typical Detail)**

PRODUCT RENEWED  
 as complying with the Florida  
 Building Code  
 Acceptance No. 02-0805.01  
 Expiration Date AUG 19, 2007

By Ishag I. Chanda  
 Miami Dade Product Control  
 Division

**Veneer Construction  
 (Typical)**


APPROVED AS COMPLYING WITH THE  
 SOUTH FLORIDA BUILDING CODE  
 DATE September 09, 1999  
 BY Ishag I. Chanda  
 PRODUCT CONTROL DIVISION  
 BUILDING CODE COMPLIANCE OFFICE  
 ACCEPTANCE NO. 98-1229.02



Revision: 2/30/99: Added design pressure; Reduced to 61/2"x11" format  
 Revision: 4/18/99: Design pressure corrected to +48.3psf-59.9psf

Prepared: 14 July 1998

Design Pressure: +48.3psf-59.9psf



**PRODUCT RENEWED**  
 as complying with the Florida  
 Building Code  
 Acceptance No. 02-0805-01  
 Expiration Date AUG 19, 2007  
 By Ishag I. Chaudh  
 Miami Dade Product Control  
 Division

APPROVED AS COMPLYING WITH THE  
 SOUTH FLORIDA BUILDING CODE  
 DATE September 09 1999  
 BY Ishag I. Chaudh  
 PRODUCT CONTROL DIVISION  
 BUILDING CODE COMPLIANCE OFFICE  
 ACCEPTANCE NO. 99-0229-02

Revision: 3/30/99: Added design pressure; Reduced to 8 1/2"x11" format.  
 Revision: 4/15/99: Design pressure corrected to +48.3psf-59.9psf

Prepared: 14 July 1998.




Project:

FLBMDA #95-0001

F1518 18-Lite French Door

(7 Pages: D1-D7)

Page No:  
**D4**



**PRODUCT RENEWED**  
 as complying with the Florida  
 Building Code  
 Acceptance No. 02-0805-01  
 Expiration Date AUG 19, 2007  
 By Ishaq I. Chaudhry  
 Miami Dade/Product Control  
 Division

APPROVED AS COMPLYING WITH THE  
 SOUTH FLORIDA BUILDING CODE  
 DATE September 09, 1999  
 BY Ishaq I. Chaudhry  
 PRODUCT CONTROL DIVISION  
 BUILDING CODE COMPLIANCE OFFICE  
 ACCEPTANCE NO. 98-1229-02

Revision: 3/30/99: Added design pressure; Reduced to 8 1/2"x11" format  
 Revision: 4/15/99: Design pressure corrected to +48.3psf-59.8psf

Prepared: 14 July 1998

Project:

**PRODUCT RENEWED**  
 as complying with the Florida  
 Building Code  
 Acceptance No. 02-0805-01  
 Expiration Date Aug 19, 2007


APPROVED AS COMPLYING WITH THE  
 SOUTH FLORIDA BUILDING CODE  
 DATE September 09, 1999  
 BY Iskay I. Chanda

**Golden Pharos USA, Inc.**  
 700 Atlantic Road, Unit 101, Bldg. A.  
 Phone (407)678-1815 • Fax (407)678-6331


By Iskay I. Chanda  
 PROJECT CONTROL DIVISION  
 BUILDING CODE COMPLIANCE OFFICE

Design Pressure: +48.3psf-59.9psf  
 ACCEPTANCE NO. 98-1279-02


**Type D: 1818 Family**




2020




1820




1818




1810




1808




2059




1809




1880




1890




2016




944




2056



1518



1512



1506

Revision: 3/30/98: Added design pressure; Reduced to 81/2"x11" format.  
 Revision: 4/18/98: Design pressure corrected to +48.3psf-59.9psf

Prepared: 14 July 1998.


Project:

Page No:  
**D6**


Golden Pharos USA, Inc.  
 700 Atlantic Road, Unit 104, Bldg. A Y Melbourne, Fla. 32904  
 Phone (407)676-1615 Y Fax (407)676-6551

Design Pressure: +48.3psf-59.9psf


Type B: 1518 Family





944



259



2055



PRODUCT RENEWED  
 as complying with the Florida  
 Building Code  
 Acceptance No. 02-0805.01  
 Expiration Date, AUG 19, 2007  
 By Ishag I. Chanda  
 Miami Dade Product Control  
 Division

APPROVED AS COMPLYING WITH THE  
 SOUTH FLORIDA BUILDING CODE  
 DATE September 09, 1999  
 BY Ishag I. Chanda  
 PRODUCT CONTROL DIVISION  
 BUILDING CODE COMPLIANCE OFFICE  
 ACCEPTANCE NO. 98-1229-02

Revision: 2/30/99: Added design pressure; Reduced to 8 1/2"x11" format  
 Revision: 4/16/99: Design pressure corrected to +48.3psf-59.9psf

Prepared: 14 July 1998

Project:

FLBMDA #95-0001

F1518 18-Lite French Door

(7 Pages: D1-D7)

Page No:  
**D7**