



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

---

**Golden Pharos USA, Inc.  
700 Atlantis Road Bldg.101  
Melbourne, FL 32904**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Series "F2130" Outswing Raised Wood Panel Door Slab-FBMA Component**

**APPROVAL DOCUMENT:** Drawing titled "Project FLBMDA #95-0003" Series F2130 6-Panel Door", sheets A1 through A7 of 7, prepared by the manufacturer, dated 7/14/98 last revised on 08-13-02, bearing the Miami-Dade County Product Control Renewal stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Division.

**MISSILE IMPACT RATING: None**

**LABELING:** Each unit shall bear a permanent label, issued by FBMA (FLBMDA) with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.


**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA # 98-1229.03 and, consists of this page 1 as well as approval document mentioned above. The submitted documentation was reviewed by **Ishaq I. Chanda, P.E.**



**NOA No 02-0805.08  
Expiration Date: August 19, 2007  
Approval Date: August 19, 2002  
Page 1**



**PRODUCT RENEWED**  
 as complying with the Florida  
 Building Code  
 Acceptance No 02-0805-08  
 Expiration Date AUG 19, 2007  
 By Ishar I. Chanda  
 Miami Dade Product Control  
 Division

**Section Drawings  
 Not to Scale**

Not to Scale  
**F-2130**  
 Six Panel  
 36"x96"x1 3/4"

**General Notes:**

1. This component is approved as equal alternate to the Series 2130 Out-swing Raised Panel Door, per NWWDAI.S. 6-91, to be used, interchangeably only, in out-swing door systems with approvals under the auspices of FLBMDA's (FBMA) system: 95-0003(b).
2. Single door units shall include all components described in the active leaf of system approval.
3. Installation of this product will require HVZ approved hurricane protection system.

- Wood Species**
- o Vertical Grain Douglas Fir (Pseudotsuga Taxifolia)
  - o American Red Oak (Quercus Rubis)
  - o Nyatoh (Sapotaceae)
  - o Meranti Bakau (Shorea Uliginosa)

- REVISION: 3/30/99 ADDED DESIGN PRESSURE;  
 REDUCED TO 8-1/2" X 11" FORMAT  
 REVISION: 4/15/99 PANEL SIZE CORRECTED TO 3/4"  
 REVISION: 8/13/02 ADD NOTES

Prepared: 14 July 1998

Golden Pharos USA, Inc.  
700 Atlantic Road, Unit 101, Bldg. A. • Melbourne, Fla. 32904  
Phone (407)676-1615 • Fax (407)676-6551

Design Pressure: +48.3psf-63.4psf

### BILL OF MATERIALS

#### PRODUCT TYPE AND SERIES

Golden Pharos USA, Inc.

F-2130 Six Panel Exterior Door  
Vertical Grain Douglas Fir  
Veneer Construction

M-2130 Meranti Veneer Construction  
N-2130 Nyatoh Veneer Construction  
R-2130 Red Oak Veneer Construction

#### CONFIGURATION:

Single Slab Door

Dimensions: 1 3/4" X 36" X 96"

#### CORNER CONSTRUCTION:

Top Rail: 1 3/4" X 6 1/2" X 27 5/8"  
Two (2) 5/8" X 5" Dowels at each end.  
2 7/8" Penetration into the rail.

Cross Rail: 1 3/4" X 4 1/2" X 27 5/8"  
Two (2) 5/8" X 5" Dowels at each end.  
2 7/8" Penetration into the rail.

Lock Rail: 1 3/4" X 7 1/2" X 27 5/8"  
Three (3) 5/8" X 5" Dowels at each end.  
2 7/8" Penetration into the rail.

Bottom Rail: 1 3/4" X 9 7/16" X 27 5/8"  
Four (4) 5/8" X 5" Dowels at each end.  
2 7/8" Penetration into the rail.

Stiles: 1 3/4" X 4 1/2" X 96"

#### Mullions:

One (1) 1 3/4" X 4 1/2" X 12 3/16"  
One (1) 1 3/4" X 4 1/2" X 34 5/8"  
One (1) 1 3/4" X 4 1/2" X 23 1/2"

#### Panels:

96" Door  
Two (2) 3/4" X 11 13/16" X 12"  
Two (2) 3/4" X 11 13/14" X 34 7/16"  
Two (2) 3/4" X 11 13/16" X 23 3/8"

#### PRODUCT RENEWED

as complying with the Florida  
Building Code

Acceptance No. 02-0805-08

Expiration Date Aug 19, 2007

By Ishag I. Chanda  
Miami Dade Product Control  
Division

APPROVED AS COMPLYING WITH THE  
SOUTH FLORIDA BUILDING CODE

DATE September 09, 1999

BY Ishag I. Chanda

PRODUCT CONTROL DIVISION

BUILDING CODE COMPLIANCE OFFICE

ACCEPTANCE NO. 98-1229-02

#### Drawings Not to Scale

Revisions: 3/30/99: Added design pressure; Reduced to 8 1/2" x 11" format  
Revisions: 4/18/99: Panel size corrected to 3/4"

Prepared: 14 July 1998

Project

FLBMDA #95-0003

F2130 6-Panel Door

(7 Pages: A1-A7)

Page No:

**A2**

Golden Pharos USA, Inc.  
 700 Atlantic Road, Unit 101, Bldg. A • Melbourne, Fla. 32904  
 Phone (407)678-1815 • Fax (407)678-8551


Design Pressure: +48.3psf-63.4psf

PRODUCT REVIEWED  
 as complying with the Florida  
 Building Code  
 Acceptance No. 02-0205-08  
 Expiration Date: August 2, 2007


By Isaac I. Chaudh  
 Miami Dade Product Control  
 Division

**Dowel Penetration  
 (Typical Detail)**

APPROVED AS COMPLYING WITH THE  
 SOUTH FLORIDA BUILDING CODE  
 DATE September 09, 1999  
 BY Isaac I. Chaudh  
 PRODUCT CONTROL DIVISION  
 BUILDING CODE COMPLIANCE OFFICE  
 ACCEPTANCE NO. 98-1229-03



**Veneer Construction  
 (Typical)**



Drawings Not to Scale

Revision: 3/30/99: Added design pressure; Reduced to 8 1/2"x11" format

Prepared: 14 July 1998

Project:

FLBMDA #95-0003

F2130 6-Panel Door

(7 Pages: A1-A7)

Page No:  
**A3**


Golden Pharos USA, Inc.  
 700 Atlantic Road, Unit 101, Bldg. A. • Melbourne, Fla. 32904  
 Phone (407)878-1815 • Fax (407)878-8551

Design Pressure: +48.3psf-63.4psf


**PRODUCT RENEWED**  
 as complying with the Florida  
 Building Code  
 Acceptance No. 02-0805-08  
 Expiration Date April 19, 2007

By Ishaq I. Chande  
 Miami Dade Product Control  
 Division

APPROVED AS COMPLYING WITH THE  
 SOUTH FLORIDA BUILDING CODE  
 DATE September 09 1999  
 BY Ishaq I. Chande  
 PRODUCT CONTROL DIVISION  
 BUILDING CODE COMPLIANCE OFFICE  
 ACCEPTANCE NO. 98-1229-03



Veneer Construction  
(Typical)



Drawings Not to Scale

Revision: 3/30/98: Added design pressure; Reduced to 61/2"x11" format  
 Revision: 4/18/98: Panel size corrected to 3/4"

Prepared: 14 July 1998

Project:




Page No:

FLBMDA #95-0003

F2130 6-Panel Door

(7 Pages: A1-A7)

A4



APPROVED AS COMPLYING WITH THE  
 SOUTH FLORIDA BUILDING CODE  
 DATE September 09 1999  
 BY Ishag I. Charis  
 PRODUCT CONTROL DIVISION  
 BUILDING CODE COMPLIANCE OFFICE  
 ACCEPTANCE NO. 98-1229.03

**PRODUCT RENEWED**  
 as complying with the Florida  
 Building Code  
 Acceptance No. 02-0805.08  
 Expiration Date Aug 19, 2007  
 By Ishag I. Charis  
 Miami Dade Product Control  
 Division

Drawings Not to Scale

Revision: 3/30/99: Added design pressure; Reduced to 8 1/2"x11" format  
 Revision: 4/18/99: Panel size corrected to 3/4"

Prepared: 14 July 1998

Project:

FLBMDA #95-0003




F2130 6-Panel Door

(7 Pages: A1-A7)

Page No:

**A5**

Group A: 2130 Family




**PRODUCT RENEWED**  
 as complying with the Florida  
 Building Code  
 Acceptance No. 02-0805-08  
 Expiration Date Aug 19, 2007  
 By Ishaq I. Chaudhry  
 Miami Dade Product Control  
 Division


6 Panel Curve Top

15 Panel


APPROVED AS COMPLYING WITH THE  
 SOUTH FLORIDA BUILDING CODE  
 DATE September 09, 1999  
 BY Ishaq I. Chaudhry  
 PRODUCT CONTROL DIVISION  
 BUILDING CODE COMPLIANCE OFFICE  
 ACCEPTANCE NO. 98-1229-03




10 Panel



6 Panel



6 Panel Curve Top



15 Panel

Drawings Not to Scale

Revision: 3/30/99: Added design pressure; Reduced to 8 1/2"x11" format  
 Revision: 4/18/99: Doors under 6 panels separated into a separate family

Prepared: 14 July 1998

Project:



FLBMDA #95-0003

F2130 6-Panel Door

(7 Pages: A1-A7)




Page No:  
**A6**

**Group A: 2130 Family**



**PRODUCT RENEWED**  
 as complying with the Florida  
 Building Code  
 Acceptance No. 02-0805-08  
 Expiration Date AUG 19, 2007  
 By Ishag I. Chanda  
 Miami Dade Product Control  
 Division

APPROVED AS COMPLYING WITH THE  
 SOUTH FLORIDA BUILDING CODE  
 DATE September 09, 1999  
 BY Ishag I. Chanda  
 PRODUCT CONTROL DIVISION  
 BUILDING CODE COMPLIANCE OFFICE  
 ACCEPTANCE NO. 98-1279-03



**Drawings Not to Scale**

Revision: 3/30/88: Added design pressure; Reduced to 8 1/2" x 11" format  
 Revision: 4/15/88: Doors under 6 panels separated into a separate family

Prepared: 14 July 1988

Project:

FLBMDA #95-0003

F2130 6-Panel Door

(7 Pages: A1-A7)

Page No:  
**A7**