



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

---

**Bitec, Inc.  
#2 Industrial Park Drive  
Morrilton, AR 72110**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Bitec Modified Roof Systems for Wood Decks**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This consists of pages 1 through 33

The submitted documentation was reviewed by Frank Zuloaga, RRC



**NOA No 02-1018.03  
Expiration Date: 03/27/08  
Approval Date: 03/27/03  
Page 1 of 33**

## ROOFING ASSEMBLY APPROVAL

**Category:** Roofing  
**Sub-Category:** APP/SBS Modified Bitumen  
**Deck Type:** Wood  
**Maximum Design Pressure** -60 psf  
**Fire Classification:** See General Limitation #1

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
APM-4.5T	25.58 x 3.28'; roll weight: 92lbs.	ASTM D 5147	APP mineral surfaced modified bitumen membrane reinforced with polyester for use as a roof membrane sheet.
APM-4T	32.8 x 3.28'; roll weight: 107 lbs.	ASTM D 5147	APP mineral surfaced modified bitumen membrane reinforced with polyester for use as a roof membrane sheet.
MDA	32.8 x 3.28'; roll weight: 107 lbs.	ASTM D 5147	APP colored pattern mineral surfaced modified bitumen membrane reinforced with polyester for use as a roof membrane sheet.
APS-4T	33.5 x 32.8'; roll weight: 90 lbs.	ASTM D 5147	APP modified bitumen membrane reinforced with polyester for use as a roof membrane sheet.
FA-2T	49.2 x 3.28'; roll weight: 70 lbs.	ASTM D 5147	APP modified bitumen membrane reinforced with fiberglass for use as a base sheet or interply membrane.
MAC 300		PA 121	Aluminum roof coating
MAC 200		PA 121	Aluminum roof coating.
SPM-3.5H	33.9 x 3.28'; roll weight: 100 lbs.	ASTM D 5147	SBS mineral surfaced modified bitumen membrane reinforced with polyester for use as a roof membrane sheet.
SPM-4H	32.8 x 3.28'; roll weight: 100 lbs.	ASTM D 5147	SBS mineral surfaced modified bitumen membrane reinforced with polyester for use as a roof membrane sheet.
MDS	32.8 x 3.28'; roll weight: 100 lbs.	ASTM D 5147	SBS colored pattern mineral surfaced modified bitumen membrane reinforced with polyester for use as a roof membrane sheet.
SPM-4.5T	25.58 x 3.28'; roll weight: 92 lbs.	ASTM D 5147	SBS mineral surfaced modified bitumen membrane reinforced with polyester for use as a roof membrane sheet.
SPS-3H	33.5 x 32.8'; roll weight: 83 lbs	ASTM D 5147	SBS modified bitumen membrane reinforced with polyester for use as a roof membrane sheet.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
SFM-3.5H	33.9 x 3.28'; roll weight: 100 lbs.	ASTM D 5147	SBS modified bitumen membrane reinforced with fiberglass for use as a roof membrane.
SFM-3.5H-FR	33.9 x 3.28'; roll weight: 103 lbs.	ASTM D 5147	SBS modified bitumen membrane reinforced with fiberglass for use as a roof membrane sheet.
FS-2H	49.2 x 3.28'; roll weight: 70 lbs.	ASTM D 5147	SBS modified bitumen membrane reinforced with fiberglass for use as a base sheet or interply membrane

**EVIDENCE SUBMITTED**

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Factory Mutual Research Corporation	J.I. # 0B3A7.AM		12/30/96
Dynatech Engineering, Inc.	06.94.07	Wind Uplift Testing	06/07/94
Underwriters Laboratories, Inc.	R12321 (N)	Fire Classification Compliance	02/25/93



**APPROVED SYSTEMS**

- Membrane Type:** APP
- Deck Type II:** Wood, Insulated, New Construction or Reroof
- Deck Description:** 1 9/32" or greater plywood or wood plank
- System Type A:** Anchor sheet mechanically fastened; all layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

<u>Insulation Base Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
----------------------------------	--------------------------	---------------------------------	--------------------------------	-----------------------------

One or more layers of the following:

Approved Type(s): ACFoam II, Armor R Plus, Dow Iso, GAFTEMP Isotherm RA, Kop-R(WII), UltraGard, USIso				
Minimum: 4' x 4' x 1.5"	N/A	N/A	N/A	N/A

<u>Insulation Base or Top Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
---	--------------------------	---------------------------------	--------------------------------	-----------------------------

One or more layers of any of the following insulations:

Approved Type(s): Celotherm, ConPerl, GAFTEMP Permalite, Fesco Board				
Minimum: 2' x 4' x 3/4"	N/A	N/A	N/A	N/A

Approved Type(s): Armor Board Regular, Esgard, Celotex Fiberboard, GAFTEMP Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber				
Minimum: 4' x 4' x 1"	N/A	N/A	N/A	N/A

Approved Type(s): Celotex High Density Wood Fiberboard				
Minimum: 4' x 4' x 1/2"	N/A	N/A	N/A	N/A

Approved Type(s): ACFoam Composite, Kop-R(WC), Fesco Foam, USIso/Perlite Composite				
Minimum: 4' x 4' x 1.5"	N/A	N/A	N/A	N/A

**Note:** All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

**Anchor Sheet:** One ply of GAFGLAS #75 fastened to the deck as described below:



- Fastening:** Fasten anchor sheet using approved roofing nails and tin caps spaced 9" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.
- Base Sheet:** One or more plies of PermaPly No. 28, Glas Base, VaporBar, GAFGLAS #75 adhered to the insulated substrate with a full mopping of approved asphalt at an application rate of 25 lb./sq. ± 15%.
- Ply Sheet:** (Optional or as specified) One ply of FA-2T or APS-4T torch applied or one or more plies of GlasPly IV or GlasPly Premier adhered with a full mopping of asphalt at an application rate of 25 lb./sq. ± 15%.
- Membrane:** One ply of MDA, APS-4T, APM-4T, or APM-4.5T torch applied.
- Surfacing:** (Optional) Install one of the following as required for fire rating:  
1. APOC 212, Henry 520, Karnak 97 or 97AF, MAC 200, Monsey ProGrade Aluminum or Grundy al MB applied at a rate of 1 ½ gal./sq.  
2. Install 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved asphalt at an application rate of 60 lb./sq..
- Maximum Design Pressure:** -45 psf (See General Limitation #9)



**Membrane Type:** SBS

**Deck Type II:** Wood, Insulated, New Construction or Reroof

**Deck Description:** 19/32" or greater plywood or wood plank

**System Type A:** Anchor sheet mechanically fastened; all layers of insulation adhered with approved asphalt.

**All General and System Limitations apply.**

<u>Insulation Base Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
----------------------------------	--------------------------	---------------------------------	--------------------------------	-----------------------------

One or more layers of the following:

Approved Type(s): **ACFoam II, Armor R Plus, Dow Iso, GAFTEMP Isotherm RA, Kop-R(WII), UltraGard, USIso**  
 Minimum: 4' x 4' x 1.5"      N/A      N/A      N/A      N/A

<u>Insulation Base or Top Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
---	--------------------------	---------------------------------	--------------------------------	-----------------------------

One or more layers of any of the following insulations:

Approved Type(s): **Celotherm, ConPerl, GAFTEMP Permalite, Fesco Board**  
 Minimum: 2' x 4' x 3/4"      N/A      N/A      N/A      N/A

Approved Type(s): **Armor Board Regular, Esgard, Celotex Fiberboard, GAFTEMP Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber**  
 Minimum: 4' x 4' x 1"      N/A      N/A      N/A      N/A

Approved Type(s): **Celotex High Density Wood Fiberboard**  
 Minimum: 4' x 4' x 1/2"      N/A      N/A      N/A      N/A

Approved Type(s): **ACFoam Composite, Kop-R(WC), Fesco Foam, USIso/Perlite Composite**  
 Minimum: 4' x 4' x 1.5"      N/A      N/A      N/A      N/A

**Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.**

**Anchor Sheet:** One ply of GAFGLAS #75 fastened to the deck as described below:

**Fastening:** Fasten anchor sheet using approved roofing nails and tin caps spaced 9" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.



- Base Sheet:** One or more plies of PermaPly No. 28, Glas Base, VaporBar, GAFGLAS #75 adhered to the insulated substrate with a full mopping of approved asphalt at an application rate of 25 lb./sq. ± 15%.
- Ply Sheet:** (Optional or as specified) One ply of FS-2H or SPS-3H or one or more plies of GlasPly IV or GlasPly Premier adhered with a full mopping of approved asphalt at an application rate of 25 lbs./sq. ± 15%.
- Membrane:** One ply of SPM-4.5T torch welded, or one ply of MDS, SPM-3.5H, SFM-3.5H, SFM-3.5H-FR or SPS-3H adhered with a full mopping of approved asphalt at an application rate of 25 lb./sq. ± 15%.
- Surfacing:** (Optional) Install one of the following as required for fire rating:
1. Karnak 97 or 97AF, MAC 200, MAC 300, Monsey ProGrade Aluminum or Grundy al MB applied at a rate of 1 ½ gal./sq.
  2. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved asphalt at an application rate of 60 lb./sq.
- Maximum Design Pressure:** -45 psf (See General Limitation # 9)



**Membrane Type:** APP

**Deck Type II:** Wood, Insulated, New Construction or Reroof

**Deck Description:** 19/32" or greater plywood or wood plank

**System Type A:** Anchor sheet mechanically fastened; all layers of insulation adhered with approved asphalt.

**All General and System Limitations apply.**

**Deck Attachment:** In accordance with applicable Building Code, but in no case shall it be less than # 8 x 1½" wood screws. In reroofing, where the deck is less than 19/32" thick (Minimum 15/32"). The above attachment method must be in addition to the existing attachment.

<u>Insulation Base Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
----------------------------------	--------------------------	---------------------------------	--------------------------------	-----------------------------

One or more layers of the following:

Approved Type(s): <b>ACFoam II</b>				
Minimum: 4' x 4' x 1.5"	N/A	N/A	N/A	N/A

<u>Insulation Base or Top Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
---	--------------------------	---------------------------------	--------------------------------	-----------------------------

One or more layers of any of the following insulations:

Approved Type(s): <b>Celotex High Density Wood Fiberboard</b>				
Minimum: 4' x 4' x ½"	N/A	N/A	N/A	N/A

**Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.**

**Anchor Sheet:** One ply of GAFGLAS #75 fastened to the deck as described below:

**Fastening:** Fasten anchor sheet using Olympic Standard Screws (#12) and Standard Metal Plates (3" round) spaced 12" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.

**Base Sheet:** One or more plies of GAFGLAS #75 adhered to the insulated substrate with a full mopping of approved asphalt at an application rate of 25 lb./sq. ± 15%.



Ply Sheet: (Optional or as specified) One ply of FA-2T or APS-4T torch applied or one or more plies of GlasPly IV or GlasPly Premier adhered with a full mopping of asphalt at an application rate of 25 lb./sq. ± 15%.

Membrane: One ply of MDA, APS-4T, APM-4T, or APM-4.5T torch applied.

Surfacing: (Optional) Install one of the following as required for fire rating:  
1. APOC 212, Henry 520, Karnak 97 or 97AF, MAC 200, Monsey ProGrade Aluminum or Grundy al MB applied at a rate of 1 ½ gal./sq.  
2. Install 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved asphalt at an application rate of 60 lb./sq..

Maximum Design Pressure: -52.5 psf (See General Limitation #7)



**Membrane Type:** SBS

**Deck Type II:** Wood, Insulated, New Construction or Reroof

**Deck Description:** 19/32" or greater plywood or wood plank

**System Type A:** Anchor sheet mechanically fastened; all layers of insulation adhered with approved asphalt.

**All General and System Limitations apply.**

**Deck Attachment:** In accordance with applicable Building Code, but in no case shall it be less than # 8 x 1½" wood screws. In reroofing, where the deck is less than 19/32" thick (Minimum 15/32"). The above attachment method must be in addition to the existing attachment.

<u>Insulation Base Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
----------------------------------	--------------------------	---------------------------------	--------------------------------	-----------------------------

One or more layers of the following:

Approved Type(s): <b>ACFoam II</b>				
Minimum: 4' x 4' x 1.5"	N/A	N/A	N/A	N/A

<u>Insulation Base or Top Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
---	--------------------------	---------------------------------	--------------------------------	-----------------------------

One or more layers of the following:

Approved Type(s): <b>Celotex High Density Wood Fiberboard</b>				
Minimum: 4' x 4' x ½"	N/A	N/A	N/A	N/A

**Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.**

**Anchor Sheet:** One ply of GAFGLAS #75 fastened to the deck as described below:

**Fastening:** Fasten anchor sheet using Olympic Standard Screws (#12) and Standard Metal Plates (3" round) spaced 12" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.

**Base Sheet:** One or more plies of GAFGLAS #75 adhered to the insulated substrate with a full mopping of approved asphalt at an application rate of 25 lb./sq. ± 15%.



Ply Sheet: (Optional or as specified) One ply of FS-2H or SPS-3H or one or more plies of GlasPly IV or GlasPly Premier adhered with a full mopping of approved asphalt at an application rate of 25 lbs./sq. ± 15%.

Membrane: One ply of SPM-4.5T torch welded, or one ply of MDS, SPM-3.5H, SFM-3.5H, SFM-3.5H-FR or SPS-3H adhered with a full mopping of approved asphalt at an application rate of 25 lb./sq. ± 15%.

Surfacing: (Optional) Install one of the following as required for fire rating:  
1. Karnak 97 or 97AF, MAC 200, MAC 300, Monsey ProGrade Aluminum or Grundy al MB applied at a rate of 1 ½ gal./sq.  
2. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved asphalt at an application rate of 60 lb./sq..

Maximum Design Pressure: -52.5 psf (see General Limitations #7)



**Membrane Type:** APP

**Deck Type II:** Wood, Insulated, New Construction or Reroof

**Deck Description:** 1<sup>9</sup>/<sub>32</sub>" or greater plywood or wood plank

**System Type B:** Base layer of insulation mechanically attached, top layer adhered with approved asphalt.

All General and System Limitations apply.

<u>Insulation Base Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
----------------------------------	--------------------------	---------------------------------	--------------------------------	-----------------------------

Approved Type(s): **ACFoam II**

Minimum: 4' x 4' x 1.5"	Olympic	[3]	8	1:2 ft. <sup>2</sup>
Minimum: 4' x 4' x 1.5"	Olympic	[3]	6	1:2.67 ft. <sup>2</sup>

Approved Type(s): **ACFoam Composite, Kop-R(WC), Fesco Foam, USIso/Perlite Composite**

Minimum: 4' x 4' x 2"	Olympic	[3]	8	1:2 ft. <sup>2</sup>
Minimum: 4' x 4' x 2"	Olympic	[3]	6	1:2.67 ft. <sup>2</sup>

**Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).**

<u>Insulation Top Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
---------------------------------	--------------------------	---------------------------------	--------------------------------	-----------------------------

Approved Type(s): **Celotex High Density Wood Fiberboard**

Minimum: 4' x 4' x 1/2"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

Approved Type(s): **ACFoam Composite, Kop-R(WC), Fesco Foam, USIso/Perlite Composite**

Minimum: 4' x 4' x 1.5"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

**Note: Apply top layer of insulation in a full mopping of any approved mopping hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as Base Layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.**

**Base Sheet:** One or more plies of PermaPly No. 28, Glas Base, VaporBar, GAFGLAS #75 adhered to the insulated substrate with a full mopping of approved asphalt at an application rate of 25 lb./sq. ± 15%.



Ply Sheet: (Optional or as specified) One ply of FA-2T or APS-4T torch applied or one or more plies of GlasPly IV or GlasPly Premier adhered with a full mopping of asphalt at an application rate of 25 lb./sq. ± 15%.

Membrane: One ply of MDA, APS-4T, APM-4T, or APM-4.5T torch applied.

Surfacing: (Optional) Install one of the following as required for fire rating:  
1. APOC 212, Henry 520, Karnak 97 or 97AF, MAC 200, Monsey ProGrade Aluminum or Grundy al MB applied at a rate of 1 ½ gal./sq.  
2. Install 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved asphalt at an application rate of 60 lb./sq..

Maximum Design Pressure: -45 psf (See General Limitations #9.)



**Membrane Type:** SBS

**Deck Type II:** Wood, Insulated, New Construction or Reroof

**Deck Description:** 19/32" or greater plywood or wood plank

**System Type B:** Base layer of insulation mechanically attached, top layer adhered with approved asphalt.

**All General and System Limitations apply.**

<u>Insulation Base Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
Approved Type(s): <b>ACFoam II</b>				
Minimum: 4' x 4' x 1.5"	Olympic	[3]	8	1:2 ft. <sup>2</sup>
Minimum: 4' x 4' x 1.5"	Olympic	[3]	6	1:2.67 ft. <sup>2</sup>
Approved Type(s): <b>ACFoam Composite, Kop-R(WC), Fesco Foam, USIso/Perlite Composite</b>				
Minimum: 4' x 4' x 2"	Olympic	[3]	8	1:2 ft. <sup>2</sup>
Minimum: 4' x 4' x 2"	Olympic	[3]	6	1:2.67 ft. <sup>2</sup>

**Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).**

<u>Insulation Top Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
Approved Type(s): <b>Celotex High Density Wood Fiberboard</b>				
Minimum: 4' x 4' x 1/2"	N/A	N/A	N/A	N/A
Approved Type(s): <b>ACFoam Composite, Kop-R(WC), Fesco Foam, USIso/Perlite Composite</b>				
Minimum: 4' x 4' x 1.5"	N/A	N/A	N/A	N/A

**Note: Apply top layer of insulation in a full mopping of any approved mopping hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as Base Layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.**

**Base Sheet:** One or more plies of PermaPly No. 28, Glas Base, VaporBar, GAFGLAS #75 adhered to the insulated substrate with a full mopping of approved asphalt at an application rate of 25 lb./sq. ± 15%.



- Ply Sheet:** (Optional or as specified) One ply of FS-2H or SPS-3H or one or more plies of GlasPly IV or GlasPly Premier adhered with a full mopping of approved asphalt at an application rate of 25 lbs./sq. ± 15%.
- Membrane:** One ply of SPM-4.5T torch welded, or one ply of MDS, SPM-3.5H, SFM-3.5H, SFM-3.5H-FR or SPS-3H adhered with a full mopping of approved asphalt at an application rate of 25 lb./sq. ± 15%.
- Surfacing:** (Optional) Install one of the following as required for fire rating:
1. Karnak 97 or 97AF, MAC 200, MAC 300, Monsey ProGrade Aluminum or Grundy al MB applied at a rate of 1 ½ gal./sq.
  2. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved asphalt at an application rate of 60 lb./sq..
- Maximum Design Pressure:** -45 psf (See General Limitations #9.)



**Membrane Type:** APP

**Deck Type II:** Wood, Insulated, New Construction or Reroof

**Deck Description:** 19/32" or greater plywood or wood plank

**System Type B:** Base layer of insulation mechanically attached, top layer adhered with approved asphalt.

**All General and System Limitations apply.**

**Deck Attachment:** In accordance with applicable Building Code, but in no case shall it be less than # 8 x 1½" wood screws. In reroofing, where the deck is less than 19/32" thick (Minimum 15/32"). The above attachment method must be in addition to existing attachment.

<u>Insulation Base Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
Approved Type(s): AC Foam II Minimum: 4' x 4' x 1.5"	Olympic	[3]	8	1:2 ft. <sup>2</sup>

**Note:** Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Insulation Top Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
Approved Type(s): Celotex High Density Wood Fiberboard Minimum: 4' x 4' x ½"	N/A	N/A	N/A	N/A

**Note:** Apply top layer of insulation in a full mopping of any approved mopping hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as Base Layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

**Base Sheet:** One or more plies GAFGLAS #75 adhered to the insulated substrate with a full mopping of approved asphalt at an application rate of 25 lb./sq. ± 15%.



Ply Sheet: (Optional or as specified) One ply of FA-2T or APS-4T torch applied or one or more plies of GlasPly IV or GlasPly Premier adhered with a full mopping of asphalt at an application rate of 25 lb./sq. ± 15%.

Membrane: One ply of MDA, APS-4T, APM-4T, or APM-4.5T torch applied.

Surfacing: (Optional) Install one of the following as required for fire rating:  
1. APOC 212, Henry 520, Karnak 97 or 97AF, MAC 200, Monsey ProGrade Aluminum or Grundy al MB applied at a rate of 1 ½ gal./sq.  
2. Install 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved asphalt at an application rate of 60 lb./sq..

Maximum Design Pressure: -52.5 psf (See General Limitations #7.)



**Membrane Type:** SBS

**Deck Type II:** Wood, Insulated, New Construction or Reroof

**Deck Description:** 19/32" or greater plywood or wood plank

**System Type B:** Base layer of insulation mechanically attached, top layer adhered with approved asphalt.

**All General and System Limitations apply.**

**Deck Attachment:** In accordance with applicable Building Code, but in no case shall it be less than # 8 x 1½" wood screws. In reroofing, where the deck is less than 19/32" thick (Minimum 15/32"). The above attachment method must be in addition to the existing attachment.

<u>Insulation Base Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
Approved Type(s): <b>ACFoam II</b> Minimum: 4' x 4' x 1.5"	Olympic	[3]	8	1:2 ft. <sup>2</sup>

**Note:** Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Insulation Top Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
Approved Type(s): <b>Celotex High Density Wood Fiberboard</b> Minimum: 4' x 4' x ½"	N/A	N/A	N/A	N/A

**Note:** Apply top layer of insulation in a full mopping of any approved mopping hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as Base Layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

**Base Sheet:** One or more plies of GAFGLAS #75 adhered to the insulated substrate with a full mopping of approved asphalt at an application rate of 25 lb./sq. ± 15%.



Ply Sheet: (Optional or as specified) One ply of FS-2H or SPS-3H or one or more plies of GlasPly IV or GlasPly Premier adhered with a full mopping of approved asphalt at an application rate of 25 lbs./sq. ± 15%.

Membrane: One ply of SPM-4.5T torch welded, or one ply of MDS, SPM-3.5H, SFM-3.5H, SFM-3.5H-FR or SPS-3H adhered with a full mopping of approved asphalt at an application rate of 25 lb./sq. ± 15%.

Surfacing: (Optional) Install one of the following as required for fire rating:  
1. Karnak 97 or 97AF, MAC 200, MAC 300, Monsey ProGrade Aluminum or Grundy al MB applied at a rate of 1 ½ gal./sq.  
2. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved asphalt at an application rate of 60 lb./sq..

Maximum Design Pressure: -52.5 psf (See General Limitations #7.)



**Membrane Type:** APP

**Deck Type II:** Wood, Insulated, New Construction or Reroof

**Deck Description:** 1<sup>9</sup>/<sub>32</sub>" or greater plywood or wood plank

**System Type C:** All layers of insulation simultaneously fastened.

**All General and System Limitations apply.**

<u>Insulation Base Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
----------------------------------	--------------------------	---------------------------------	--------------------------------	-----------------------------

One or more layers of any of the following insulations:

Approved Type(s): **ACFoam II, Armor R Plus, Dow Iso, GAFTEMP Isotherm RA, Kop-R(WII), UltraGard, USIso**

Minimum: 4' x 4' x 1.4"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

Approved Type(s): **ACFoam Composite, Kop-R(WC), Fesco Foam, USIso/Perlite Composite**

Minimum: 4' x 4' x 1.5"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

Approved Type(s): **Standard or Wide Flute Fiberglass Roof Insulation, Standard or Wide Flute Fiber Glass Roof Insulation**

Minimum: 4' x 4' x 15/16"	N/A	N/A	N/A	N/A
---------------------------	-----	-----	-----	-----

Approved Type(s): **Celotherm, ConPerl, GAFTEMP Permalite, Fesco Board**

Minimum: 2' x 4' x 1"	N/A	N/A	N/A	N/A
-----------------------	-----	-----	-----	-----

Approved Type(s): **Armor Board Regular, Esgard, Celotex Fiberboard, GAFTEMP Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber**

Minimum: 4' x 4' x 1"	N/A	N/A	N/A	N/A
-----------------------	-----	-----	-----	-----

Approved Type(s): **Type X Gypsum**

Minimum: 4' x 8' x 5/8"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

Approved Type(s): **Celotherm, ConPerl, GAFTEMP Permalite, Fesco Board**

Minimum: 2' x 4' x 3/4"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**



<b><u>Insulation Top Layer</u></b>	<b><u>Fastener Type</u></b>	<b><u>Fastening Detail No.</u></b>	<b><u>Fasteners Per Board</u></b>	<b><u>Fastener Density</u></b>
--	---------------------------------	--	---------------------------------------	------------------------------------

Approved Type(s): **ACFoam II**

Minimum: 4' x 4' x 1.5"	Olympic	[3]	8	1:2 ft. <sup>2</sup>
Minimum: 4' x 4' x 1.5"	Olympic	[3]	6	1:2.67 ft. <sup>2</sup>

Approved Type(s): **ACFoam Composite, Kop-R(WC), Fesco Foam, USIso/Perlite Composite**

Minimum: 4' x 4' x 2"	Olympic	[3]	8	1:2 ft. <sup>2</sup>
Minimum: 4' x 4' x 2"	Olympic	[3]	6	1:2.67 ft. <sup>2</sup>

Base Sheet: One or more plies of GAFGLAS #75 fastened to the deck as described below:

Fastening : Fasten base sheet with metal plates and Dekfast #14, #15, Olympic #14, Rawl #14, or Roofgrip spaced 12" o.c. in a 4" side lap and 12" o.c. in two staggered rows in the center of the sheet

Ply Sheet: (Optional or as specified) One ply of FA-2T or APS-4T torch applied or one or more plies of GlasPly IV or GlasPly Premier adhered with a full mopping of asphalt at an application rate of 25 lb./sq. ± 15%.

Membrane: One ply of APM-4.5T, APM-4T, MDA, APS-4T torch applied.

Surfacing: (Optional) Install one of the following as required for fire rating:

1. APOC 212, Henry 520, Karnak 97 or 97AF, MAC 200, Monsey ProGrade Aluminum or Grundy al MB applied at a rate of 1 ½ gal./sq.
2. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved asphalt at an application rate of 60 lb./sq..

Maximum Design Pressure: -45 psf (See General Limitation #9)



**Membrane Type:** SBS

**Deck Type II:** Wood, Insulated, New Construction or Reroof

**Deck Description:** 1<sup>9</sup>/<sub>32</sub>" or greater plywood or wood plank

**System Type C:** All layers of insulation simultaneously fastened.

**All General and System Limitations apply.**

<u>Insulation Base Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
----------------------------------	--------------------------	---------------------------------	--------------------------------	-----------------------------

One or more layers of any of the following insulations:

Approved Type(s): **ACFoam II, Armor R Plus, Dow Iso, GAFTEMP Isotherm RA, Kop-R(WII), UltraGard, USIso**

Minimum: 4' x 4' x 1.4"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

Approved Type(s): **ACFoam Composite, Kop-R(WC), Fesco Foam, USIso/Perlite Composite**

Minimum: 4' x 4' x 1.5"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

Approved Type(s): **Standard or Wide Flute Fiberglass Roof Insulation, Standard or Wide Flute Fiber Glass Roof Insulation**

Minimum: 4' x 4' x 15/16"	N/A	N/A	N/A	N/A
---------------------------	-----	-----	-----	-----

Approved Type(s): **Celotherm, ConPerl, GAFTEMP Permalite, Fesco Board**

Minimum: 2' x 4' x 1"	N/A	N/A	N/A	N/A
-----------------------	-----	-----	-----	-----

Approved Type(s): **Armor Board Regular, Esgard, Celotex Fiberboard, GAFTEMP Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber**

Minimum: 4' x 4' x 1"	N/A	N/A	N/A	N/A
-----------------------	-----	-----	-----	-----

Approved Type(s): **Type X Gypsum**

Minimum: 4' x 8' x 5/8"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

Approved Type(s): **Celotherm, ConPerl, GAFTEMP Permalite, Fesco Board**

Minimum: 2' x 4' x 3/4"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**



<b><u>Insulation Top Layer</u></b>	<b><u>Fastener Type</u></b>	<b><u>Fastening Detail No.</u></b>	<b><u>Fasteners Per Board</u></b>	<b><u>Fastener Density</u></b>
--	---------------------------------	--	---------------------------------------	------------------------------------

Approved Type(s): **ACFoam II**

Minimum: 4' x 4' x 1.5"	Olympic	[3]	8	1:2 ft. <sup>2</sup>
Minimum: 4' x 4' x 1.5"	Olympic	[3]	6	1:2.67 ft. <sup>2</sup>

Approved Type(s): **ACFoam Composite, Kop-R(WC), Fesco Foam, USIso/Perlite Composite**

Minimum: 4' x 4' x 2"	Olympic	[3]	8	1:2 ft. <sup>2</sup>
Minimum: 4' x 4' x 2"	Olympic	[3]	6	1:2.67 ft. <sup>2</sup>

Base Sheet: One or more plies of GAFGLAS #75 fastened to the deck as described below:

Fastening : Fasten base sheet with metal plates and Dekfast #14, #15, Olympic #14, Rawl #14, or Roofgrip spaced 12" o.c. in a 4" side lap and 12" o.c. in two staggered rows in the center of the sheet.

Ply Sheet: (Optional or as specified) One ply of FS-2H or SPS-3H or one or more plies of GlasPly IV or GlasPly Premier adhered with a full mopping of approved asphalt at an application rate of 25 lbs./sq. ± 15%.

Membrane: One ply of SPM-4.5T torch welded, or one ply of MDS, SPM-3.5H, SFM-3.5H, SFM-3.5H-FR or SPS-3H adhered with a full mopping of approved asphalt at an application rate of 25 lb./sq. ± 15%.

Surfacing: (Optional) Install one of the following as required for fire rating:

1. Karnak 97 or 97AF, MAC 200, MAC 300, Monsey ProGrade Aluminum or Grundy al MB applied at a rate of 1 ½ gal./sq.
2. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved asphalt at an application rate of 60 lb./sq..

Maximum Design Pressure: -45 psf (See general Limitation #9)



**Membrane Type:** APP

**Deck Type II:** Wood, Insulated, New Construction or Reroof

**Deck Description:** 1<sup>9</sup>/<sub>32</sub>" or greater plywood or wood plank

**System Type D:** All layers of insulation and base sheet simultaneously fastened.

**All General and System Limitations apply.**

<u>Insulation Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
-------------------------	----------------------	-----------------------------	----------------------------	-------------------------

One or more layers of any of the following insulations:

Approved Type(s): **ACFoam II, Armor R Plus, Dow Iso, GAFTEMP Isotherm RA, Kop-R(WII), UltraGard, USIso**

Minimum: 4' x 4' x 1.4"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

Approved Type(s): **ACFoam Composite, Kop-R(WC), Fesco Foam, USIso/Perlite Composite**

Minimum: 4' x 4' x 1.5"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

Approved Type(s): **Standard or Wide Flute Fiberglass Roof Insulation, Standard or Wide Flute Fiber Glass Roof Insulation**

Minimum: 4' x 4' x 15/16"	N/A	N/A	N/A	N/A
---------------------------	-----	-----	-----	-----

Approved Type(s): **Celotherm, ConPerl, GAFTEMP Permalite, Fesco Board**

Minimum: 2' x 4' x 1"	N/A	N/A	N/A	N/A
-----------------------	-----	-----	-----	-----

Approved Type(s): **Armor Board Regular, Esgard, Celotex Fiberboard, GAFTEMP Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber**

Minimum: 4' x 4' x 1"	N/A	N/A	N/A	N/A
-----------------------	-----	-----	-----	-----

Approved Type(s): **Type X Gypsum**

Minimum: 4' x 8' x 5/8"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

Approved Type(s): **Celotherm, ConPerl, GAFTEMP Permalite, Fesco Board**

Minimum: 2' x 4' x 3/4"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

**Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.**



Base Sheet: One or more plies of GAFGLAS #75 fastened to the deck as described below:

Fastening : Fasten base sheet with metal plates and Dekfast #14, #15, Olympic #14, Rawl #14, or Roofgrip spaced 12" o.c. in a 4" side lap and 12" o.c. in two staggered rows in the center of the sheet

Ply Sheet: (Optional or as specified) One ply of FA-2T or APS-4T torch applied or one or more plies of GlasPly IV or GlasPly Premier adhered with a full mopping of asphalt at an application rate of 25 lb./sq. ± 15%.

Membrane: One ply of APM-4.5T, APM-4T, MDA, APS-4T torch applied.

Surfacing: (Optional) Install one of the following as required for fire rating:  
1. APOC 212, Henry 520, Karnak 97 or 97AF, MAC 200, Monsey ProGrade Aluminum or Grundy al MB applied at a rate of 1 ½ gal./sq.  
2. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved asphalt at an application rate of 60 lb./sq..

Maximum Design Pressure: -45 psf (See General Limitation #9)



**Membrane Type:** SBS

**Deck Type II:** Wood, Insulated, New Construction or Reroof

**Deck Description:** 1<sup>9</sup>/<sub>32</sub>" or greater plywood or wood plank

**System Type D:** All layers of insulation and base sheet simultaneously fastened.

**All General and System Limitations apply.**

<u>Insulation Layer</u>	<u>Fastener Type</u>	<u>Fastening Detail No.</u>	<u>Fasteners Per Board</u>	<u>Fastener Density</u>
-------------------------	----------------------	-----------------------------	----------------------------	-------------------------

One or more layers of any of the following insulations:

Approved Type(s): **ACFoam II, Armor R Plus, Dow Iso, GAFTEMP Isotherm RA, Kop-R(WII), UltraGard, USIso**

Minimum: 4' x 4' x 1.4"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

Approved Type(s): **ACFoam Composite, Kop-R(WC), Fesco Foam, USIso/Perlite Composite**

Minimum: 4' x 4' x 1.5"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

Approved Type(s): **Standard or Wide Flute Fiberglass Roof Insulation, Standard or Wide Flute Fiber Glass Roof Insulation**

Minimum: 4' x 4' x 15/16"	N/A	N/A	N/A	N/A
---------------------------	-----	-----	-----	-----

Approved Type(s): **Celotherm, ConPerl, GAFTEMP Permalite, Fesco Board**

Minimum: 2' x 4' x 1"	N/A	N/A	N/A	N/A
-----------------------	-----	-----	-----	-----

Approved Type(s): **Armor Board Regular, Esgard, Celotex Fiberboard, GAFTEMP Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber**

Minimum: 4' x 4' x 1"	N/A	N/A	N/A	N/A
-----------------------	-----	-----	-----	-----

Approved Type(s): **Type X Gypsum**

Minimum: 4' x 8' x 5/8"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

Approved Type(s): **Celotherm, ConPerl, GAFTEMP Permalite, Fesco Board**

Minimum: 2' x 4' x 3/4"	N/A	N/A	N/A	N/A
-------------------------	-----	-----	-----	-----

**Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.**

Base Sheet: One or more plies of GAFGLAS #75 fastened to the deck as described below:



- Fastening :** Fasten base sheet with metal plates and Dekfast #14, #15, Olympic #14, Rawl #14, or Roofgrip spaced 12" o.c. in a 4" side lap and 12" o.c. in two staggered rows in the center of the sheet.
- Ply Sheet:** (Optional or as specified) One ply of FS-2H or SPS-3H or one or more plies of GlasPly IV or GlasPly Premier adhered with a full mopping of approved asphalt at an application rate of 25 lbs./sq.  $\pm$  15%.
- Membrane:** One ply of SPM-4.5T torch welded, or one ply of MDS, SPM-3.5H, SFM-3.5H, SFM-3.5H-FR or SPS-3H adhered with a full mopping of approved asphalt at an application rate of 25 lb./sq.  $\pm$  15%.
- Surfacing:** (Optional) Install one of the following as required for fire rating:
1. Karnak 97 or 97AF, MAC 200, MAC 300, Monsey ProGrade Aluminum or Grundy al MB applied at a rate of 1 ½ gal./sq.
  2. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved asphalt at an application rate of 60 lb./sq..
- Maximum Design Pressure:** -45 psf (See general Limitation #9)



**Membrane Type:** APP  
**Deck Type 1:** Wood, Non-insulated  
**Deck Description:** 1<sup>9</sup>/<sub>32</sub>" or greater plywood or wood plank decks  
**System Type E:** Base sheet mechanically fastened.

**All General and System Limitations apply.**

**Barrier:** (Optional) Type X gypsum or min. 1/4" thick Dens Deck, loose laid

**Base Sheet:** One or more plies of GAFGLAS #75 fastened to the deck as described below:

**Fastening :** Fasten base sheet with approved roofing nails and tin caps spaced 9" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.

**Ply Sheet:** (Optional or as specified) One ply of FA-2T or APS-4T torch applied or one or more plies of GlasPly IV, GlasPly Premier, PermaPly 28, Glas Base, VaporBar or GAFGLAS #75 adhered with a full mopping of asphalt at an application rate of 25 lb./sq. ± 15%. **(Note: Minimum two plies of fiberglass ply sheet required when no barrier installed.)**

**Membrane:** One ply of APM-4.5T, APM-4T, MDA, APS-4T torch applied.

**Surfacing:** (Optional) Install one of the following as required for fire rating:

1. APOC 212, Henry 520, Karnak 97 or 97AF, MAC 200, Monsey ProGrade Aluminum or Grundy al MB applied at a rate of 1 1/2 gal./sq.
2. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved asphalt at an application rate of 60 lb./sq..

**Maximum Design Pressure:** -45 psf (See General Limitation #9)



**Membrane Type:** SBS  
**Deck Type 1:** Wood, Non-insulated  
**Deck Description:** 1 9/32" or greater plywood or wood plank decks  
**System Type E:** Base sheet mechanically fastened.

**All General and System Limitations apply.**

**Barrier:** (Optional) Type X gypsum, loose laid

**Base Sheet:** One or more plies of GAFGLAS #75 fastened to the deck as described below:  
Fasten base sheet with approved roofing nails and tin caps spaced 9" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.

**Ply Sheet:** (Optional or as specified) One ply of FS-2H or SPS-3H or one or more plies of GlasPly IV, GlasPly Premier, PermaPly No. 28, Glas Base, VaporBar, or GAFGLAS #75 adhered with a full mopping of approved asphalt at an application rate of 25 lbs./sq. ± 15%. *(Note: Minimum two plies of fiberglass ply sheet required when no barrier installed.)*

**Membrane:** One ply of SPM-4.5T torch welded, or one ply of MDS, SPM-3.5H, SFM-3.5H, SFM-3.5H-FR or SPS-3H adhered with a full mopping of approved asphalt at an application rate of 25 lb./sq. ± 15%.

**Surfacing:** (Optional) Install one of the following as required for fire rating:  
1. Karnak 97, MAC 200, MAC 300, or Grundy al MB applied at a rate of 1 ½ gal./sq.  
2. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved asphalt at an application rate of 60 lb./sq..

**Maximum Design Pressure:** -45 psf (See General Limitation #9)



**Membrane Type:** APP  
**Deck Type 1:** Wood, Non-insulated  
**Deck Description:** 19/32" or greater plywood or wood plank decks  
**System Type E:** Base sheet mechanically fastened.

**All General and System Limitations apply.**

**Deck Attachment:** In accordance with applicable Building Code, but in no case shall it be less than # 8 x 1½" wood screws. In reroofing, where the deck is less than 19/32" thick (Minimum 15/32"). The above attachment method must be in addition to the existing attachment.

**Barrier:** (Optional) Type X gypsum or min. ¼" thick Dens Deck, loose laid

**Base Sheet:** One or more plies of GAFGLAS #75 fastened to the deck as described below:

**Fastening:** Fasten base sheet sheet using CF Dekfasts Screws (#12) and Dekfastr Plates spaced 9" o.c. in a 4" side lap and 9" o.c. in two staggered rows in the center of the sheet.

**Ply Sheet:** (Optional or as specified) One ply of FA-2T or APS-4T torch applied or one or more plies of GlasPly IV, GlasPly Premier, PermaPly 28, Glas Base, VaporBar or GAFGLAS #75 adhered with a full mopping of asphalt at an application rate of 25 lb./sq. ± 15%. **(Note: Minimum two plies of fiberglass ply sheet required when no barrier installed.)**

**Membrane:** One ply of APM-4.5T, APM-4T, MDA, APS-4T torch applied.

**Surfacing:** (Optional) Install one of the following as required for fire rating:  
1. APOC 212, Henry 520, Karnak 97 or 97AF, MAC 200, Monsey ProGrade Aluminum or Grundy al MB applied at a rate of 1 ½ gal./sq.  
2. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved asphalt at an application rate of 60 lb./sq..

**Maximum Design Pressure:** -60 psf (See General Limitation #7)



**Membrane Type:** SBS  
**Deck Type 1:** Wood, Non-insulated  
**Deck Description:** 19/32" or greater plywood or wood plank decks  
**System Type E:** Base sheet mechanically fastened.

**All General and System Limitations apply.**

**Deck Attachment:** In accordance with applicable Building Code, but in no case shall it be less than # 8 x 1½" wood screws. In reroofing, where the deck is less than 19/32" thick (Minimum 15/32"). The above attachment method must be in addition to the existing attachment.

**Barrier:** (Optional) Type X gypsum, loose laid

**Base Sheet:** One or more plies of GAFGLAS #75 fastened to the deck as described below:

**Fastening:** Fasten base sheet sheet using CF Dekfasts Screws (#12) and Dekfastr Plates spaced 9" o.c. in a 4" side lap and 9" o.c. in two staggered rows in the center of the sheet.

**Ply Sheet:** (Optional or as specified) One ply of FS-2H or SPS-3H or one or more plies of GlasPly IV, GlasPly Premier, PermaPly No. 28, Glas Base, VaporBar, or GAFGLAS #75 adhered with a full mopping of approved asphalt at an application rate of 25 lbs./sq. ± 15%. *(Note: Minimum two plies of fiberglass ply sheet required when no barrier installed.)*

**Membrane:** One ply of SPM-4.5T torch welded, or one ply of MDS, SPM-3.5H, SFM-3.5H, SFM-3.5H-FR or SPS-3H adhered with a full mopping of approved asphalt at an application rate of 25 lb./sq. ± 15%.

**Surfacing:** (Optional) Install one of the following as required for fire rating:  
1. Karnak 97, MAC 200, MAC 300, or Grundy al MB applied at a rate of 1 ½ gal./sq.  
2. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved asphalt at an application rate of 60 lb./sq..

**Maximum Design Pressure:** -60 psf (See General Limitation #7)



**Deck Type 1:** Wood  
**Deck Description:** 1<sup>9</sup>/<sub>32</sub>" or greater plywood or wood plank  
**System Type G:** System applied as tile underlayment.

**All General and System Limitations apply.**

**Base Sheet:** One ply of ASTM D 226 type II, ASTM D 2626, FA-2T or UDL-40 mechanically fastened with a minimum side lap of 4" and a minimum end lap of 6". Base sheet may be applied at a right angle (90<sup>0</sup>) to the slope of the deck with approved corrosion resistant annular ring shank nails and tin caps at a fastener spacing of 6" o.c. at the 4" side lap, and with staggered rows spaced 12" o.c.

**Membrane:** One or more plies of FA-2T torch applied to a mechanically attached base sheet, in accordance with manufacturers written specifications. Membrane shall be backnailed to deck with approved annular ring shank nails and tin caps at a maximum fastener spacing of 6" o.c. No nails or tin caps shall be exposed.

\* Membrane may also be installed parallel to the slope of the roof (i.e. strapping). If membrane is strapped, then anchor sheet and ply sheet must also be strapped.

**Maximum Design Pressure:** Refer to tile manufacturer's NOA.

**Maximum Slope:** Must Comply with Roofing Application Standard RAS 118, RAS 119, RAS 120 and applicable Building Code.



## WOOD DECK SYSTEM LIMITATIONS:

1. A red rosin sheet shall be installed on all wood plank decks to eliminate asphalt seepage and bonding of the base sheet to wood plank decks. Red rosin sheet may also be installed on plywood decks as an option.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**

END OF THE ACCEPTANCE



NOA No 02-1018.03  
Expiration Date: 03/27/08  
Approval Date: 03/27/03  
Page 33 of 33