



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Soprema, Inc.
310 Quadral Drive
Wadsworth, OH 44281**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The BCCO (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BCCO reserves the right to revoke this acceptance, if it is determined by BCCO that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Soprema Waterproofing System

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 14.
The submitted documentation was reviewed by Frank Zuloaga, RRC



**NOA No.: 03-0210.01
Expiration Date: 09/18/08
Approval Date: 09/18/03
Page 1 of 14**

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Waterproofing
Material:	Modified Bitumen SBS
Deck Type:	Steel and Concrete
Maximum Design Pressure	-457.5 psf
Fire Classification:	See General Limitation #1

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Elastophene Flam	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced SBS modified bitumen membrane covered on both sides with a thermofusible plastic film. Applied by torch.
Elastophene FR GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced SBS modified bitumen membrane surfaced with colored granules. Top ply membrane formulated for Class 'A'. Applied in hot asphalt or cold adhesive.
Elastophene Flam FR GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane surfaced with colored granules. Applied by torch.
Sopralene Flam 180, 250, or 350	39" x 32' (1 sq.) 39" x 26' (¾ sq.)	ASTM D 6164	Non-woven polyester reinforced SBS modified bitumen membrane, both sides covered with thermofusible plastic film, primarily used as a base ply. Applied by torch.
Sopralene 180, 250, 350, GR or FR	39" x 26' (¾ sq.)	ASTM D 6164	Non-woven polyester reinforced SBS modified bitumen membrane surfaced with colored granules. Applied in hot asphalt or cold applied adhesive.
Sopralene Flam 180, 250 or 350 GR or FR GR	39" x 26' (¾ sq.)	ASTM D 6164	Non-woven polyester reinforced SBS modified bitumen membrane surfaced with colored granules. Applied by torch.
Sopralene Flam Antirock	39" x 26' (¾ sq.)	ASTM D 6164	Non-woven polyester reinforced SBS modified bitumen membrane surfaced with colored granules. Applied in hot asphalt or cold applied adhesive.
High Velocity Insulation Adhesive II		Proprietary	One part elastomeric urethane foam adhesive.
Elastocol 500 and 600		ASTM D 41	Asphalt primers.
SopraDrain	Various		Drainage mat
SopraFiltre	Various		Filter mat



APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
ACFoam II	Polyisocyanurate foam insulation	Atlas Energy Products
ACFoam Composite	Composite polyisocyanurate insulation board	Atlas Energy Products
Foam Insulation	Extruded Polystyrene Insulation (XPS). Minimum 60 psi	Dow Chemical USA
Gypsum	Gypsum board	generic
High Density Wood Fiberboard	Wood fiber insulation board	generic
Perlite Insulation	Perlite insulation board	generic
Dens Deck	Water resistant gypsum board	G-P Gypsum Corp.
ENRGY-2	Polyisocyanurate foam insulation	Johns Manville
ENRGY-2 Plus, Composite, Fesco Foam	Composite Insulation board	Johns Manville

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	#12 & #14 Soprema Fasteners	Fasteners for membrane or insulation attachment to wood, steel or concrete decks.		Soprema, Inc.
2.	Soprema Plates	Metal or plastic stress plates for use with Soprema Fasteners.	3" diameter	Soprema, Inc.
3.	#12 & #14 Dekfast Fastener	Insulation fastener		Construction Fasteners, Inc.
4.	Omega Fastener	Stainless steel insulation fastener		Construction Fasteners, Inc.
5.	Dekfast Hex Plate	Galvalume AZ50 steel plate	2 7/8" x 3 1/4"	Construction Fasteners, Inc.
6.	Dekfast Lock Plate	Polypropylene locking plate.	3" x 3 1/4"	Construction Fasteners, Inc.
7.	#12 Roofgrip Fasteners	Insulation fastener for wood and steel.		ITW Buildex Corp.
8.	AccuTrac Hextra Fasteners	Insulation fastener for wood and steel.		ITW Buildex Corp.



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
9.	Accutrak Plate	Galvalume square stress plate	3" square	ITW Buildex Corp.
10.	Flat Bottom Metal Plate	Galvalume stress plate.	3" round 3" square	ITW Buildex Corp.
11.	Olympic Fastener #12 & #14	Insulation fastener.		Olympic Mfg. Group, Inc.
12.	Olympic Standard	3" round galvalume AZ50 steel plate	3" round	Olympic Mfg. Group, Inc.
13.	Olympic Plastic	Polypropylene stress plate	3.25" round	Olympic Mfg. Group, Inc.
14.	Insul-Fixx Fastener	Insulation fastener for steel and wood decks		SFS Stadler, Inc.
15.	Isofast Fasteners	Insulation fastener for steel and wood decks		SFS Stadler, Inc.
16.	Extra Load Fasteners #15	Fasteners for membrane attachment to steel or concrete decks.		SFS Stadler, Inc.
17.	Insul-Fixx S Plate	3" round galvalume AZ50 steel plate	3" round	SFS Stadler, Inc.
18.	Insul-Fixx P Plate	Polyethylene stress plate	3" round	SFS Stadler, Inc.
19.	ES-I Fastening Systems	Insulation fastening assembly with plate.	3" round	SFS Stadler, Inc.
20.	Tru-Fast Fastener	Insulation fastener for wood and steel decks		The Tru-Fast Corp.
21.	Tru-Fast HD	Insulation fastener for wood and steel decks		The Tru-Fast Corp.
22.	Tru-Fast MP-3	3" round galvalume AZ50 steel plate	3" round	The Tru-Fast Corp.
23.	Tru-Fast Plastic	Polypropylene plate	3" round	The Tru-Fast Corp.



TRADE NAMES OF PRODUCTS MANUFACTURED BY OTHERS

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>	<u>Manufacturer</u>
Concrete Pavers	24" x 24" x 1.5" min. wt. 125 lbs/ft ³	ASTM C902	4000 psi min. compressive strength, 5% water absorption max.	Generic
Ceramic Tiles	12" x 12" x ½"	ASTM C902	Ceramic plaza deck walking tiles, 5% water absorption max.	Generic
Thin set Mortar	15 lb. Box, 25 & 50 Bags	ANSI A118.1 & A118.4	A bonding agent for tiles.	Generic
Portland Cement	94 lb. Bags	ASTM C 220	Type I Portland Cement.	Generic

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corp.	J.I. 1W8A1.AM	Wind Uplift Classification	07.15.93
	J.I. 1Z3A6.AM	Wind Uplift Classification	04.27.95
	J.I. 2D0A0.AM	Wind Uplift Classification	08.15.97
	FM Approval Guide	Uplift Classifications	Published Annually
Underwriters Laboratories, Inc.	UL Roofing Materials and Systems Directory	File No. R11436	Published Annually
		Fire Classification	Annually
Dynatech Engineering Corp.	10.94.27	Wind Uplift	10.27.94
	2491-04.95	Wind Uplift	01.04.95
Exterior Research & Design, LLC	2003.02.97-1	Wind Uplift	02.15.97
	2003-2.04.97-1	Wind Uplift	04.15.97
	2002.07.97-1	Wind Uplift	08.15.97
	2755.09.02	Wind Uplift	10.19.02
IRT of S. Florida, Inc.	01-002	TAS 114	01.21.01
ITS / Warnock Hersey		ASTM D 5147 Physical Property Testing	05.27.93



APPROVED APPLICATIONS:

Substrate Type 2I: Steel, Insulated

Substrate Description: Terrace/Plaza Deck, Planter, Traffic

System Type: Waterproofing System for Terrace/Plaza Decks, Planters or Traffic Areas

All General and System Limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Toprox Minimum 1" thick	1 or 11	1:2.4 ft²
AC Foam II Minimum 1.5" thick	1, 3,4, 7, 8, 11, 14, 15, 19 or 20	1:2 ft²
ACFoam Composite, ENRGY-2 Composite, ENRGY-2 Plus Minimum 1.5" thick	1, 3,4, 7, 8, 11, 14, 15, 19 or 20	1:4 ft²
ENRGY-2, PSI-25 Minimum 1.4" thick	1, 3,4, 7, 8, 11, 14, 15, 19 or 20	1:2.67 ft²
AC Foam II, ENRGY-2, PSI-25 Minimum 2" thick	1, 3,4, 7, 8, 11, 14, 15, 19 or 20	1:4 ft²
ENRGY-2, PSI-25 Minimum 1.4" thick	1, 3,4, 7, 8, 11, 14, 15, 19 or 20	1:2.67 ft²
Dens-Deck Minimum ¼" thick	1, 3, 8 or 14	1:4 ft²
Fireguard, type X gypsum Minimum 5/8" thick	1, 3, 8 or 14	1:4 ft²
GAFTEMP Permalite, Fesco Board Minimum ¾" thick	1, 3,4, 7, 8, 11, 14, 15, 19 or 20	1:2 ft²
Esgard, High Density Fiberboard, GAFTEMP Fiberboard, Huebert Fiberboard Minimum 1" thick	1, 3,4, 7, 8, 11, 14, 15, 19 or 20	1:4 ft²



Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

- Primer: Elastocol 500 or ASTM D 41 primer applied to top of composite board or top of coverboard in insulation assembly.
- Base Sheet: Sopralene Flam 180 or 250, heat welded.
- Top Sheet: Sopralene Flam 250, Sopralene Flam Antirock, Sopralene Flam 180 GR heat welded.
- Integrity Test: Required, and shall be performed in accordance with ASTM D 5957. Water maybe maintained for a period longer than 24 hours if required.
- Inspection: Contractor and a representative of the membrane manufacturer shall inspect the waterproofing assembly and notify the contractor of any defects. Inspection must take place prior to installation of any overlay insulation, protection pads, drainage boards and traffic surfacing. All defects observed shall be corrected.
- Drain Board: SopraDrain (for planters only)
- Filter Layer: SopraFiltre (for planters only)
- Surfacing: For Terrace/Plaza Deck: Mortar set tile or paver system
For Planters: Soil or Sand
For Traffic Areas: Mortar set exterior traffic grade surface tile.
- Maximum Design Pressure: -52.5 psf (See General Limitation #9)



Substrate Type 2: Steel, Insulated
Substrate Description: Terrace/Plaza Deck, Planter, Traffic
System Type: Waterproofing System for Terrace/Plaza Decks, Planters or Traffic Areas

All General and System Limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Dens Deck Minimum ¼" thick	1, 3, 11 or 14	1:4 ft²
Fireguard, Fiberbond Minimum 5/8" thick	1, 3, 11 or 14	1:4 ft²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Intermediate Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Dow Chemical ROOFMATE or PLAZAMATE Minimum 1.5 thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Perlite Minimum ¾" thick	N/A	N/A

Note: Intermediate and top layer of insulation shall be adhered with approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft², allow asphalt to cool to 225°-250°F before placement of insulation. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Primer: Elastocol 500 or ASTM D 41 primer applied to top of composite board or top of coverboard in insulation assembly.

Base Sheet: Sopralene Flam 180 or 250, heat welded.

Top Sheet: Sopralene Flam 250, Sopralene Flam Antirock, Sopralene Flam 180 GR heat welded.

Integrity Test: Required, and shall be performed in accordance with ASTM D 5957. Water maybe maintained for a period longer than 24 hours if required.

Inspection: Contractor and a representative of the membrane manufacturer shall inspect the waterproofing assembly and notify the contractor of any defects. Inspection must take place prior to installation of any overlay insulation, protection pads, drainage boards and traffic surfacing. All defects observed shall be corrected.

Drain Board: SopraDrain (for planters only)

Filter Layer: SopraFiltre (for planters only)



Surfacing: For Terrace/Plaza Deck: Mortar set tile or paver system
For Planters: Soil or Sand
For Traffic Areas: Mortar set exterior traffic grade surface tile.

Maximum Design Pressure: -45 psf (See General Limitation #9)



Substrate Type 3I: Concrete Decks
Substrate Description: Min. 2500 psi.
System Type: Tile Finish over Membrane.

All General and System Limitations apply.

Substrate Preparation:

All surfaces must be dry, smooth, free of depressions, voids, and protrusions, and clean and free of any non-compatible curing compounds, foam release agents and other surface contaminants. Substrate shall be smooth, free of voids, spalled areas, laitance, honeycombs, and sharp protrusions.

Primer: Elastocol 500 or ASTM D 41 primer applied to deck at a minimum rate of 100-150 ft²/gal.

Base Sheet: One or more plies of Elastophene Flam, heat welded according to manufacturer's application instruction.

Top Sheet: Elastophene Flam GR, heat welded according to manufacturer's application instruction.

Integrity Test: Required, and shall be performed in accordance with ASTM D 5957. Water maybe maintained for a period longer than 24 hours if required.

Inspection: Contractor and a representative of the membrane manufacturer shall inspect the waterproofing assembly and notify the contractor of any defects. Inspection must take place prior to installation of any overlay insulation, protection pads, drainage boards and traffic surfacing. All defects observed shall be corrected.

Insulation: Min. 2" thick Dow Chemical STYROFOAM High Load 60 Insulation (Minimum 60 psi) adhered to membrane with High Velocity Insulation Adhesive II applied in 3/4" wide strips spaced 12" o.c. or hot asphalt is applied to the membrane at a rate of 20-40 lbs/100 ft² and allowed to cool to 225°-250°F before placement of extruded polystyrene boards.

Surfacing: Exterior grade ceramic plaza deck walking tiles (Maximum size of 12" x 12" and minimum 1/2" thick), tiles shall be embedded into dry-set Portland Cement applied with a 1/4" square notched trowel. Tiles should then be carefully embedded in the mortar bed and tapped in place to insure full solid bearing. Tile shall be installed in accordance with applicable Building Code.

Maximum Design Pressure: -277.5 psf (See General Limitation #9)



Substrate Type 3I: Non-Insulated, Concrete Decks

Substrate Description: Min. 2500 psi.

System Type: Tile Finish over Membrane.

All General and System Limitations apply.

Substrate Preparation:

All surfaces must be dry, smooth, free of depressions, voids, and protrusions, and clean and free of any non-compatible curing compounds, foam release agents and other surface contaminants. Substrate shall be smooth, free of voids, spalled areas, laitance, honeycombs, and sharp protrusions.

Primer: Elastocol 500 or ASTM D 41 primer applied to deck at a rate of 100-150 ft²/gal.

Base Sheet: One or more plies of Elastophene Flam or Sopralene Flam 180, 250 or 350, heat welded according to manufacturer's application instruction.

Top Sheet: Elastophene Flam GR, Sopralene Flam 180, 250 or 350 or Sopralene Antirock, heat welded according to manufacturer's application instruction.

Integrity Test: Required, and shall be performed in accordance with ASTM D 5957. Water maybe maintained for a period longer than 24 hours if required.

Inspection: Contractor and a representative of the membrane manufacturer shall inspect the waterproofing assembly and notify the contractor of any defects. Inspection must take place prior to installation of any overlay insulation, protection pads, drainage boards and traffic surfacing. All defects observed shall be corrected.

Surfacing: Exterior grade ceramic plaza deck walking tiles (Maximum size of 12" x 12" and minimum 1/2" thick), tiles shall be embedded into dry-set Portland Cement applied with a 1/4" square notched trowel. Tiles should then be carefully embedded in the mortar bed and tapped in place to insure full solid bearing. Tile shall be installed in accordance with applicable Building Code.

Maximum Design Pressure: -457.5 psf (See General Limitation #9)



NOA No.: 03-0210.01
Expiration Date: 09/18/08
Approval Date: 09/18/03
Page 11 of 14

Substrate Type 3I: Insulated, Concrete Decks
Substrate Description: Min. 2500 psi concrete or concrete plank.
System Type: Concrete Paver Finish over Membrane.

All General and System Limitations apply.

Substrate Preparation:

All surfaces must be dry, smooth, free of depressions, voids, and protrusions, and clean and free of any non-compatible curing compounds, foam release agents and other surface contaminants. Substrate shall be smooth, free of voids, spalled areas, laitance, honeycombs, and sharp protrusions.

Primer: Elastocol 500 or ASTM D 41 primer applied to deck at a rate of 100-150 ft²/gal.

Base Sheet: One or more plies of Sopralene Flam 180 or 250, heat welded according to manufacturer's application instruction.

Top Sheet: Sopralene Flam 180, 250, 350 GR Sopralene Flam 180, 250, 350 FR GR, heat welded according to manufacturer's application instruction.

Integrity Test: Required, and shall be performed in accordance with ASTM D 5957. Water maybe maintained for a period longer than 24 hours if required.

Inspection: Contractor and a representative of the membrane manufacturer shall inspect the waterproofing assembly and notify the contractor of any defects. Inspection must take place prior to installation of any overlay insulation, protection pads, drainage boards and traffic surfacing. All defects observed shall be corrected.

Insulation: (Optional) Min. 1.5" thick Dow Chemical STYROFOAM High Load 60 Insulation (Min. 60 psi) adhered to membrane with High Velocity Insulation Adhesive II applied in ¾" wide strips spaced 12" o.c. or hot asphalt is applied to the membrane at a rate of 20-40 lbs/100 ft² and allowed to cool to 225°-250°F before placement of extruded polystyrene boards.

Surfacing: Concrete pavers (24" x 24" x 1.5" thick), 4000 psi minimum shall be embedded into dry-set Portland Cement applied with a ¼" square notched trowel. Pavers should then be carefully embedded in the mortar bed and tapped in place to insure full solid bearing. Tile shall be installed in accordance with applicable Building Code.

Maximum Design Pressure:

-340 psf (See General Limitation #9)



NOA No.: 03-0210.01
Expiration Date: 09/18/08
Approval Date: 09/18/03
Page 12 of 14

Substrate Type 3: Non-Insulated, Concrete Decks
Substrate Description: Min. 2500 psi, dual slab construction (roof plaza and parking decks)
System Type: Membranes applied directly to substrate.

All General and System Limitations apply.

Substrate Preparation:

All surfaces must be dry, smooth, free of depressions, voids, and protrusions, and clean and free of any non-compatible curing compounds, foam release agents and other surface contaminants. Substrate shall be smooth, free of voids, spalled areas, laitance, honeycombs, and sharp protrusions.

Primer: Elastocol 500, 600c or ASTM D 41 primer applied to deck at a rate of 100-150 ft²/gal.

Base Sheet: One or more plies of Sopralene Flam 180 or 250, heat welded according to manufacturer's application instruction.

Top Sheet: Sopralene Flam 180, 250, 350 GR, Sopralene Flam 180, 250, 350 FR GR or Sopralene Antirock, heat welded according to manufacturer's application instruction.

Integrity Test: Required, and shall be performed in accordance with ASTM D 5957. Water maybe maintained for a period longer than 24 hours if required.

Inspection: Contractor and a representative of the membrane manufacturer shall inspect the waterproofing assembly and notify the contractor of any defects. Inspection must take place prior to installation of any overlay insulation, protection pads, drainage boards and traffic surfacing. All defects observed shall be corrected.

Insulation: (Optional) Min. 1.5" thick Dow Chemical STYROFOAM High Load 60 Insulation (Min. 60 psi) adhered to membrane with High Velocity Insulation Adhesive II applied in 3/4" wide strips spaced 12" o.c. or hot asphalt is applied to the membrane at a rate of 20-40 lbs/100 ft² and allowed to cool to 225°-250°F before placement of extruded polystyrene boards.

Protection Board and/or Drainage Layer:

Install drainage board over top ply membrane

Surfacing: Structural Concrete Slab, minimum 2500 psi, in compliance with applicable Building Code.

Maximum Design

Pressure: N/A (Topping concrete slab shall comply with applicable Building Code requirement.)



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Required integrity flood testing shall be provided to the Building Official for review at time of final inspection.
3. Contractor shall be approved by Soprema, Inc.
4. Flashings shall be installed according to the manufacturer's published standard details and shall be submitted to the Building Official for review.
5. Contractor shall submit to the Building Official for review the system specifications and details. Submission of these documents, as well as the proper application and installation of all materials shall be the sole responsibility of the contractor.
6. Systems shall not be installed over lightweight insulating concrete.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and the wind load requirements of applicable Building Code.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 03-0210.01
Expiration Date: 09/18/08
Approval Date: 09/18/03
Page 14 of 14