



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Specialty Glass Products, Inc.
5815 Brookhollow Parkway, Suite D.
Norcross, GA 31525**

SCOPE: This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami Dade-County Product Control Division (In Miami-Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code. This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone.

DESCRIPTION: Specialty Lite Frame.

APPROVAL DOCUMENT: Drawing No. DWG-MA-WL-0031-60, titled "Polypropylene Glass Frame" sheet 1 of 1, dated 02/17/03, with last revision on 04/14/04, prepared by Specialty Building Products, Inc. signed and sealed by K. L. Balthazor, PE bearing the Miami Dade County Product Control Approval stamp with the Notice of Acceptance number and approval date by the Miami Dade County Product Control Division.

MISSILE IMPACT RATING: None.

LABELING: Each Laminated assembly shall bear a permanent label with the manufacturer's name or logo, city, state and the following statement "Miami-Dade County Product Control Approved" or "MDCA-Specialty".

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of this page, evidence page as well as the approval document mentioned above. The submitted documentation was reviewed by **Candido E. Font PE.**

(Handwritten signature and date)
5/27/04



**NOA No: 03-0303.07
Expiration Date: May 27, 2009
Approval Date: May 27, 2004
Page 1**

NOTICE OF ACCEPTANCE: EVIDENCE PAGE

A DRAWING:

1. Drawing No. DWG-MA-WL-0031-60, sheet 1 of 1, prepared by Specialty Building Products, Inc issued on 02/17/03, with last revision on 04/14/04, signed and sealed by K. L. Balthazor, PE.

B TEST REPORTS:

Laboratory Report	Test	Date	Signature
1. ETC 02-797-12517.2	ASTM D 1929	01/09/03	J. L. Doldan, PE
2. ETC 02-797-12517.2	ASTM D 635	01/09/03	J. L. Doldan, PE
3. ETC 02-797-12517.2	ASTM E 2843	01/09/03	J. L. Doldan, PE.
4. ETC 02-797-12517.2	ASTM G155 & D638	01/09/03	J. L. Doldan, PE

C CALCULATIONS:

N/A

D MATERIAL CERTIFICATION:

N/A

E STATEMENTS:

1. Letter of Code Compliance and No-Financial Interest issued by K. L. Balthazor PE, on 10/22/03, signed and sealed by K. L. Balthazor, PE.
2. Letter of No-Financial Interest issued by Specialty Building Products, Inc. on 02/17/03 signed by S. Stecker and Notarized by M. N. Elrod.

F QUALITY ASSURANCE

1. Building Code Compliance Office.




Candido F. Font PE.
Sr. Product Control Examiner
NOA No 03-0303.07
Expiration Date: May 27, 2009
Approval Date: May 27, 2004



SPECIALTY BUILDING PRODUCTS, INC.

GENERAL NOTES

1. POLYPROPYLENE LITE FRAMES ARE DESIGNED TO MEET THE REQUIRMENTS OF THE 2001 FLORIDA BUILDING CODE.
2. THIS IS A COMPONENT APPROVAL AND DOES NOT INCLUDE AN EVALUATION OF THE STRUCTURAL PERFORMANCE OF THIS COMPONENT.
3. SYSTEMS INCORPORATING SPECIALTY LITE FRAMES SHALL APPLY FOR AN NOA AND SHALL SUBMIT TEST REPORTS AND OTHER REQUIRED DOCUMENTS SHOWING THAT THE SYSTEM USING THIS COMPONENT WILL RESIST THE LOADS ACCORDING TO CHAPTER 16 OF THE FLORIDA BUILDING CODE.



varies* → ←

SPECIALTY/BAYLITE
GLASS LITE FRAME
POLYPROPYLENE

* 1/8", 1/2", 3/4", OR 1"

TEST DESCRIPTION	TEST DESIGNATION	TEST RESULT
SELF IGNITION TEMP	ASTM D1929	740 °F
RATE OF BURNING	ASTM D635	0.77 IN/MIN
SMOKE DENSITY	ASTM D2843	13.4%
TENSILE STRESS*	ASTM D638	7.5%

* COMPARATIVE TENSILE STRESS AFTER WEATHERING PER SECTION 2605.2 OF THE FLORIDA BUILDING CODE
BEFORE WEATHERING 3622.9 lbs.
AFTER WEATHERING 3351.9 lbs.

K.L. Balth
4-14-04

KURT L. BALTHAZOR, PE
STATE OF FLORIDA LICENSE 56533

Approved as complying with the Florida Building Code
Date 5/27/04
NOA# 03-0303-01
Miami Dade Product Control
Division
By

DATE: 2/17/03
SCALE: N.T.S.
DWG. BY: SWS
CHK. BY: KB
DRAWING NO.:
DWG-MA-WL-0031-60
SHEET 1 OF 1

SPECIALTY BUILDING PRODUCTS, INC.
5815 BROOKHOLLOW PARKWAY
NORCROSS, GA 31525

PRODUCT: POLYPROPYLENE GLASS FRAME
PART OR ASSEMBLY:

NO.	DATE	BY	REVISIONS
C	4/14/04	SWS	ADDED TENSILE STRESS
B	1/21/04	SWS	UPDATED WEATHERING DATA
A	8/20/03	SWS	ADDED WEATHERING NOTES