



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

**Birdview Skylights.  
201 Longhorn Rd.  
Fort Worth, TX 76179**

**Scope:** This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Aluminum Framed Polycarbonate Domed Skylight.**

**APPROVAL DOCUMENT:** Drawing No. EB696, model "6SFD-DADE ", sheets No 1 of 1, prepared by Birdview Skylights dated 07/26/00 with no revisions bearing the Miami-Dade County Product Control Renewal stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Division.

**MISSILE IMPACT RATING: Large & Small Missile Impact**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein and the dome shall be properly marked by GE Plastics.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA # 00-0524.02 it consists of this page 1 & approval document mentioned above  
The submitted documentation was reviewed by **Candido F. Font, P.E.**

*(Handwritten signature and date)*  
06/05/03



**NOA No 03-0303.11  
Expiration Date: July 02, 2008  
Approval Date: June 05, 2003  
Page 1**

**Birdview Skylights.**

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

(For File ONLY. Not part of NOA)

**A. DRAWINGS**

1. Drawing No. EB696, sheets 1 & 1, model "6SFD-DADE", prepared by Birdview Skylights, dated 07/26/00, with no revisions, signed and sealed by V. N. Tolat, P.E.

**B. TESTS**

1. Test report on Large Missile Impact Test per PA 201, Cyclic Load Test per PA 203 and Uniform Static air Pressure Test per PA 202, on "Series 6SFD-DADE Self Flashing Aluminum/Polycarbonate Skylight", prepared by Miami Testing Laboratory, report No. K-49362 issued on 09/10/96, signed and sealed by D. G. Ober, P.E.

**C. CALCULATIONS**

1. Anchor Calculation, sheets 2 through 5, dated 08/21/96 and signed by D. A. Terwilleger, PE.

**D. MATERIAL CERTIFICATIONS**

1. Notice of Acceptance No. 00-0718.02 issued to General Electric Company on 09/08/2000, expiring on 07/02/2003.
2. Extrusion drawings No. BVS-X10947-A & BVS 8554 by Tel Tower Extrusions, LTD for Birdview Skylights.


**E. STATEMENTS**

1. No change letter issued by Birdview Skylights, on 08/10/2000 and signed by E. Bird.
2. No change letter issued by Birdview Skylights on 02/11/03 and signed by G. E. Bird.



---

**Candido F. Font, P. E.**  
**Senior Product Control Examiner**  
**NOA No 03-0303.11**  
**Expiration Date: July 02, 2008**  
**Approval Date: June 05, 2003**



APPROVED MODELS & SIZES	
MODEL NUMBER	SIZE ROOF OPENING
6SFD1818	14 1/4" X 14 1/4"
6SFD1820	14 1/4" X 16 1/4"
6SFD1826	14 1/4" X 22 1/4"
6SFD1834	14 1/4" X 30 1/4"
6SFD1850	14 1/4" X 46 1/4"
6SFD2424	24" X 24"
6SFD2436	24" X 36"
6SFD2626	22 1/4" X 22 1/4"
6SFD2634	22 1/4" X 30 1/4"
6SFD2638	22 1/4" X 34 1/4"
6SFD2650	22 1/4" X 46 1/4"
6SFD3434	30 1/4" X 30 1/4"
6SFD3450	30 1/4" X 46 1/4"
6SFD3636	36" X 36"
6SFD5050	46 1/4" X 46 1/4"

**NOTE:**  
ALL ALUMINUM TO BE 6063-T5 ALLOY FULLY MITERED AND WELDED AT CORNERS

DADE COUNTY ACCEPTANCE NUMBER  
00-0524.02

**BIRDVIEW SKYLIGHTS**  
THE CLEAR CHOICE  
201 LONGHORN RD. FT. WORTH TX. 76179  
Ph. 817-439-9266 Fx. 817-232-8468

DRAWING# EB696 REV. 00 SHEET 1 OF 1  
DRAWN BY: E. BIRD DATE: 7 - 26 - 00  
MODEL: 6SFD-DADE SCALE: FULL

DESIGN PRESSURE RATING  
POSITIVE + 56 PSF & NEGATIVE - 67 PSF  
LARGE MISSILE IMPACT RESISTANT

**GENERAL NOTES:**  
1. ALL ROOFING DETAILS SHALL COMPLY WITH CHAPTER 34 OF THE S.F.B.C.  
2. 4" MINIMUM DISTANCE FROM ANGLE LIP TO ROOF SURFACE IS FOR SHINGLE OR BUR WITHOUT INSULATION. FOR INSULATION AND ROOF TILES, ADD THE TILE HEIGHT AND THE INSULATION THICKNESS TO THE 4" MINIMUM HEIGHT.

**PRODUCT RENEWED**  
as complying with the Florida Building Code  
Acceptance No. 03-0303.11  
Expiration Date 01/02/08  
By: [Signature]  
Miami Dade Product Control Division

APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE  
DATE September 07, 2000  
BY: [Signature]  
PRODUCT CONTROL DIVISION  
BUILDING CODE COMPLIANCE OFFICE  
ACCEPTANCE NO. 00-0524.02

VIPIN N. TOLAT, P.E.  
REGISTERED CIVIL ENGINEER  
FLORIDA REG. 12847

[Signature]  
8/7/00