



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**CertainTeed Corporation (PA)
1400 Union Meeting Road
Blue Bell, PA 19422**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: CertainTeed Conventional Built-Up-Roof System over Concrete Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 16.

The submitted documentation was reviewed by Frank Zuloaga, RRC



**NOA No.: 03-0319.05
Expiration Date: 05/19/08
Approval Date: 06/13/03
Page 1 of 16**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Built-Up Roofing
Material: Fiberglass
Deck Type: Concrete
Maximum Design Pressure -355 psf
Fire Classification: See General Limitation #1

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
All Weather/Empire Base Sheet	36" x 72'; Roll weight: 86 lbs. (2 squares)	ASTM D 2626 UL Type 15	Asphalt coated, organic base sheet.
Flintglas® Mineral Surfaced Cap Sheet	36" X 36'; Roll Weight: 78 lbs. (1 square)	ASTM D 3909	Asphalt impregnated and coated inorganic glass fiber surfaced with mineral granules used as the top ply in conventional built-up roof membranes.
Flintglas® Ply Sheet Type IV or VI	36" x 180'; Roll weight: 40/55 lbs. (5 squares)	ASTM D 2178 Type IV or VI UL Type G1	Fiberglass, asphalt impregnated ply sheet.
Flex-I-Glas or Flex-I-Glas FR Base Sheet	36" x 108'; Roll weight: 90 lbs. (3 squares)	ASTM D 5147	SBS Modified, fiberglass reinforced base sheet.
GlasBase™ Base Sheet	36" x 108'; Roll weight: 69 lbs. (3 squares)	ASTM D 4601 UL Type G2	Asphalt coated, fiberglass base sheet.
No. 15 Perforated Felt	36" x 144', Roll weight: 90 lbs. (4 square)	ASTM D 226	Organic asphalt saturated felt.
Yosemite® Mineral Surfaced Cap Sheet	36" x 36'; Roll weight: 90 lbs. (1 square)	ASTM D 249 UL Type 30	Mineral Surfaced organic cap and buffer sheet.

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
PYROX, White Line	Polyisocyanurate foam insulation	Apache Products Co.



NOA No.: 03-0319.05
Expiration Date: 05/19/08
Approval Date: 06/13/03
Page 2 of 16

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
ACFoam II	Polyisocyanurate foam insulation	Atlas Energy Products
High Density Wood Fiberboard	Wood fiber insulation board	generic
Perlite Insulation	Perlite insulation board	generic
ISO 95+	Polyisocyanurate foam insulation	Firestone
Dens Deck	Water resistant gypsum board	G-P Gypsum Corp.
ENRGY-2, PSI 25	Polyisocyanurate foam insulation	Johns Manville
ENRGY-2 PLUS	Polyisocyanurate foam / wood fiberboard composite insulation	Johns Manville
FiberGlass Roof Insulation	Glass fiber/Mineral fiber insulation	Johns Manville
ISORoc	Polyisocyanurate foam / rockwool composite insulation	Johns Manville
Paroc Cap Board	Rockwool insulation	Partek, Inc.
Multi-Max & FA	Polyisocyanurate roof insulation	RMax, Inc.

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Dekfast Fasteners #14 & #15	Insulation fastener for wood, steel and concrete decks		Construction Fasteners Inc.
2.	Dekspike Fasteners	Insulation fastener for concrete decks		Construction Fasteners Inc.
3.	Dekfast Hex Plate	Galvalume hex stress plate.	2 7/8" x 3 1/4"	Construction Fasteners Inc.
4.	Dekfast Lock Plate	Polypropylene locking plate.	3" x 3 1/4"	Construction Fasteners Inc.
5.	#14 Roofgrip Fasteners	Insulation fastener for concrete, steel or wood decks.		ITW Buildex Corp.
6.	Metal Plate	Galvalume stress plate.	3" round 3" square	ITW Buildex Corp.
7.	Gearlok Plastic Plate	Polypropylene round plate	3.2"	ITW Buildex Corp.
8.	CD-10	Insulation fastener for concrete decks.		Olympic Mfg. Group



NOA No.: 03-0319.05
Expiration Date: 05/19/08
Approval Date: 06/13/03
Page 3 of 16

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
9.	Fluted Nail (Con-Tite)	Insulation fastener		Olympic Mfg. Group
10.	Olympic Fastener #14	Insulation fastener		Olympic Mfg. Group
11.	Olympic Fastener ASAP	Pre-assembled Insulation fastener and plate		Olympic Mfg. Group
12.	Olympic Polypropylene	Polypropylene plastic plate	3.25" round	Olympic Mfg. Group
13.	Olympic G-2	Galvalume AZ55 steel plate	3.5" round	Olympic Mfg. Group
14.	Olympic Standard	Galvalume AZ50 steel plate	3" round	Olympic Mfg. Group
15.	Rawl Drive/Spike	Insulation fastener for concrete decks		Powers Fasteners, Inc.
16.	Rawl Plate	Galvalume AZ55 steel plate	3" round	Powers Fasteners, Inc.
17.	HD Insul-Fixx Fastener	Insulation fastener for use in steel and concrete decks		SFS Stadler
18.	Insul-Fixx S	Galvalume AZ55 stress plate	3" round	SFS Stadler
19.	Insul-Fixx P	Polyethylene stress plate	3" round	SFS Stadler
20.	Tru-Fast HD	Insulation fastener for concrete decks		The Tru-Fast Corp.
21.	Tru-Fast Plates	Galvalume AZ55 steel plate	3" round	The Tru-Fast Corp.
22.	Tru-Fast MP-3	Galvalume AZ50 steel plate	3.23" round	The Tru-Fast Corp.
23.	Tru-Fast Plates	Polyethylene plastic plate	3" round	The Tru-Fast Corp.

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Applied Research Laboratories	Physical Properties	28013	06/02/87
Factory Mutual Research Corp.	Insulation Fastening Requirements	FMRC 1996	01/01/96
Factory Mutual Research Corp.	FMRC 4470	J.I. #3Y8A1.AM	03/23/96
Underwriters Laboratories, Inc.	Fire Classification Compliance	R11656	07/13/87
United States Testing Company, Inc.	ASTM D 5147	97457-4	06/03/88
	ASTM D 5147	97-457-2R	12/02/87



NOA No.: 03-0319.05
Expiration Date: 05/19/08
Approval Date: 06/13/03
Page 4 of 16

APPROVED ASSEMBLIES

- Membrane Type:** BUR
- Deck Type 3I:** Concrete Decks, Insulated, New Construction
- Deck Description:** 2500 psi structural concrete or concrete plank
- System Type A-1:** Anchor sheet (optional), base sheet and/or insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations:

Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft ²
AC-Foam I, ENRGY 2, ENRGY 2 Plus, ISORoc, Multi-Max Minimum 1" thick	N/A	N/A
High Density Wood Fiberboard Minimum ½" thick	N/A	N/A
Paroc, Perlite Minimum ¾" thick	N/A	N/A
Fiberglas Minimum 15/16" thick	N/A	N/A
Dens Deck Minimum ¼" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

- Anchor Sheet:** (Optional) One ply of All Weather/Empire, Flex-I-Glas, Flex-I-Glas FR or GlasBase base sheet in a spot mopping of approved asphalt, 12" diameter circles, 24" o.c. at a rate of 12 lbs./sq.. (See General Limitation #4)
- Base Sheet:** (Optional) Install one ply of All Weather/Empire, Flex-I-Glas or GlasBase base sheet directly over the top layer of insulation. Adhere with any approved mopping asphalt at an application rate of 20-35 lbs./sq.
- Ply Sheet:** Two or more plies of of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) or #15 Asphalt Perforated Felt ply sheet adhered in a full mopping of approved asphalt at an application rate of 20-35 lbs./sq.
- Cap Sheet:** (Optional) One ply of FlintGlas Mineral Surface cap sheet adhered in a full mopping of approved asphalt at an application rate of 20-35 lbs./sq.



Surfacing:

(Required if no cap sheet is used) Install one of the following:

1. Flood coat of hot asphalt with an application rate of 60 lbs./sq. \pm 20%; plus gravel or slag with an application rate of 400 lbs./sq. & 300 lbs./sq., respectively.
2. A two part coating consisting of a base coat of Static Asphalt Fibered Emulsion at rate of 3 gal./sq. or Monoform compound; surfaced with 1 gal./sq. Sta-Kool non-fibered aluminum coating or fibered APOC No. 212.

Maximum Design

Pressure:

-87.5 psf (See General Limitations # 9)



Membrane Type: BUR
Deck Type 3I: Concrete Decks, Insulated, New Construction
Deck Description: 2500 psi structural concrete or concrete plank
System Type A-2: Insulation adhered to deck with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
AC-Foam I, ENRGY 2, ENRGY 2 Plus, ISORoc, Multi-Max Minimum 1" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
High Density Wood Fiberboard Minimum 3/4" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

- Base Sheet:** One or more plies of GS Glas Base, GS Flex-I Glas Base, Flex-I Glas FR Base, GS Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the composite insulation with approved mopping asphalt applied within the EVT range and at a rate of 20-35 lbs./sq.
- Ply Sheet:** One or more plies of GS Glas Base, GS Flex-I-Glas Base, Flex-I-Glas FR Base, GS PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-35 lbs./sq.
- Cap Sheet:** (Optional) One ply of FlintGlas Mineral Surface cap sheet adhered in a full mopping of approved asphalt at an application rate of 20-35 lbs./sq.
- Surfacing:** (Required if no cap sheet is used) Install one of the following:
1. Flood coat of hot asphalt with an application rate of 60 lbs./sq. ± 20%; plus gravel or slag with an application rate of 400 lbs./sq. & 300 lbs./sq., respectively.
 2. A two part coating consisting of a base coat of Static Asphalt Fibered Emulsion at rate of 3 gal./sq. or Monoform compound; surfaced with 1 gal./sq. Sta-Kool non-fibered aluminum coating or fibered APOC No. 212.

Maximum Design Pressure: -227.5 psf (See General Limitations #9)



NOA No.: 03-0319.05
Expiration Date: 05/19/08
Approval Date: 06/13/03
Page 7 of 16

Membrane Type: BUR
Deck Type 3I: Concrete Decks, Insulated, New Construction
Deck Description: 2500 psi structural concrete or concrete plank
System Type A-3: Insulation adhered to deck with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
AC-Foam I, ENRGY 2, ENRGY 2 Plus, ISORoc, Multi-Max Minimum 1" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
Dens Deck Minimum 1/4" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: One or more plies of GS Glas Base, GS Flex-I Glas Base, Flex-I Glas FR Base, GS Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the composite insulation with approved mopping asphalt applied within the EVT range and at a rate of 20-35 lbs./sq.

Ply Sheet: One or more plies of GS Glas Base, GS Flex-I-Glas Base, Flex-I-Glas FR Base, GS PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-35 lbs./sq.

Cap Sheet: (Optional) One ply of FlintGlas Mineral Surface cap sheet adhered in a full mopping of approved asphalt at an application rate of 20-35 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install one of the following:

1. Flood coat of hot asphalt with an application rate of 60 lbs./sq. ± 20%; plus gravel or slag with an application rate of 400 lbs./sq. & 300 lbs./sq., respectively.
2. A two part coating consisting of a base coat of Static Asphalt Fibered Emulsion at rate of 3 gal./sq. or Monoform compound; surfaced with 1 gal./sq. Sta-Kool non-fibered aluminum coating or fibered APOC No. 212.

Maximum Design Pressure: -240 psf (See General Limitations #9)



NOA No.: 03-0319.05
Expiration Date: 05/19/08
Approval Date: 06/13/03
Page 8 of 16

Membrane Type: BUR
Deck Type 3I: Concrete Decks, Insulated, New Construction
Deck Description: 2500 psi structural concrete or concrete plank
System Type A-4: Insulation adhered to deck with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations:

Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
ENRGY 2, ENRGY 2 Composite Minimum 1.5" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

- Base Sheet:** One or more plies of All Weather/Empire, Flex-I-Glas or GlasBase base sheet adhered to the fiberglass insulation with approved mopping asphalt applied within the EVT range and at a rate of 20-35 lbs./sq.
- Ply Sheet:** Two or more plies of Flintglas Ply Sheet (Type IV), Premium Ply Sheet (Type VI) or #15 Asphalt Perforated Felt ply sheet adhered to the base sheet with approved mopping asphalt applied within the EVT range and at a rate of 20-35 lbs./sq.
- Cap Sheet:** (Optional) One ply of FlintGlas Mineral Surface cap sheet adhered in a full mopping of approved asphalt at an application rate of 20-35 lbs./sq.
- Surfacing:** (Required if no cap sheet is used) Install one of the following:
1. Flood coat of hot asphalt with an application rate of 60 lbs./sq. ± 20%; plus gravel or slag with an application rate of 400 lbs./sq. & 300 lbs./sq., respectively.
 2. A two part coating consisting of a base coat of Static Asphalt Fibered Emulsion at rate of 3 gal./sq. or Monoform compound; surfaced with 1 gal./sq. Sta-Kool non-fibered aluminum coating or fibered APOC No. 212.

Maximum Design Pressure: -355 psf (See General Limitations #9)



NOA No.: 03-0319.05
Expiration Date: 05/19/08
Approval Date: 06/13/03
Page 9 of 16

Membrane Type: BUR
Deck Type 3I: Concrete Decks, Insulated, New Construction
Deck Description: 2500 psi structural concrete or concrete plank
System Type B: Base layer of insulation mechanically fastened, optional top layer adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
Pyrox, White Line Minimum 1.3" thick	1, 2, 8, 9, 10, 17 or 20	1:2.67 ft ²
ENRGY 2 Minimum 1.4" thick	1 or 2 8, 9, 10 or 15	1:3 ft ² 1:4 ft ²
Iso 95 + Minimum 1.4" thick	17 or 20 8, 9 or 10	1:3 ft ² 1:4 ft ²
ISORoc Minimum 1.5" thick	1, 2, 8, 9, 10 or 15	1:2.67 ft ²
Multi-Max Minimum 1.5" thick	1, 2, 8, 9, 10, 15 or 17	1:2.9 ft ²
ENRGY 2 Plus Minimum 1.5" thick	1, 2, 8, 9, 10, 15, 17 or 20	1:4 ft ²
Perlite Minimum ¾" thick	1, 2, 5, 17 or 20	1:2 ft ²
High Density Wood Fiberboard Minimum ½" thick	1, 2, 5 or 20	1:2 ft ²
Fiberglas Minimum ½" thick	1, 2, 5, 8, 9, 10, 17 or 20	1:2.67 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Top Insulation Layer (Optional)	Insulation Fasteners Table 3	Fastener Density/ft²
Any of the insulations listed for Base Layer, above.		
Paroc Minimum ¾" thick	N/A	N/A
Dens-Deck Minimum ¼" thick	N/A	N/A



Note: Optional top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

- Base Sheet: (Optional) Install one ply of All Weather/Empire, Flex-I-Glas or GlasBase base sheet directly over the top layer of insulation. Adhere with any approved mopping asphalt at an application rate of 20-35 lbs./sq. (See General Limitation #4)
- Ply Sheet: Two or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) or #15 Asphalt Perforated Felt ply sheet adhered to the base sheet with approved mopping asphalt applied within the EVT range and at a rate of 20-35 lbs./sq.
- Cap Sheet: (Optional) One ply of FlintGlas Mineral Surface cap sheet adhered in a full mopping of approved asphalt at an application rate of 20-35 lbs./sq.
- Surfacing: (Required if no cap sheet is used) Install one of the following:
1. Flood coat of hot asphalt with an application rate of 60 lbs./sq. \pm 20%; plus gravel or slag with an application rate of 400 lbs./sq. & 300 lbs./sq., respectively.
 2. A two part coating consisting of a base coat of Static Asphalt Fibered Emulsion at rate of 3 gal./sq. or Monoform compound; surfaced with 1 gal./sq. Sta-Kool non-fibered aluminum coating or fibered APOC No. 212.
- Maximum Design Pressure: -52.5 psf (See General Limitations #9)



Membrane Type: BUR
Deck Type 3I: Concrete Decks, Insulated, New Construction
Deck Description: 2500 psi structural concrete or concrete plank
System Type C: All layers of insulation simultaneously fastened.

All General and System Limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer (Optional)	Insulation Fasteners Table 3	Fastener Density/ft²
Multi-Max Minimum 1" thick	N/A	N/A
AC-Foam II Minimum 1.3" thick	N/A	N/A
ENRGY 2 Minimum 1.4" thick	N/A	N/A
ISORoc, ENRGY-2 Plus Minimum 1.5" thick	N/A	N/A
High Density Wood Fiber Minimum ½" thick	N/A	N/A
Paroc, Perlite Minimum ¾" thick	N/A	N/A
Fiberglas Minimum 1⁵/₁₆" thick	N/A	N/A

Note: All layers shall be simultaneously attached; see top layer below for fasteners and density.

Top Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
Pyrox, White Line Minimum 1.3" thick	1, 2, 8, 9, 10, 17 or 20	1:2.67 ft ²
ENRGY 2 Minimum 1.4" thick	1 or 2 8, 9, 10 or 15	1:3 ft ² 1:4 ft ²
Iso 95 + Minimum 1.4" thick	17 or 20 8, 9 or 10	1:3 ft ² 1:4 ft ²
ISORoc Minimum 1.5" thick	1, 2, 8, 9, 10 or 15	1:2.67 ft ²
Multi-Max Minimum 1.5" thick	1, 2, 8, 9, 10, 17 or 20	1:2.9 ft ²
ENRGY 2 Plus Minimum 1.5" thick	1, 2, 8, 9, 10, 17 or 20	1:4 ft ²



NOA No.: 03-0319.05
 Expiration Date: 05/19/08
 Approval Date: 06/13/03
 Page 12 of 16

Perlite Minimum ¾" thick	1, 2, 5 17 or 20	1:2 ft ²
High Density Wood Fiberboard Minimum ½" thick	1, 2, 5 or 20	1:2 ft ²
Fiberglas Minimum ½" thick	1, 2, 5, 8, 9, 10, 17 or 20	1:2.67 ft ²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density.

- Base Sheet: (Optional) Install one ply of All Weather/Empire, Flex-I-Glas or GlasBase base sheet directly over the top layer of insulation. Adhere with any approved mopping asphalt at an application rate of 20-35 lbs./sq. (See General Limitation #4)
- Ply Sheet: Two or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) or #15 Asphalt Perforated Felt ply sheet adhered to the base sheet with approved mopping asphalt applied within the EVT range and at a rate of 20-35 lbs./sq.
- Cap Sheet: (Optional) One ply of FlintGlas Mineral Surface cap sheet adhered in a full mopping of approved asphalt at an application rate of 20-35 lbs./sq.
- Surfacing: (Required if no cap sheet is used) Install one of the following:
1. Flood coat of hot asphalt with an application rate of 60 lbs./sq. ± 20%; plus gravel or slag with an application rate of 400 lbs./sq. & 300 lbs./sq., respectively.
 2. A two part coating consisting of a base coat of Static Asphalt Fibered Emulsion at rate of 3 gal./sq. or Monoform compound; surfaced with 1 gal./sq. Sta-Kool non-fibered aluminum coating or fibered APOC No. 212.
- Maximum Design Pressure: -52.5 psf (See General Limitations #9)



Membrane Type: BUR
Deck Type 3: Concrete Decks, Non-insulated, New Construction
Deck Description: 2500 psi structural concrete or concrete plank
System Type F: Base sheet adhered with approved asphalt.

All General and System Limitations apply.

Base Sheet: Install one or more plies of All Weather/Empire, Flex-I-Glas or GlasBase base sheet directly to the concrete substrate. Adhere with any approved mopping asphalt at an application rate of 20-35 lbs./sq. , or spot or strip mopped as detailed in this approval; see General Limitation #4

Ply Sheet: Two or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) or #15 Asphalt Perforated Felt ply sheet adhered with approved mopping asphalt applied within the EVT range and at a rate of 20-35 lbs./sq.

Cap Sheet: (Optional) One ply of FlintGlas Mineral Surface cap sheet adhered in a full mopping of approved asphalt at an application rate of 20-35 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install one of the following:

1. Flood coat of hot asphalt with an application rate of 60 lbs./sq. \pm 20%; plus gravel or slag with an application rate of 400 lbs./sq. & 300 lbs./sq., respectively.
2. A two part coating consisting of a base coat of Static Asphalt Fibered Emulsion at rate of 3 gal./sq. or Monoform compound; surfaced with 1 gal./sq. Sta-Kool non-fibered aluminum coating or fibered APOC No. 212.

Maximum Design Pressure: -235 psf (See General Limitation #9)



CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.



NOA No.: 03-0319.05
Expiration Date: 05/19/08
Approval Date: 06/13/03
Page 15 of 16

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**

END OF THIS ACCEPTANCE



NOA No.: 03-0319.05
Expiration Date: 05/19/08
Approval Date: 06/13/03
Page 16 of 16