MIAMI-DADE

BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

Fraser Cedar Products Ltd
27400 Loughead Highway
Maple Ridge, BC V2W1L1 Canada

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Steadfast Cedar Shakes and Shingles

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This consists of pages 1 through 3.
The submitted documentation was reviewed by Frank Zuloaga, RRC

ROOFING ASSEMBLY APPROVAL

Category:	Roofing
Sub-Category:	Wood Shingles and Shakes
Material	Cedar
Deck Type:	Wood
Maximum Design Pressure	N/A
Fire Classification:	N/A

1. SCOPE:

This approves Steadfast cedar shingles and shakes as manufactured by Fraser Cedar Products Ltd. Described in Section 2 of this Notice of Acceptance, designed to comply with the Florida Building Code High Velocity Hurricane Zone.

2. PRODUCT DESCRIPTION

Product	Dimensions	Test Specifications	Product Description
Steadfast Cedar Shake	¾" thick	PA 110	Fire retardant and preservative tapered or non-tapered cedar of random widths ranging from a minimum of 3 inches to a maximum of10 inches, and a maximum length of 24 inches long.
Steadfast Wood Shingles	¾" thick		Fire retardant and preservative treated cedar, with both faces sawn, of random widths ranging from a minimum of 3 inches to a maximum of 8 inches, and a maximum length of 20 inches.

3. INSTALLATION

3.1 "Fraser Cedar Products Ltd. Steadfast Cedar Shake, Steafast Cedar Shingle"and its components shall be installed in strict compliance with Roofing Application Standard RAS 130.

3.2 The manufacturer shall provide clearly written application instructions.

4. LIMITATIONS

4.1 Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.

4.2 This acceptance is for wood deck applications. Minimum deck requirements shall be in compliance with applicable Building Code.

4.3 Shall not be installed on roof mean heights in excess of 33 ft.

5. LABELING

5.1 Shingles and shakes shall be labeled with the Miami-Dade Logo or the wording "Miami-Dade County Product Control Approved".

6. BUILDING PERMIT REQUIREMENTS

6.1 Application for building permit shall be accompanied by copies of the following:

6.1.1 This Notice of Acceptance.

6.1.2 Any other documents required by the Building Official or the applicable building code in order to properly evaluate the installation of this system.

Fastener Pull Through Resistance	
Description	**Maximum Pull Force (lbs)**
Grade Wood Shake Shingles-6.5"	143
Grade Wood Shake Shingles-6.5"	150

EVIDENCE SUBMITTED:

Test Agency	Name	Report	Date
Celotex Corporation Testing Services	PA 100-95 Wind and Wind Driven Rain Resistance of Discontinuous Roofing Systems	258489B	09/21/1998
Celotex Corporation Testing Services	PA 100-95 Wind and Wind Driven Rain Resistance of Discontinuous Roofing Systems	528643-3	10/30/95
Celotex Corporation Testing Services	Pull-through testing	25848	09/21/1998

END OF THIS ACCEPTANCE