



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

**ODL, Inc.  
215 East Roosevelt Ave.  
Zeeland, MI 49464**

**SCOPE:** This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone.

**DESCRIPTION: Plastic Glazed Tubular Skylight.**

**APPROVAL DOCUMENT:** Drawing No. 18707-000, titled "Tubular Skylight; Severe Weather ", sheets No 1 of 1, prepared by ODL, Inc. dated 01/27/03 with last revision on 06/27/03 bearing the Miami-Dade County Product Control Approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division.

**MISSILE IMPACT RATING: Large & Small Missile Impact**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein and the dome shall be properly marked by G. E. Company.

**RENEWAL** of this NOA shall not be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of this page, evidence page and approval document mentioned above  
The submitted documentation was reviewed by **Candido F. Font, P.E.**

*[Handwritten signature]*  
02/05/04



**NOA No 03-0415.20  
Expiration Date: February 5, 2009  
Approval Date: February 5, 2004  
Page 1**

**ODL, Inc.**

**NOTICE OF ACCEPTANCE: EVIDENCE PAGE**

**A. DRAWINGS**

1. Drawing No. 18707-000, sheets 1 of 1, titled "Tubular Skylights, Severe Weather", prepared by ODL Inc, dated 01/27/03, with last revision on 06/27/03, signed and sealed by L. F. Schmidt, P.E.

**B. TESTS**

1. Test report on Large Missile Impact Test per TAS 201, Cyclic Load Test per TAS 203 and Uniform Static, Air & Water Pressure Test per TAS 202, on "14" Plastic Glazed tubular Skylight", prepared by Architectural Testing reports No. 01-043861.01 dated 03/03/03, signed and sealed by J.A. Reed PE.
2. Test report on Method for Ignition Properties of Plastics per ASTM D1929, Method for Rate of Burning and/or Extent and Time of Burning of Self Supporting Plastics in a Horizontal Position per ASTM D635, Method for Density of Smoke from the Burning or Decomposition of Plastics per ASTM D2843, Method for Tensile Method of Plastics per ASTM D638 before and after weathering of Lexan 143. They were prepared by ETC Laboratories, report No. 02-745-12582.0, dated 11/07/03, signed and sealed by J. L. Doldan, PE.
3. Addendum to ETC 02-745-12582.0 dated 12/03/03, signed and sealed by J. L. Doldan PE.

**C. CALCULATIONS**

1. Anchoring Analysis of Plastic Glazed Tubular Skylight prepared by R. W. building Consultants, Inc, signed and sealed by L. F. Schmidt on 02/28/03.

**D. QUALITY ASSURANCE**

1. Miami-Dade Product Control Division:

**E. MATERIAL CERTIFICATIONS**


NONE

**F. STATEMENTS**


1. Code Compliance letter issued by Lyndon F. Schmidt, on 03/28/03, signed and Sealed by L. F. Schmidt, PE.
2. No Financial Interest letter issued by ODL Inc, on 03/17/03, signed by D. A. De Block and notarized on M. L. Query.

  
02/05/04  
Candide F. Font, P. E.  
Senior Product Control Examiner  
NOA No 03-0415.20  
Expiration Date: February 5, 2009  
Approval Date: February 5, 2004

MODEL EZ TUBULAR SKYLIGHTS	
MODEL	TUBE DIAMETER
EZ10SCP	10"
EZ14SCP	14"



TOP VIEW  
SCREW LOCATION



SECTION VIEW

#8A X 2" SS PPH SCREWS  
1" FROM EDGE,  
8 1/4" MAXIMUM O.C.

7/16" DECK MINIMUM

NOTE:  
1. ALL ROOFING DETAILS SHALL COMPLY WITH CHAPTER 15 OF THE FLORIDA BUILDING CODE.  
2. 4" MINIMUM DISTANCE FROM DOME LIP TO ROOF SURFACE FOR SHINGLE & BUR W/O INSULATION. FOR INSULATION AND TILE ROOF; ADD THE TILE HEIGHT AND THE INSULATION THICKNESS TO 4".

DESIGN PRESSURE RATING
± 100 PSF
LARGE MISSILE IMPACT RESISTANT

EDN	REV	DESCRIPTION	CHK BY	APPD BY	DATE
4953B	B	REV NOTES PER MDCBCCO	MSE	DDB	8/27/03
4953	A	RELEASE FOR PRODUCTION	MSE	DDB	1/27/03

FOR BCCO USE

Approved as complying with the Florida Building Code  
Date 02/05/04  
NOAH 03-0415.20  
Minor Trade Product Control  
Division  
By

P.E. SEALED

7.1.03

Lyndon F. Schmidt  
Florida P. E. No. 43409  
19506 French Lace Drive Lutz, FL 33558

**ODL**  
215 EAST ROOSEVELT  
ZEELAND, MI 49464  
616-772-9111

DESCRIPTION:  
TUBULAR SKYLIGHT; SEVERE WEATHER

MATERIAL:  
ALUMINUM CURB / PC DOME

DRAWING NUMBER: 18707-000	SHEET NUMBER: 1 OF 1	DRAWING DATE: 1/27/03	REVISION DATE: 1/27/03
------------------------------	-------------------------	--------------------------	---------------------------