



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Johns Manville Corporation
717 17th Street
Denver, CO 80202**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Johns Manville PVC Single Ply Roof Systems over Lightweight Concrete Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA #01-0112.08 and consists of pages 1 through 13.
The submitted documentation was reviewed by Frank Zuloaga, RRC



**NOA No.: 03-0421.06
Expiration Date: 06/21/06
Approval Date: 11/06/03
Page 1 of 13**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Single Ply
Material: PVC
Deck Type: Lightweight Concrete
Maximum Design Pressure -492.5 psf
Fire Classification: See General Limitation #1

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
UltraGard SR-50, SR-60 and SR-80	37.5" - 81" wide	ASTM D 4434	Polyester reinforced PVC membrane 50, 60 or 80 mils thickness used in mechanically fastened and adhered roofing assemblies, and as membrane flashing for walls, curbs, etc.
UltraGard FAS-50, FAS-60, FAS-80	81" wide	ASTM D 4434	Glass fiber scrim reinforced PVC membrane available in 50, 60 and 80 mil thickness used in adhered roofing assemblies and as adhered membrane flashing for walls, curbs, etc.
UltraGard Plus 50 Plus 60	53" - 81" wide	ASTM D 4434	Polyester reinforced PVC membrane 50 mils and 60 mils thick with a 7.5 ounce polyester fleece laminated to the underside. UltraGard Plus may be mechanically attached or adhered to acceptable substrates.
UltraGard V-2/50 and V-2/60	37.5" - 81" wide	ASTM D 4434	Polyester reinforced PVC polymer based, 50 or 60 mil membrane used in mechanically fastened and adhered roofing assemblies, and as membrane flashing for walls, curbs, etc.
Seekure Paper Slipsheet	96" x 300'		A laminated Kraft paper slipsheet with a fiberglass scrim reinforcement intended for use with mechanically attached systems as a separating slipsheet over smooth substrates. It is not intended for use over smooth surface BURs.
CTP Foil Slipsheet	6' - 300'		A laminated foil/Kraft paper slip sheet with a polyethylene coating on both sides of the foil intended for use with mechanically attached systems as a separation layer.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
DN Flameguard Slipsheet	71" x 700'		A laminated aluminum foil/Kraft paper slipsheet with proprietary flame extinguishing adhesive and a fiberglass scrim reinforcement for use with mechanically attached systems as a fire-retardant slipsheet in certain UL and FM assemblies.
Polyester Protection Mat	12' x 100'		A 9 ounce needle-punched polyester fabric that is used as a cushioning layer in certain applications.
Detail Membrane 80	35" x 75'	ASTM D 4434	35" wide, 80 mil thick PVC membrane used in field-formed flashing where heat forming is required. Available in white, grey, pearl or black.
Detail Strip 80	6" x 150'		6" wide 80 mil thick unreinforced PVC membrane strips used to waterproof joints of UltraGard metal. Available in white, grey, pearl and black.
Inside Corner	various		Pre-manufactured corners available in white or grey used to waterproof the corners of walls, parapets, etc..
Outside Corner	various		Pre-manufactured corners available in white or grey used to waterproof the corners of walls, parapets, curbs, pitch pockets, etc..
Coated Metal Sheets	4' x 8' 4' x 10'		Available in white, grey and black. 4' x 8' and 4' x 10' sheet sizes. UltraGard metal is a laminate of UltraGard PVC membrane and galvanized steel field fabricated into metal base flashings, edge details, and pitch pockets.
Coated Metal 3" strip	3" x 8' 3" x 10'		Pre-cut UltraGard metal strips are used for base securement and membrane flashing securement in specific details.
Pipe Boots	various		Pre-manufactured membrane boots used to flash round penetrations from 1" to 12" in diameter.
¼" Microfoam	6' x 225'		A multi-ply polypropylene foam intended for use with mechanically attached systems as a cushioning slipsheet over rough, uneven substrates. It is not intended for use over existing gravel surfaced built-up roofs.
Termination Bar	1.35" x 10'		An extruded aluminum (0.93" thick) bar slotted 6" on center used to terminate adhered "SR" and "FAS" membrane flashings in certain details.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
7" Round Disk Caps	7" round		Round membrane caps used to waterproof fastening discs in certain applications. Available in white and grey.
UltraGard PVC Membrane Adhesive (Latex)	5 Gal. Pail	Proprietary	Designed for bonding UltraGard PVC membrane to concrete, cellular concrete, and specific wood fiber roof insulations in horizontal applications only.
UltraGard PVC Membrane Adhesive (Solvent)	5 Gal. Pail	Proprietary	Designed for bonding UltraGard PVC membrane to metal, wood, concrete, cellular concrete and specific roof insulations in both horizontal and vertical applications.
UltraGard PVC Membrane One-Step Adhesive	5 Gal. Pail		Designed for bonding UltraGard PVC membrane to various vertical and horizontal surfaces.
UltraGard Sealant	30 Tube box		A single component, gun grade elastomeric polyurethane sealant used to seal UltraGard termination bar, counter flashings, etc.. UltraGard caulk is not used to caulk field seams. UltraGard caulk is available in white and grey.
UltraGard Pourable Sealer	1 Gal. Can		A two part polyurethane sealant used as a pitch pocket filler.
UltraGard PVC Round Pitch Pocket	6.5" Round		Rigid PVC flashing with an opening 6.5" in diameter used to waterproof irregularly shaped penetrations. □
UltraGard PVC Sealant	1 Gal.	Proprietary	A liquid PVC compound used to seal non-encapsulated edges of completed seams.
UltraGard Solvent Welding Solution	1 Gal.		May be used to weld UltraGard PVC membrane to UltraGard metal in certain detail applications.
UltraGard Roof Systems Membrane Cleaner	1 Gal. Can		May be used to clean small areas of the membrane where asphalt, roofing cement, etc. must be removed.
Type R Tie-in Membrane	24" x 82'		An asphalt compatible PVC membrane used as a tie-in material to existing built-up roofs.
WBP 100 Walkway	48" x 60'		100 mil thick texturized polyester reinforced PVC membrane used as a walkway and protection material. Available in blue or grey.



APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
N/A	N/A	N/A

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	High Load Fasteners	Membrane fastener for wood and steel.		Johns Manville
2.	High Load Metal Plates	Galvalume AZ55 steel plate	2-3/8" round	Johns Manville
3.	Insul-Fixx Fastener	Insulation fastener for steel and wood decks	Various	SFS Stadler, Inc.
4.	Insul-Fixx S	Galvalume AZ55 stress plate	3" round	SFS Stadler, Inc.
5.	Insul-Fixx P	Polyethylene stress plate	3" round	SFS Stadler, Inc.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Factory Mutual Research Corp.	J.I. 2W1A3.AM	Wind Uplift	01/03/94
Factory Mutual Research Corp	J.I.3Y6A0.AM	Wind Uplift	11/15/95
Factory Mutual Research Corp	J.I. 4Z0A5.AM	Wind Uplift	02/07/96
Factory Mutual Research Corp	1D6A1.AM	PA 114	09/04/98
	0D9A8.AM		04/26/99
Factory Mutual Research Corp.	3012974	Wind Uplift	06/03/02
Dynatech Engineering Corporation	94.9.27	Wind Uplift	09/28/94
Exterior Research & Design, LLC	#3705.09.96-1	PA 114	09/03/96
Exterior Research & Design, LLC	#3705.10.97-1	PA 114	10/17/97
IRT of South Florida	01-005	PA 114	03/13/01



APPROVED ASSEMBLIES:

Membrane Type: Single Ply, Thermoplastic, Mechanically Attached PVC

Deck Type 4I: Lightweight Concrete, Non-insulated

Deck Description: Lightweight Concrete

System Type D: Membrane mechanically attached through LWC to 18-22 ga. steel deck

All General and System Limitations apply.

Barrier None.

Membrane: UltraGard SR-50, SR-60 , SR-80, V-2/50, V-2/60, Plus 50 or Plus 60 installed in sheets 75" wide with a 5" overlap and fastened through the lightweight concrete to the steel deck at the lap 6" o.c. using UltraGard High Load Fasteners and Plates or SFS Stadler ELF HD #15 Fasteners with SFS LR6 metal plates. Sheets are then heat seamed together with a minimum 1.5" weld area. UltraGard liquid PVC seam sealant is to be applied to all cut or non-encapsulated edges.

Maximum Design Pressure: -60 psf (See General Limitation #7.)



Membrane Type: Single Ply, Thermoplastic, Adhered PVC

Deck Type 4I: Lightweight Concrete, Non-insulated

Deck Description: Minimum 300-psi, Approved Cellular Lightweight Concrete cast over structural concrete only

System Type F(1): Membrane adhered to deck.

All General and System Limitations apply.

Barrier None.

Membrane: UltraGard Plus-50 or Plus-60, adhered with UltraGard PVC One Step Adhesive or UltraGard PVC Latex Adhesive at a rate of 40 square feet/gallon. Field sheets are to be lapped a minimum of 3" and heat seamed together using hot air equipment, which will give a minimum 1½" weld area. UltraGard Liquid PVC Seam Sealant is to be applied to all cut or non-encapsulated edges. Care shall be taken to avoid getting adhesive in the seam areas.

Maximum Design

Pressure: -320 psf (using UltraGard Membrane Adhesive) (See General Limitation #9.)
-492.5 psf (using UltraGard Latex Adhesive) (See General Limitation #9.)



Membrane Type: Single Ply, Thermoplastic, Adhered PVC

Deck Type 4I: Lightweight Concrete, Non-insulated

Deck Description: Minimum 200-psi, Approved Cellular Lightweight Concrete cast over min. 18-22 ga., type B steel deck welded 6" o.c. to steel supports spaced maximum 5 ft. o.c.

System Type F(2): Membrane adhered to deck.

All General and System Limitations apply.

Barrier None.

Membrane: UltraGard Plus-50 or Plus-60, adhered with UltraGard PVC Latex Adhesive at a rate of 40 square feet/gallon. Field sheets are to be lapped a minimum of 3" and heat seamed together using hot air equipment, which will give a minimum 1½" weld area. UltraGard Liquid PVC Seam Sealant is to be applied to all cut or non-encapsulated edges. Care shall be taken to avoid getting adhesive in the seam areas.

Maximum Design Pressure: -45 psf (See General Limitation #9.)



Membrane Type: Single Ply, Thermoplastic, Adhered PVC

Deck Type 4I: Lightweight Concrete, Non-insulated

Deck Description: Mearlcrete Cellular Lightweight Concrete

System Type F(3): Membrane adhered to deck.

All General and System Limitations apply.

Steel Deck: Minimum 22 gage ASTM A 446 Grade E steel deck fastened to steel support at a maximum span of 5 feet o.c. Steel deck shall be fastened with puddle welds and washers at a maximum spacing of 6 inches o.c. Side laps shall be fastened with ITW Buildex Traxx/1 at a maximum spacing of 18 inches o.c.

Lightweight Concrete: Minimum 300 psi cellular lightweight concrete deck applied with a minimum 1/8" slurry coat followed by an optional minimum 1" thick Apache Holey Board and a minimum 2" thick top coat.

Treatment: Polyvinyl Alcohol (PVA) applied to the deck top surface when walkable.

Barrier None.

Membrane: UltraGard Plus-50 or Plus-60, adhered with UltraGard PVC Solvent Adhesive at a rate of 40 square feet/gallon. Field sheets are to be lapped a minimum of 3" and heat seamed together using hot air equipment, which will give a minimum 1½" weld area. UltraGard Liquid PVC Seam Sealant is to be applied to all cut or non-encapsulated edges. Care shall be taken to avoid getting adhesive in the seam areas.

Maximum Design Pressure: -45 psf (See General Limitation #9.)



Membrane Type: Single Ply, Thermoplastic, Adhered PVC
Deck Type 4I: Lightweight Concrete, Non-insulated
Deck Description: Celcore Cellular Lightweight Concrete over structural concrete
System Type F(4): Membrane adhered to deck.

All General and System Limitations apply.

Deck: Structural Concrete

Lightweight Concrete: Minimum 300 psi cellular lightweight concrete and minimum 3" thick.

Treatment: Celcore PVA Curing compound at a rate 1 gal/300 ft² applied to the deck top surface when walkable. Curing shall be dry prior to membrane adhesion.

Barrier None.

Membrane: UltraGard Plus-50 or Plus-60, adhered with UltraGard PVC Latex Adhesive at a rate of 3 gal/sq. or two coats of UltraGard PVC Solvent Adhesive (one coat on deck other coat on roof membrane) at a rate of 2 gal/sq. per coat. Field sheets are to be lapped a minimum of 3" and heat seamed together using hot air equipment, which will give a minimum 2" weld area. UltraGard Liquid PVC Seam Sealant is to be applied to all cut or non-encapsulated edges. Care shall be taken to avoid getting adhesive in the seam areas.

Maximum Design Pressure: -135 psf (See General Limitation #9.)



Membrane Type: Single Ply, Thermoplastic, Adhered PVC

Deck Type 4I: Lightweight Concrete

Deck Description: Cellular Concrete, LLC Mearlcrete Cellular Lightweight Concrete (Min. 300 psi)

System Type F(5): Membrane adhered to deck.

All General and System Limitations apply.

Deck: 18-22 ga Grade E steel deck shall be secured 6" o.c. to structural supports spaced a maximum of 6' o.c. with 5/8" puddle welds. Steel deck side laps are attached 12" o.c. with Traxx/1 fasteners or #10 self-tapping screws. Mearlcrete cast at 39 pcf wet density is applied with an 1/8" slurry coat followed by optional minimum 1" thick Apache Holey Board. A minimum 2" thick cap of Mearlcrete Lightweight Concrete.

Barrier None.

Membrane: UltraGard Plus-50 or Plus-60, adhered with UltraGard PVC Solvent Adhesive or UltraGard PVC Latex Adhesive at a rate of 40 square feet/gallon. Field sheets are to be lapped a minimum of 3" and heat seamed together using hot air equipment, which will give a minimum 1½" weld area. UltraGard Liquid PVC Seam Sealant is to be applied to all cut or non-encapsulated edges. Care shall be taken to avoid getting adhesive in the seam areas.

Maximum Design Pressure: -90 psf (See General Limitation #9.)



LIGHTWEIGHT INSULATING CONCRETE SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 137, calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.
3. For Systems where specific lightweight insulating concrete is referenced consult current lightweight insulating concrete NOA for specific deck construction and limitations. For systems where specific lightweight insulating concrete is not referenced, the minimum design mix shall be a minimum of 300 psi.



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 03-0421.06
Expiration Date: 06/21/06
Approval Date: 11/06/03
Page 13 of 13