MIAMI-DADE

BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

Tritex LLC
60 Corporate Lane
Independence, VA 24348

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Tritex ROCKROOF 600

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This consists of pages 1 through 3.
The submitted documentation was reviewed by Frank Zuloaga, RRC

PRODUCT CONTROL ACCEPTED

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Insulation
Material: Mineral wool

1.SCOPE

This acceptance is for **ROCKROOF** a rock wool fibermat installed as a fire barrier for use with various roof and wall assemblies as manufactured by Tritex, LLC, and as described in Section 2 of this Notice of Acceptance herein.

2. PRODUCT DESCRIPTION

Product	Dimensions	Test Specification	Product Description
ROCROOF 600	4mm x 1m x 30m or other agreed length and width	N/A	Rock wool-based, non-woven felt developed to provide a UL fire rating to waterproofing membranes and metal roofs.

3. LIMITATIONS

3.1 Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product

3.2 Trixtex's ROCROOF 600 is a rock wool fibermat used as a fire barrier for prepared roof assemblies. For fire classification of specific roof assemblies using Trixtex's ROCROOF 600 refer to a current Approved Roofing Materials Directory for fire ratings of this product.

3.3 This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code.

4. INSTALLATION

4.1 Trixtex's ROCROOF 600 shall be installed in strict compliance with applicable Building Code.

4.2 Trixtex's ROCROOF 600 is loose-laid with side laps and butt-joints over various insulations, underlayments, or decks. Various approved roofing systems may be applied over ROCROOF 600.

4.3 Trixtex's ROCROOF 600 is a component used in roof assemblies. Roof assemblies are approved under specific assembly Notice of Acceptance.

4.4 Trixtex's ROCROOF 600 may be used with any approved roof covering Notice of Acceptance listing Trixtex's ROCROOF 600 as a component part of an assembly in the Notice of Acceptance. If Trixtex's ROCROOF 600 is not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.

5. LABELING

5.1 All packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo.

5.2 Tritex's ROCROOF 600 shall be provided in packaging labeled with the Underwriters Laboratories Fire Classification

6. BUILDING PERMIT REQUIREMENTS

6.1 Application for building permit shall be accompanied by copies of the following:

6.1.1 This Notice of Acceptance.

6.1.2 Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this material.

EVIDENCE SUBMITTED:

Test Agency/Identifier	Name	Report	Date
Underwriters Laboratories	Fire Classification	UL File R 10117	11/22/95

END OF THIS ACCEPTANCE