MIAMI-DADE

BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

Alside, Inc.
3773 State Road
Cuyahoga Falls, OH 44223

SCOPE: This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone.
DESCRIPTION: Vinyl Siding & Soffit
APPROVAL DOCUMENT: Drawing No. DC0004, titled "Installation Design Drawing for Vinyl Siding", sheets 1 of 1, prepared, by Alside Inc, dated 04/14/00,with no revisions, signed and sealed J. R. Humphrey, PE, bearing the Miami-Dade County Product Control Renewal stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Division.
MISSILE IMPACT RATING: Large and Small Missile Impact
LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.
RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.
TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.
ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.
INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.
This NOA **renews NOA # 00-0128.11** and, consist of this page 1, evidence page as well as approval document mentioned above.
The submitted documentation was reviewed by **Candido Font, PE.**

02/08/04

PRODUCT CONTROL ACCEPTED

NOA No 03-1105.05
Expiration Date: April 24, 2005
Approval Date: February 5, 2004

Alside, Inc.

NOTICE OF ACCEPTANCE: EVIDENCE PAGE

A DRAWING

1. Drawing prepared by Alside, Inc., titled "Installation Design Drawing For Vinyl Siding", drawing No. DC0004, dated 04/14/2000, with no revisions, signed and sealed by J. R. Humphrey, PE.

B TEST

	Laboratory Report	Test	Date	Signature
1	NCTL-210-1820 (4 - 6)	PA 202 & 203	04/15/96	B. Portnoy, PE.
2	NCTL 210-1820(10 – 12)	PA 202 & 203	04/15/96	B. Portnoy, PE.
3	NCTL 210-1820(1 – 3)	PA 202 & 203	04/15/96	B. Portnoy, PE.
4	NCTL 210-1820(7 – 8)	PA 202 & 203	04/15/96	B. Portnoy, PE.
4	ATI – 18749	PA 202 & 203	01/21/97	A. N. Reeves, PE.
5	ATI – 18749-1	PA 202 & 203	01/21/97A.	A. N. Reeves, PE.
6	ATI – 01-33667.01	PA 202 & 203	07/08/99A.	A.N. Reeves, PE.
7	ATI – 01-32593.01	PA 202 & 203	07/08/99	A. N. Reeves, PE.
8	ATI – 01-33409.01	PA 202 & 203	07/07/99	A. N. Reeves, PE.
9	ATI – 17648-1	ASTM D3679	10/25/96	D. G. Moyer.
10	UL R14214	ASTM E84	06/01/92	N. G. Sanchez.

C MATERIAL CERTIFICATION

1 None.

D STATEMENTS

1 Code Compliance letter issued by Alside, Inc., dated 12/10/99, signed and sealed by J. R. Humphrey, PE.

2 Test compliance letter issued by Architectural Testing, Inc., on 07/28/99, signed and sealed by A. N. Reeves, PE.

3 No financial Interest letter issued by H. R. Engineering Inc, dated 10/30/03, signed by A. N. Reeves PE and notarized by R. E. Davis.

E QUALITY ASSURANCE

1 Building Code Compliance Office.

02/08/04

Candido F. Font, PE
Product Control Division
NOA No 03-1105.05
Expiration Date: April 24, 2005
Approval Date: February 5, 2004

ALSIDE VINYL SIDING

APPROVED MODELS



CenterLock



Charter Oak



D/41/2 or 5" Traditional Lap

General Notes

1. Alside's Vinyl Siding/Soffit is Manufactured from a formulated P.V.C. powder compound meeting the spfcifications of ASTM D3679
2. Walls and Soffit receiving Vinyl Siding/Soffit shall be checked for structural adequacy, cracks or defects that shall be eliminated
3. Walls shall be water proofed with the equivalent of 15 pound felt as described in section 2704.6 (b) of the SFBC
4. Walls and Soffit where Vinyl Siding/Soffit will be installed shall be designed by a certified professional per the SFBC and the requirements of this NOA
5. Installation of Siding/Soffit accesories & accesories such as Corner Posts, Starter Strips,Trims around openings shall be done in accordance with the Manufactures instructions and the SFBC

TABLE I

Name	Fastner & Frequency	Exposure in Inches	Thickness	Design (psf) Pressure (1)
CenterLock	two 16ga. staples 1x1-1/2 @ 18"o.c.	Double 4 1/2	0.042"	F.S. @ 18"o.c. 40
CenterLock	one 16ga. Staple 1x1-1/2,@ 6" o.c.	Double 4 1/2	0.042"	Plywood 80
CenterLock	one 1-1/2 galv. roofing nails @ 8" o.c.	Double 4 1/2	0.042"	Plywood 52
Sears CenterLock	two 16ga. staples 1x1-1/2 @ 18"a.c.	Double 4 1/2	0.044"	F.S. @ 18"o.c. 47
Sears CenterLock	one 16ga. Staple 1x1-1/2,@ 6" o.c.	Double 4 1/2	0.044"	Plywood 80
Sears CenterLock	one 1-1/2 galv. roofing nails @ 8" o.c.	Double 4 1/2	0.044"	Plywood 76
Charter Oak	two 16ga. staples 1x1-1/2 @ 18"a.c.	Double 4 1/2	0.046"	F.S. @ 18"o.c. 47
Charter Oak	one 16ga. Staple 1x1-1/2,@ 6" o.c.	Double 4 1/2	0.046"	Plywood 80
Charter Oak	one 1-1/2 galv. roofing nails @ 8" o.c.	Double 4 1/2	0.046"	Plywood 70

TABLE II

Name	Fastner & Frequency	Exposure in Inches	Thickness	Design (psf) Pressure (1)
Standard	one #8x1-1/4 screw @ 9"a.c.	Double 5	0.044"	Plywood 70
Standard	two 16ga. staples 1x1-1/2 @ 9"o.c.	Double 5	0.044"	Plywood 70
Standard	two 16ga. staples 1x1-1/2 @ 12"o.c.	Double 5	0.044"	F.S. @ 12"o.c. 40
Highland Cedar	one #8x1-1/4 screw @ 12"o.c.	Double 4 1/2	0.044"	Plywood 70
Highland Cedar	two 16ga. staples 1x1-1/2 @ 10"a.c.	Double 4 1/2	0.044"	Plywood 70
Highland Cedar	two 16ga. staples 1x1-1/2 @ 12"a.c.	Double 4 1/2	0.044"	F.S. @ 12"o.c. 60

(1) Design Pressure depends on Fasrener type & frequency. F.S. indicates Furring strip spacing in agreement with the fastener spacing required.

APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE
DATE May 26, 2000
BY _____
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 00-0128.11

Typical Installation Vinyl Siding



Plywood/Wood Installation

Typical Installation Vinyl Siding



CBS Installation

PRODUCT RENEWED
as complying with the Florida Building Code
Acceptance No. 03-1105.05
Expiration Date 4/24/05
By _____
Miami Dade Product Control Division

James Robert Humphrey, P.E. 5/8/00
James Robert Humphrey, P.E. Date
P.E. #0044508

Alside	
DRAWN BY	JFSHANER
CHECKED	JFSHANER
SCALE	NONE
ISSUE DATE	14-APRIL-2000
SHEET 1 OF 1	

INSTALLATION DESIGN DRAWING FOR VINYL SIDING

DRAWING NO. DC0004