



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Dyplast Products LLC
12501 NW 38 Avenue
Opa Locka, FL 33054**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone.

DESCRIPTION: Dyplast Iso-25 Isocyanurate Insulation.

APPROVAL DOCUMENT: Drawing No. 01, titled "Dyplast Iso-25 Isocyanurate Insulation", sheet 1 of 1, prepared by Dyplast Products LLC, signed and sealed by J. D. Burkhart, P.E., dated 05/05/04 with no revisions, bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: None

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA # 01-1108.08 and, consists of this page, evidence page as well as approval document mentioned above.

The submitted documentation was reviewed by ~~Candido Fant~~, P.E.



[Signature]
06/10/04

**NOA No 03-1209.09
Expiration Date: January 11, 2007
Approval Date: June 10, 2004
Page 1**

Dyplast Products LLC.

NOTICE OF ACCEPTANCE: EVIDENCE PAGE

A DRAWING

1. Drawing No. 01, titled, "Dyplast Iso-25 Isocyanurate Insulation", Sheet 1 of 1, prepared by Dyplast Products LLC, dated 05/05/04 signed and sealed by J. O. Burkhart, PE.

B TEST

	Laboratory Report	Test	Date	Signature
1.	MTS # 25-7446-A	ASTM C209	11/08/95	R.G. Miller PE
2.	MTS # 25-7446-C	ASTM D1621	11/08/95	RG Miller, PE
3.	MTS # 25-7446-D	ASTM D1622	11/08/95	RG Miller, PE
4.	MTS # 25-7446-E	ASTM D2126	11/08/95	RG Miller, PE
5.	MTS # 25-7446-F	ASTM E96	12/11/95	RG Miller, PE
6.	MTS # 257478-B	ASTM D1929	12/11/95	RG Miller, PE
7.	FMS J.I. 0W7Q3.AM	ASTM E84	07/21/93	RG Miller, PE

C CALCULATION N/A

D QUALITY ASSURANCE


1. Miami Dade Product Control Division

E STATEMENTS

1. Letter of evaluation prepared by Center For Applied Engineering Inc., issued on 09/18/95 and signed by L.F. Barry.
2. No change letter issued by Apache Products Company on 11/01/2001 and signed by I. Handy.
3. No change letter issued by Dyplast Products LLC on 05/05/04 and signed by J. Glorioso.
4. US Bankruptcy Chapter 11 papers received by the Court on 10/24/02 filed by Apache Products Co.

F OTHER

NOA # 01-1108.08


06/10/04
Candido F. Font, P.E.
Senior Product Control Examiner
NOA No 03-1209.09
Expiration Date: January 11, 2007
Approval Date: June 10, 2004

DYPLAST ISO-25 ISOCYANURATE INSULATION
PROPERTIES

<u>Description</u>	<u>Test</u>	<u>Properties</u>
Density	ASTM D-1622	1.93 PCF
Compressive Strength	ASTM D-1621	23.4 PSI
Water Absorption by Volume	ASTM C-209	0.54%
Dimensional Stability by Volume at 14 days	ASTM D-2126	3.37%
Flame Spread	ASTM E-84	20
Smoke Density	ASTM E-84	155
Self Ignition Temp	ASTM D-1929	1004°F
R-Value (3/4" thick)	ASTM C-518	5.61
Water Vapor Transmission	ASTM E-96	2.36 Perms

General Notes

1. Application of DYPLAST ISO-25 insulation shall comply with all pertinent sections of the Florida Building Code, in particular Section 2605.2.
2. This product has not been evaluated for outdoor exposure, therefore it shall be fully protected from the elements at all times.
3. Installation of DYPLAST ISO-25 may be made with cement mortar on mechanical fasteners in accordance with the recommendation of DYPLAST Products LLC.
4. This product cannot be used as sheathing and it shall be continuously supported by a structural backing.

DYPLAST PRODUCTS LLC
12501 NW 38 AVENUE
OPA LOCKA, FLORIDA 33054
DYPLAST ISO-25 ISOCYANURATE INSULATION
DRAWING NO. <i>01</i> DRAWING DATE: <i>5/5/2004</i> SHEET NO: <i>1</i> OF <i>1</i>

James D. Burkhot
James D. Burkhot
P.E. No 49277
5/5/2004

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No *03-1209-09*
Expiration Date *01/11/10*
[Signature]
Miami Dade Product Control
Division