



BUILDING CODE COMPLIANCE OFFICE (BCCO)
 PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
 METRO-DADE FLAGLER BUILDING
 140 WEST FLAGLER STREET, SUITE 1603
 MIAMI, FLORIDA 33130-1563
 (305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

GAF Materials Corporation
1361 Alps Road
Wayne, NJ 07470

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: GAF EverGuard Freedom TPO SA Single Ply Roofing System over Lightweight Concrete Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 7.
 The submitted documentation was reviewed by Frank Zuloaga, RRC.



NOA No: 04-0122.02
Expiration Date: 05/28/09
Approval Date: 05/28/04
Page 1 of 7

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	TPO, Self-Adhered Single Ply Roofing
Deck Type:	LWC
Maximum Design Pressure	-52.5 psf
Fire Classification:	See General Limitation #1

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
EverGuard Freedom TPO SA Membrane	Various	ASTM D 6878	Self-Adhered thermoplastic olefin reinforced membrane.
EverGuard Freedom HW TPO Membrane	Various	ASTM D 6878	Self-Adhered thermoplastic olefin reinforced membrane.
EverGuard TPO-45 Utility Flashing Strips	Various	ASTM D 6878	Thermoplastic olefin reinforced flashing membrane.
EverGuard TPO UN-60 Detailing Membrane	Various	ASTM D 6878	Thermoplastic olefin reinforced flashing membrane.
EverGuard TPO Coated Metal	4' x 8' 4' x 10' sheets	US CS-245-62	EverGuard membrane laminated 24 Ga. galvanized steel.
EverGuard TPO Preformed Corners	4" x 4" x 4" 20 pcs. crtn.	ASTM D 4434	Prefabricated molded one piece corners.
EverGuard TPO Preformed Vent Boots	1" - 8" o.d. 6 pcs. crtn.	ASTM D 4434	Premolded vent pipe boots.
EverGuard TPO Cut Edge Sealant	1 quart squeeze tube	Proprietary	Solvent based sealant for TPO cut edges.
EverGuard Expansion Joint Cover	4"-8" x 50'		Low profile expansion joint cover.
EverGuard Standard Walkway	1/8" x 30" x 36"		Standard duty walkway pad.
EverGuard HD Walkway	1/4" x 30" x 36"		Heavy duty walkway pad.

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
EnergyGuard PolyIso, RA, RN	Polyisocyanurate foam insulation	GAF Materials Corp.



NOA No: 04-0122.02
 Expiration Date: 05/28/09
 Approval Date: 05/28/04
 Page 2 of 7

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
EnergyGuard High Density Fiberboard	High density wood fiberboard insulation.	GAF Materials Corp.
EnergyGuard Perlite	Perlite insulation board.	GAF Materials Corp.
EnergyGuard Composite RA, RN	Polyisocyanurate foam insulation with high density fiberboard or Permalite perlite insulation.	GAF Materials Corp.
Wood Fiberboard	Regular wood fiber insulation	Generic
High Density Wood Fiberboard	High Density Wood Fiber insulation board.	Generic
Perlite Insulation Board	Perlite Insulation	Generic
Type X Gypsum	Gypsum Wallboard	Generic
Dens Deck	Water-resistant gypsum board	Georgia Pacifi

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Drill-Tec® #12 Standard & #14 HD Roofing Fasteners	Insulation fastener for steel, wood & concrete decks.		GAF Materials Corp.
2.	Drill-Tec® Base Sheet Fastener and Plate	Base sheet fastening assembly.		GAF Materials Corp.
3.	GAFTITE® (Drill-Tec®) CR Base Sheet Fastener and Plate	Base sheet fastening assembly.		GAF Materials Corp.
4.	Drill-Tec® Metal Plates	Round galvalume stress plates.	3" and 3 ½"	GAF Materials Corp.
5.	NTB Fasteners	Fastener for use in gypsum, tectum and lightweight insulating concrete decks.		GAF Materials Corp.
6.	Olympic Base Sheet Fastener and Plate	Base sheet fastening assembly.		Olympic Manufacturing Group, Inc.
7.	Olympic CR Base Sheet Fastener and Plate	Base sheet fastening assembly.		Olympic Manufacturing Group, Inc.



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
8.	Olympic Standard	Galvalume AZ50 steel plate	3" round	Olympic Manufacturing Group, Inc.

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Underwriters Laboratory, Inc.	03CA38009	UL 790	01/21/04
IRT-Arcon, Inc.	04-019	TAS 114	04/26/04
Factory Mutual Research Corp.	FMRC 4470	3020588	03/24/04



APPROVED ASSEMBLIES:

Deck Type 4I: Lightweight Concrete, Insulated, over Steel Deck

Deck Description: Cellular or Aggregate Lightweight Concrete

System Type B: Base layer of insulation mechanically attached to Steel Deck deck. Membrane is subsequently adhered to insulation.

Deck: Minimum 22 ga. Type B steel deck secured to minimum ¼” thick supports space at maximum 6 ft o.c. with ITW Buildex Traxx/4 or Traxx/5 spaced at 6” o.c. Deck side laps are secured with Traxx/1 fasteners spaced at maximum 24” o.c.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard PolyIso Minimum 2” thick	1	1:2 ft²

Note: Base layers of insulation shall be mechanically attached using the fastener density listed. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Slip Sheet: Install one ply of GAFGLAS® #75, GAFGLAS #80 Ultima™ Base Sheet, STRATAVENT® Eliminator Nailable Venting or RUBEROID® 20 loose laid over Lightweight Concrete deck.

Membrane: EverGuard Freedom TPO SA adhered to insulation with a minimum 6” side lap fully self-adhered or Freedom HW (self-adhered) with a minimum 3” side lap heat welded with a minimum 1.75” weld.

Maximum Design Pressure: -52.5 psf (See General Limitation #7.)



Deck Type 4: Lightweight Concrete, Non-Insulated

Deck Description: Celcore Lightweight Insulating Concrete (Min. 300 psi)

System Type E: Anchor sheet mechanically fastened; membrane adhered

Deck: Min. 22 ga., Type B steel decking over ¼” thick steel supports spaced max. 5 ft o.c. attached 6” o.c. using Traxx/5 fasteners. Deck side laps are attached 12” o.c. using Traxx/1 fasteners. Steel deck is covered with a Celcore lightweight concrete pour consisting of a 1/8” slurry coat, minimum 2” thick Holey Board, followed by a min. 2” thick top coat.

Base Sheet: Install one ply of TriFlex 30 Base Sheet mechanically fastened as described below.

Fasteners: Drill-Tec 1.75 CR Base Sheet Fasteners at a fastener spacing of 9” o.c. at the 3” wide sidelaps and 9” o.c. in three staggered rows in the field of the base sheet.

Membrane: EverGuard Freedom TPO SA adhered to base sheet with a minimum 6” side lap fully self-adhered or Freedom HW (self-adhered) with a minimum 3” side lap heat welded with a minimum 1.75” weld.

Maximum Design Pressure: -52.5 psf (See General Limitation #7)

LIGHTWEIGHT INSULATING CONCRETE SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 137, calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8” puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.
3. For Systems where specific lightweight insulating concrete is referenced consult current lightweight insulating concrete NOA for specific deck construction and limitations. For systems where specific lightweight insulating concrete is not referenced, the minimum design mix shall be a minimum of 300 psi.



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
- 10 All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No: 04-0122.02
Expiration Date: 05/28/09
Approval Date: 05/28/04
Page 7 of 7