



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Tamko Roofing Products, Inc.
P.O. Box 1404
Joplin, MO 64802**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: TAMKO Modified Bitumen Roof System Over Wood Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA #02-0212.07 and consists of pages 1 through 19.
The submitted documentation was reviewed by Frank Zuloaga, RRC



**NOA No.: 04-0506.03
Expiration Date: 05/23/07
Approval Date: 07/01/04
Page 1 of 19**

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	SBS/APP, Modified Bitumen
Deck Type:	Wood
Maximum Design Pressure	-60 psf
Fire Classification:	See General Limitation #1

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Awaplan 170 FR	Roll weight: 98 lbs.; 33' 11" x 39 3/8"	ASTM D 5147 ASTM D 6164 Type I, Grade G	A 180 g/m ² polyester reinforced SBS modified bitumen membrane surfaced with granules and treated for additional fire resistance. Applied in hot asphalt or cold adhesive.
Awaplan 170™	Roll weight: 98 lbs.; 33' 11" x 39 3/8"	ASTM D 5147 ASTM D 6164 Type I Grade G	A 180 g/m ² polyester reinforced SBS modified bitumen membrane surfaced with granules. Applied in hot asphalt or cold adhesive.
Awaplan Heat Welding™	Roll weight: 96 lbs.; 25' 5" x 39 3/8"	ASTM D 5147 ASTM D 6164 Type II Grade G	A 250 g/m ² polyester reinforced SBS modified bitumen membrane surfaced with granules. Applied by torch and also used as a walkway material.
Awaplan Premium FR™	Roll weight: 101 lbs.; 33' 11" x 39 3/8"	ASTM D 5147 ASTM D 6164 Type II Grade G	A 250 g/m ² polyester reinforced modified bitumen membrane surfaced with granules. Applied by hot asphalt and also used as a walkway material.
Awaplan Premium™	Roll weight: 101 lbs.; 33' 11" x 39 3/8"	ASTM D 5147 ASTM D 6164 Type II Grade G	A 250 g/m ² polyester reinforced SBS modified bitumen membrane surfaced with granules. Applied in hot asphalt or cold adhesive, and also used as a walkway material.
Awaflex	Roll weight: 76 lbs; 35.9' x 36"	ASTM D 5147	SBS modified cap sheet constructed with a 155gm/m ² non- woven polyester mat saturated with asphalt, coated on both sides with SBS rubber modified asphalt and surfaced with ceramic granules for UV protection.
Awaflex FR	Roll weight: 76 lbs; 35.9' x 36"	ASTM D 5147	SBS FR modified cap sheet constructed with a 155gm/m ² non- woven polyester mat saturated with asphalt, coated on both sides with SBS rubber modified asphalt, FR treated, and surfaced with ceramic granules for UV protection.



NOA No.: 04-0506.03
 Expiration Date: 05/23/07
 Approval Date: 07/01/04
 Page 2 of 19

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Awaplan Versa-Smooth	Roll weight: 100 lbs. 33' 11" x 39 ³ / ₈ "	ASTM D 5147 ASTM D 6164 Type I Grade S	A 180 g/m ² polyester reinforced SBS modified bitumen membrane. Applied in hot asphalt, by torch, or mechanically fastened, as a base ply in 2 ply modified systems.
Awaplan Versa-Flex	Roll weight: 76 lbs; 33' 11" x 39-3/8"	ASTM D 5147 ASTM D 6164 Type I Grade S	A 170 g/m ² nonwoven polyester reinforced SBS modified bitumen membrane. Applied in hot asphalt, as a base ply in 2 ply modified systems.
Base-N-Ply®	Roll weight: 72 lbs.; 97' -6" x 39 ³ / ₈ "	ASTM D 4601 Type II	Asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.
Glass-Base™	Roll weight: 72 lbs.; 97' 6" x 39 ³ / ₈ "	ASTM D 4601 Type II	Asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.
Tam-Cap™	Roll weight: 83 lbs.; 32' 11" x 39 ³ / ₈ "	ASTM D 3909	Asphalt impregnated and coated felt surfaced with mineral granules used as the top ply in conventional built-up roof membranes.
Tam-Glass Premium™	Roll weight: 53 lbs.; 161' 9" x 39 ³ / ₈ "	ASTM D 2178 Type VI	Asphalt impregnated glass felt for use in conventional and modified bitumen built-up roofing.
Tam-Ply IV™	Roll weight: 44 lbs.; 161' 9" x 39 ³ / ₈ "	ASTM D 2178 Type IV	Asphalt impregnated glass felt for use in conventional and modified bitumen built-up roofing.
Type 43 Base Sheet	Roll weight: 85 lbs.; 72' x 36"	ASTM D 2626	An organic felt reinforced asphalt base sheet. Applied in hot asphalt or mechanically fastened.
Vapor-Chan™	Roll weight: 86 lbs.; 32' 11" x 39 ³ / ₈ "	ASTM D 4897	Heavy duty fiber glass base sheet impregnated and coated on both sides with asphalt with or without a fine mineral stabilizer. Surfaced on the bottom side with coarse mineral granules embedded in hot asphaltic coating.
Versa-Base FR™	Roll weight: 60 lbs.; 48' 2" x 39 ³ / ₈ "	ASTM D 5147	Asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.
Versa-Base™	Roll weight: 94 lbs.; 48' 2" x 39 ³ / ₈ "	ASTM D 5147 ASTM D 6163 Type I, Grade G	Asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.
Versa-Cap FR™	Roll weight: 87 lbs.; 33' x 39 ³ / ₈ "	ASTM D 5147	A fiberglass reinforced, mineral surfaced, SBS modified bitumen top membrane.
Tam-Pro 846 Fibered Emulsion Coating	5 gallon	ASTM D 1227, type II	Protective coating.
Tam-Pro 813 Quick-Dry Primer	5 gallon	ASTM D 41	Asphalt based primer



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Tam-Pro 842 Fire Rated Fibered Aluminum Roof coating	5 gallons	ASTM D2824, type III	Flame retardant protective coating

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
Pyrox, White Line	Isocyanurate Insulation	Apache Products Co.
ACFoam Composite	Isocyanurate Insulation with perlite facer	Atlas Roofing Corp.
ACFoam II	Isocyanurate Insulation	Atlas Roofing Corp.
ConPearl	Expanded perlite mineral fiber	Conglas
EnergyGuard Perlite	Expanded mineral fiber	GAF Mat'l. Corp.
EnergyGuard Fiberboard	Wood fiber board	GAF Mat'l. Corp.
Dens Deck	Silicon treated gypsum	G-P Products
Sturdi-Top	Wood fiber insulation board.	G-P Products
Wood Fiberboard	Regular wood fiber insulation	Generic
High Density Wood Fiberboard	High Density Wood Fiber insulation board.	Generic
Perlite Insulation Board	Perlite Insulation	Generic
Armor Board Regular Fiberboard	Wood fiber board	Honeywell Int'l. Inc.
Hubert Fiberboard	Wood fiber board	Huebert Fiberboard, Inc.
ENERGY 2, ENERGY 3, PSI-25	Isocyanurate Insulation.	Johns Manville
Retro-Fit Board, DuraBoard	A high-density perlite roof insulation.	Johns Manville
Fesco Board	Rigid perlite roof insulation board.	Johns Manville
Kop-R Wood Fiber	Wood fiber board	Koppers Industries, Inc.
Structodeck, Structodek FS	High Density Wood Fiber insulation board.	Masonite



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Dekfast Fasteners #12, #14 & #15	Insulation fastener for wood, steel and concrete decks		SFS Intec, Inc.
2.	Dekfast Hex Plate	Galvalume hex stress plate.	2 7/8" x 3 1/4"	SFS Intec, Inc.
3.	#12 Roofgrip Fasteners	Insulation fastener for wood and steel.		ITW Buildex Corp.
4.	Metal Plate	Galvalume stress plate.	3" round 3" square	ITW Buildex Corp.
5.	Olympic Fastener #12 & #14	Insulation fastener		Olympic Mfg Group, Inc..
6.	Olympic G-2	Galvalume AZ55 steel plate	3.5" round	Olympic Mfg Group, Inc.
7.	Olympic Standard	Galvalume AZ50 steel plate	3" round	Olympic Mfg Group, Inc.
8.	Insul-Fixx Fastener	Insulation fastener for steel and wood decks		SFS Intec, Inc.
9.	Insul-Fixx S Plate	Galvalume AZ50 steel plate	3" round	SFS Intec, Inc.
10.	Tru-Fast	Insulation fastener for steel and wood decks		The Tru-Fast Corp.
11.	Tru-Fast Plates	Galvalume AZ55 steel plate	3" round	The Tru-Fast Corp.

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corp.	Comparative Rupture Testing	J.I. 4D0A7.AM	10.21.98
	Class 1 Fire	J.I. 0Z4A3.AM	08.27.97
	Class 1 Fire; 1-90 Windstorm	J.I. 1D4A7.AM	10.20.97
	Class 1 Fire; 1-90 Windstorm	J.I. 3B5A9.AM	08.27.978
Exterior Research & Design, LLC	Wind Uplift Testing	4444.06.98-1	06.15.98
	Wind Uplift Testing	4449.08.99-1	08.03.99



NOA No.: 04-0506.03
 Expiration Date: 05/23/07
 Approval Date: 07/01/04
 Page 5 of 19

APPROVED ASSEMBLIES:

- Deck Type II:** Wood, Insulated
- Deck Description:** Minimum 1⁵/₃₂" or greater plywood or wood plank. Plywood shall be attached to 2" x 4" wood supports spaced 24" o.c. using wood screws spaced 6" o.c. at perimeters and intermediate supports.
- System Type A:** Anchor sheet mechanically fastened; all layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

Anchor Sheet: One ply of Tamko Glass-Base, Vapor-Chan or Base-N-Ply fastened to the deck as described below:

- Fastening:**
 - (*Option #1*) Attach anchor sheet using 11 ga. annular ring shank nails and 1-5/8" diameter tin caps spaced 9" o.c. in a 4" lap and 9" o.c. in two staggered rows in the center of the sheet.
(-52.5 psf, See General Limitation #7.)
 - (*Option #2*) Attach anchor sheet using #12 or #14 Dekfast Fasteners with Hex Plates, SFS #12 or HD Insulfixx S, or Buildex Accutrax Fasteners and 3" Square Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.
(-60 psf, See General Limitation #7.)

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam II Minimum 1.2" thick	N/A	N/A
UltraGard Gold Minimum 1.3" thick	N/A	N/A
ENRGY-2, ENRGY-3, PSI-25 Minimum 1.4" thick	N/A	N/A
Top or Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ConPerl, EnergyGuard Perlite, Fesco Board, Retro-Fit, High Density Wood Fiberboard, Structodek FS Minimum 1/2" thick	N/A	N/A

Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.



- Base Sheet:** (Optional) One ply of Glass-Base, Base-N-Ply, Versa-Base, Versa-Smooth, Awaplan VersaFlex, or Vapor-Chan adhered to the substrate with a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Ply Sheet:** One or more plies of Tam-Glass Premium, Tam-Ply IV, Glass Base, Base-N-Ply, Awaplan VersaFlex, Awaplan Versa-smooth, or Versa-Base adhered with a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Membrane:** Awaplan Premium, Awaplan Premium FR, Awaplan 170, Awaflex, Awaflex FR,, Awaplan 170 FR, Awaplan Versa-Smooth, Awaplan VersaFlex, or Versa-Cap FR adhered with a full mopping of approved asphalt applied at 400° F at the point of contact and at a rate of 20-40 lbs./sq.; or Awaplan Heat Welding or Versa-Smooth adhered by torch.
- Surfacing:** Optional to mineral surfaced Membranes. Required for smooth surfaced membranes:
1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
 2. Tam-Pro FR Aluminum Coating applied at 1½ gal./sq., or Tam-Pro 846 Fibered Emulsion Coating at 3 gal./sq.
- Maximum Design Pressure:** *See Anchor Sheet Fastening Options above.*



- Deck Type II:** Wood, Insulated
- Deck Description:** ¹⁹/₃₂" or greater plywood or wood plank
- System Type B(1):** Base layer of insulation mechanically fastened; optional top layer adhered with approved asphalt.

All General and System Limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam II, White Line Minimum 1.2" thick	1, 3, 5 or 10	1:2 ft ²
ACFoam II Minimum 1.4" thick	1, 3, 5 or 10	1:4 ft ²
ENRGY-2, ENRGY-3 Minimum 1.4" thick	1, 3, 5 or 10	1:2 ft ²
UltraGard Gold Minimum 1.3" thick	1, 3, 5 or 10	1:2 ft ²
ACFoam Composite Minimum 1.5" thick	1, 3, 5 or 10	1:4 ft ²
ConPerl, EnergyGuard Perlite, Fesco Board, Armor Board Regular, Esgard, Wood Fiberboard, EnergyGuard Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber, Structodek Minimum 1" thick	1, 3, 5 or 10	1:2 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
ConPerl, EnergyGuard Perlite, Fesco Board, Retrofit Minimum ½" thick	N/A	N/A
ACFoam Composite Minimum 1.5" thick	N/A	N/A

Note: Apply optional top layer of insulation shall be adhered with approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as the base layer shall only be used as the base layer with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side face down.

Base Sheet: (Optional) One ply of Glass-Base, Base-N-Ply, Versa-Base, Versa-Smooth, Awaplan VersaFlex, or Vapor-Chan adhered to the substrate with a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.



Ply Sheet: One or more plies of Tam-Glass Premium, Tam-Ply IV, Glass Base, Base-N-Ply, Awaplan VersaFlex, Awaplan Versa-Smooth, or Versa-Base adhered with a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: Awaplan Premium, Awaplan Premium FR, Awaplan 170, Awaflex, Awaflex FR,, Awaplan 170 FR, Awaplan Versa-Smooth, Awaplan VersaFlex, or Versa-Cap FR adhered with a full mopping of approved asphalt applied at 400° F at the point of contact and at a rate of 20-40 lbs./sq.; or Awaplan Heat Welding or Versa-Smooth adhered by torch.

Surfacing: Optional to mineral surfaced Membranes. Required for smooth surfaced membranes:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Tam-Pro FR Aluminum Coating applied at 1½ gal./sq. or Tam-Pro 846 Fibered Emulsion Coating at 3 gal./sq.

Maximum Design Pressure: -45 psf; (See General Limitation #9.)



Deck Type 1I: Wood, Insulated

Deck Description: $1\frac{9}{32}$ " or greater plywood or wood plank. Plywood shall be attached to 2" x 4" wood supports spaced 24" o.c. using wood screws spaced 6" o.c. at perimeters and intermediate supports.

System Type B(2): Base layer of insulation mechanically fastened; top layer adhered with approved asphalt.

All General and System Limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam II, ENRGY-2, ENRGY-3, PSI-25 Minimum 1.5" thick	5 or 8	1:1.33 ft²

Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
High Density Wood Fiberboard Minimum $\frac{1}{2}$ " thick	N/A	N/A

Note: Apply optional top layer of insulation shall be adhered with approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as the base layer shall only be used as the base layer with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side face down.

Base Sheet: (Optional) One ply of Glass-Base, Base-N-Ply, Versa-Base, Versa-Smooth, Awaplan VersaFlex, or Vapor-Chan adhered to the substrate with a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: One or more plies of Tam-Glass Premium, Tam-Ply IV, Glass Base, Base-N-Ply, Awaplan VersaFlex, Awaplan Versa-Smooth, or Versa-Base adhered with a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: Awaplan Premium, Awaplan Premium FR, Awaplan 170, Awaflex, Awaflex FR,, Awaplan 170 FR, Awaplan Versa-Smooth, Awaplan VersaFlex, or Versa-Cap FR adhered with a full mopping of approved asphalt applied at 400° F at the point of contact and at a rate of 20-40 lbs./sq.; or Awaplan Heat Welding or Versa-Smooth adhered by torch.



Surfacing:

Optional to mineral surfaced Membranes. Required for smooth surfaced membranes:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Tam-Pro FR Aluminum Coating applied at 1½ gal./sq., or Tam-Pro 846 Fibered Emulsion Coating at 3 gal./sq.

Maximum Design Pressure:

-60 psf (See General Limitation #7.)



Deck Type 1I: Wood, Insulated
Deck Description: ¹⁹/₃₂" or greater plywood or wood plank
System Type C: All layers of insulation simultaneously mechanically fastened.

All General and System Limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam II, White Line Minimum 1.2" thick	N/A	N/A
UltraGard Gold Minimum 1.3" thick	N/A	N/A
ENRGY-2, ENRGY-3, PSI-25 Minimum 1.4" thick	N/A	N/A

Note: All layers shall be simultaneously attached; see top layer below for fasteners and density.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ConPerl, EnergyGuard Perlite, Fesco Board, Armor Board Regular, Esgard, Fiberboard, EnergyGuard Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber Minimum 1" thick	1, 3, 5 or 10	1:2 ft ²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional) One ply of Glass-Base, Base-N-Ply, Versa-Base, Versa-Smooth, Awaplan VersaFlex, or Vapor-Chan adhered to the substrate with a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: One or more plies of Tam-Glass Premium, Tam-Ply IV, Glass Base, Base-N-Ply, Awaplan VersaFlex, Awaplan Versa-Smooth, or Versa-Base adhered with a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: Awaplan Premium, Awaplan Premium FR, Awaplan 170, Awaflex, Awaflex FR,, Awaplan 170 FR, Awaplan Versa-Smooth, Awaplan VersaFlex, or Versa-Cap FR adhered with a full mopping of approved asphalt applied at 400° F at the point of contact and at a rate of 20-40 lbs./sq.; or Awaplan Heat Welding or Versa-Smooth adhered by torch.



Surfacing:

Optional to mineral surfaced Membranes. Required for smooth surfaced membranes:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Tam-Pro FR Aluminum Coating applied at 1½ gal./sq., or Tam-Pro 846 Fibered Emulsion Coating at 3 gal./sq.

Maximum Design Pressure:

-45 psf;(See General Limitation #9.)



Deck Type 1I: Wood, Insulated

Deck Description: Minimum $1\frac{5}{32}$ " or greater plywood or wood plank. Plywood shall be attached to 2" x 4" wood supports spaced 24" o.c. using wood screws spaced 6" o.c. at perimeters and intermediate supports.

System Type D: Base sheet attached over insulation.

All General and System Limitations apply.

One or more layers of any of the following insulations adhered to deck:

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam II, White Line Minimum 1.2" thick	N/A	N/A
UltraGard Gold Minimum 1.3" thick	N/A	N/A
ENRGY-2, ENRGY-3, PSI-25 Minimum 1.4" thick	N/A	N/A
ConPerl, EnergyGuard Perlite, Fesco Board Minimum $\frac{3}{4}$ " thick	N/A	N/A
Armor Board Regular, Esgard, Fiberboard, EnergyGuard Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber, Structodek Minimum $\frac{1}{2}$ " thick	N/A	N/A

Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Base Sheet: One ply of Tamko Glass-Base, Versa-Base, Awaflex, Versa-Flex, Vapor-Chan or Base-N-Ply fastened to the deck as described below:

Fastening: Attach anchor sheet using #12 or #14 Dekfast Fasteners with Hex Plates or SFS #12 HD Insulfixx S or Buildex Accutrak Fasteners and 3" Square Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.

Ply Sheet: (Optional) One or more plies of Tam-Glass Premium, Tam-Ply IV, Glass Base, Base-N-Ply, Awaplan Versa-Smooth, Awaplan VersaFlex, or Versa-Base adhered with a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.



Membrane:

Awaplan Premium, Awaplan Premium FR, Awaplan 170, Awaflex, Awaflex FR,, Awaplan 170 FR, Awaplan Versa-Smooth, Awaplan VersaFlex, or Versa-Cap FR adhered with a full mopping of approved asphalt applied at 400° F at the point of contact and at a rate of 20-40 lbs./sq.; or Awaplan Heat Welding or Versa-Smooth adhered by torch.

Surfacing:

Optional to mineral surfaced Membranes. Required for smooth surfaced membranes:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq.
2. Tam-Pro FR Aluminum Coating applied at 1½ gal./sq., or Tam-Pro 846 Fibered Emulsion Coating at 3 gal./sq.

Maximum Design Pressure:

-60 psf; (See General Limitation #7.)



Deck Type 1: Wood, Non-insulated

Deck Description: Minimum $1\frac{5}{32}$ " or greater plywood or wood plank. Plywood shall be attached to 2" x 4" wood supports spaced 24" o.c. using wood screws spaced 6" o.c. at perimeters and intermediate supports.

System Type E: Base sheet mechanically fastened.

All General and System Limitations apply.

Anchor Sheet: One ply of Tamko Glass-Base, Vapor-Chan, Versa-Flex, Versa-Base, Versa-Smooth or Base-N-Ply fastened to the deck as described below:

Fastening: (*Option #1*) Attach anchor sheet using 11 ga. annular ring shank nails and 1-5/8" diameter tin caps spaced 9" o.c. in a 4" lap and 9" o.c. in two staggered rows in the center of the sheet. (*-52.5 psf, See General Limitation #7.*)
(*Option #2*) Attach anchor sheet using #12 or #14 Dekfast Fasteners with Hex Plates, SFS #12 or HD Insulfixx S, or Buildex Accutrak Fasteners and 3" Square Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet. (*-60.0 psf, See General Limitation #7.*)

Ply Sheet: (Optional) One or more plies of Tam-Glass Premium, Tam-Ply IV, Glass Base, Base-N-Ply, Awaplan Versa-Smooth, Awaplan VersaFlex, or Versa-Base adhered with a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: Awaplan Premium, Awaplan Premium FR, Awaplan 170, Awaflex, Awaflex FR., Awaplan 170 FR, Awaplan Versa-Smooth, Awaplan VersaFlex, or Versa-Cap FR adhered with a full mopping of approved asphalt applied at 400° F at the point of contact and at a rate of 20-40 lbs./sq.; or Awaplan Heat Welding or Versa-Smooth adhered by torch.

Surfacing: Optional to mineral surfaced Membranes. Required for smooth surfaced membranes:
1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Tam-Pro FR Aluminum Coating applied at 1½ gal./sq., or Tam-Pro 846 Fibered Emulsion Coating at 3 gal./sq.

Maximum Design Pressure: See Base Sheet Fastening Options above



Deck Type 1: Wood, Non-insulated

Deck Description: Minimum $1\frac{5}{32}$ " or greater plywood or wood plank. Plywood shall be attached to 2" x 4" wood supports spaced 24" o.c. using wood screws spaced 6" o.c. at perimeters and intermediate supports.

System Type E(2): Base sheet mechanically fastened.

All General and System Limitations apply.

Anchor Sheet: One ply of Tamko Glass-Base, Vapor-Chan, Versa-Flex, Versa-Base, Versa-Smooth or Base-N-Ply fastened to the deck as described below:

Fastening: (*Option #1*) One ply of Red Rosin sheet loose laid over deck. Followed by anchor sheet attached using Simplex Mega Cap Nails spaced 9" o.c. in a 4" lap and 9" o.c. in two staggered rows in the center of the sheet. (*-45 psf, See General Limitation #7.*)

(*Option #2*) Attach anchor sheet using Simplex Mega Cap Nails spaced 9" o.c. in a 4" lap and 9" o.c. in two staggered rows in the center of the sheet. (*-60 psf, See General Limitation #7.*)

Ply Sheet: (Optional) One or more plies of Tam-Glass Premium, Tam-Ply IV, Glass Base, Base-N-Ply, Awaplan Versa-Smooth, Awaplan VersaFlex, or Versa-Base adhered with a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: Awaplan Premium, Awaplan Premium FR, Awaplan 170, Awaflex, Awaflex FR., Awaplan 170 FR, Awaplan Versa-Smooth, Awaplan VersaFlex, or Versa-Cap FR adhered with a full mopping of approved asphalt applied at 400° F at the point of contact and at a rate of 20-40 lbs./sq.; or Awaplan Heat Welding or Versa-Smooth adhered by torch.

Surfacing: Optional to mineral surfaced Membranes. Required for smooth surfaced membranes:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Tam-Pro FR Aluminum Coating applied at 1½ gal./sq. or Tam-Pro 846 Fibered Emulsion Coating at 3 gal./sq.

Maximum Design Pressure: See Base Sheet Fastening Options above



Membrane Type: SBS
Deck Type 1: Wood, Non-insulated
Deck Description: $\frac{19}{32}$ " or greater plywood or wood plank
System Type: Tile Underlayment, Base Sheet mechanically attached.

All General and System Limitations shall apply.

Anchor sheet: Tamko No. 30 UL, Type 43 Coated Base, Base-N-Ply®, Vapor-Chan™, or Versa-Base™ base sheet applied with a minimum 2" side lap and a minimum 6" end lap. Base sheet may be applied at a right angle (90°) to the slope of the deck with approved annular ring shank nails and tin caps at a fastener spacing of 6" o.c. at the 2" side lap, and two 12" o.c. staggered rows along the center of the sheet.

Ply Sheet: (Optional) One or more plies Tam-Ply IV™ or Tam-Glass Premium™ sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Cap Sheet: One ply Awaplan Premium™, Awaplan 170™, Awaflex, Tamko ASTM Slate Surface or Tamko ASTM Tile Underlayment. Cap sheet may be applied at a right angle (90°) to the slope of the deck* adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. Cap sheet shall be back nailed to deck with approved annular ring shank nails and tin caps at a maximum 12" o.c. at the side laps and 6" o.c. at the end laps. No nails or tin caps shall be exposed.

*Cap Sheet may also be installed parallel to the slope of the roof (i.e. strapping). If membrane or cap sheet is strapped, then anchor sheet and ply sheet must also be strapped.

Maximum Design Pressure: Refer to Tile Manufacturer's NOA.

Maximum Slope: Must Comply with Roofing Application Standard RAS 118, RAS 119, RAS 120 and Applicable Building Code.



WOOD DECK SYSTEM LIMITATIONS:

1. A slip-sheet is required with Ply 4 and Ply 6 when used as a mechanically fastened base or anchor sheet.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 04-0506.03
Expiration Date: 05/23/07
Approval Date: 07/01/04
Page 19 of 19