



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

**Kaycan  
1 Memorial Drive.  
Richford, VT 05476**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code. This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: 10" Vented Vinyl Soffit**

**APPROVAL DOCUMENT:** Drawing No. **KBP-DC-103**, Sheets 1 of 1, titled "10 inches Vented Vinyl Soffit" dated 12/04/05 with no revisions, prepared by Kaycan Building Products signed and sealed by A. N. Reeves PE, bearing the Miami-Dade County Product Control Approval stamp with the NOA number and approval date by the Miami-Dade County Product Control Division.

**MISSILE IMPACT RATING: None**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved or MDCPCA", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of this page, evidence page as well as approval document mentioned above.

The submitted documentation was reviewed by **Candido F. Font PE.**

*[Handwritten signature]*  
04/20/06



**NOA No: 05-0804.03  
Expiration Date: April 20, 2011  
Approval Date: April 20, 2006  
Page 1**

Kaycan.

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

**A. DRAWINGS**

1. Drawing No.**KBP-DC-104**, Sheets 1 of 1, titled "10 inches Full O Vent Vinyl Soffit " dated 08/13/98 with no revisions, prepared by Kaycan Building Products signed and sealed by A.N. Reeves, P.E.

**B. TESTS**

	<b>Laboratory</b>	<b>Test</b>	<b>Date</b>	<b>Signature</b>
1.	AT-55983.01-106-18	ASTM D3679	01/03/06	J. A. Reed, PE.
2.	AT-55983.01-106-18	ASTM G155	01/03/06	J. A. Reed, PE.
3.	AT-55983.01-106-18	ASTM D638	01/03/06	J. A. Reed, PE
4.	AT-55983.01-106-18	ASTM D2843	01/03/06	J. A. Reed, PE.
5.	AT-55983.01-106-18	ASTM D1929	01/03/06	J. A. Reed, PE
6.	AT-55983.01-106-18	ASTM D635	01/03/06	J. A. Reed, PE
7.	AT-55981.02-122-18	PA 202 & 203	07/15/05	S. A. Urich, PE

**C. CALCULATION**

1. Fastener Installation Analysis, sheets 1 through 3, dated 07/27/05, project No. 05020010 signed and sealed by A. N. Reeves PE.

**D. QUALITY ASSURANCE**

1. Building Code Compliance Office.


**E. STATEMENTS**

1. Code compliance letters issued by H. R. Engineering, Inc. dated 08/02/05, signed and sealed by A. N. Reeves, PE.
2. No financial interest letter issued by H. R. Engineering Inc, dated 07/21/05 signed by A. N. Reeves PE and notarized by C. R. King.
3. Test compliance letter issued by Architectural Testing on 07/27/05, signed and sealed by S. M. Urich PE.




04/20/06


**Candido F. Font PE.**  
**Sr. Product Control Examiner**  
**NOA No: 05-0804.03**  
**Expiration Date: April 20, 2011**  
**Approval Date: April 20, 2006**




**PANEL CROSS SECTION**  
NOT TO SCALE




**INSTALLATION DETAIL SECTION B-B**  
NOT TO SCALE



**PANEL DETAILS**  
NOT TO SCALE



**INSTALLATION PLAN, LOOKING UP A-A**  
NOT TO SCALE



**VINYL SOFFIT INSTALLATION - 10" VENTED**  
NOT TO SCALE

**GENERAL NOTES**

1. THE ABOVE INSTALLATION HAS ALLOWABLE DESIGN WIND PRESSURES OF +55.0 & -35.0 PSF.
2. SOFFIT MATERIAL: KAYCAN VINYL SOFFIT IS MANUFACTURED FROM A FORMULATED P.V.C. POWDER COMPOUND MEETING THE SPECIFICATIONS OF ASTM D3679.
3. INSTALLATION FASTENERS ARE GALVANIZED STEEL ROOFING NAILS 1 1/2" LONG WITH 1/8" DIAMETER SHANKS AND 3/8" DIAMETER HEADS.
4. THIS PRODUCT IS DESIGNED TO MEET THE FLORIDA BUILDING CODE. WOOD/CBS OVERHANG CONSTRUCTION BY OTHERS, MUST BE ANCHORED PROPERLY TO TRANSFER LOADS TO THE STRUCTURE.
5. FASTENERS SHALL BE LISTED AND SPACED AS SHOWN ON DETAILS. FASTENERS EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING.
6. OVERHANG RECEIVING VINYL SOFFIT SHALL BE CHECKED FOR STRUCTURAL INADEQUACY, CRACKS OR DEFECTS THAT SHALL BE ELIMINATED.
7. OVERHANG WHERE VINYL SOFFIT SHALL BE INSTALLED MUST BE DESIGNED BY A PROFESSIONAL PER THE FLORIDA BUILDING CODE.
8. INSTALLATION OF SOFFIT ACCESSORIES AND ACCESSORIES SUCH AS CORNER POSTS, STARTER STRIPS, AND TRIM AROUND OPENINGS SHALL BE DONE IN ACCORDANCE WITH THE FLORIDA BUILDING CODE AND THE MANUFACTURER'S INSTRUCTIONS.

Approved as complying with the Florida Building Code  
Date 04/20/06  
NOA# 03-0804.03  
Miami Dade Product Control Division  
By: [Signature]

D5 SOFFIT 10" SOLID AND VENTED  
PRODUCT CALIPER - .044 ± .003  
UNDEVELOPED LENGTH - 14.000"

KAYCAN BUILDING PRODUCTS			
This Drawing and/or Design is the property of Kaycan Building Products and is not to be copied or used by others without the expressed written consent of Kaycan Building Products.			
Drawn By	Date 12/4/2005	10" VENTED	
Checked By	Date	VINYL SOFFIT	
Approved By	Date	Scale FULL	Reference
Sheet 1 of 1		Drawing Number KBP-DC-103	

Allen M. Reeves  
21 MARCH 2006