



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Neogard div of Jones-Blair
2728 Empire Central
Dallas, TX 75235**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Elasta-Gard

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.

The submitted documentation was reviewed by Jorge L. Acebo



**NOA No.: 05-1102.07
Expiration Date: 04/13/11
Approval Date: 04/13/06
Page 1 of 3**

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Maintenance Coating
Material: Polyurethane Elastomeric
Maximum Design Pressure N/A
Fire Classification: See Limitation #1

SCOPE:

This approves “**Elasta-Gard**” as a maintenance roof coating system as manufactured by Neogard div of Jones-Blair, as described in this Notice of Acceptance.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Asphalt Technologies	NDJB-007-02-01	ASTM D 6083 TAS 114(H)	08/22/05

PHYSICAL PROPERTIES OF COMPONENTS:

Trade names: **7419 PermaGard Base Coat**
Thickness: See Description Below.
Specifications: ASTM D 6083, FBC (HVHZ) TAS 114(H) Delamination
Description: A black single component aromatic solvent based polyurethane elastomeric coating membrane that is applied at an application rate of: 0.5 gal./100 ft² minimum.

- SBS Roofs: Apply to a minimum thickness of 8 dry mils
- EPDM Roofs: Apply to a minimum thickness of 8 dry mils
- TPO Roofs: Apply to a minimum thickness of 8 dry mils
- PVC Roofs: Apply to a minimum thickness of 8 dry mils

Container Size: 5 and 55 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly System’s Product Control Notice of Acceptance where it exceeds standards of this NOA..



NOA No.: 05-1102.07
Expiration Date: 04/13/11
Approval Date: 04/13/06
Page 2 of 3

Trade names: **70611 PermaThane Top Coat**
70612 PermaThane Top Coat
70613 PermaThane Top Coat

Thickness: See Description Below.

Specifications: ASTM D 6083, FBC (HVHZ) TAS 114(H) Delamination

Description: A white, gray or tan single component aromatic solvent based polyurethane elastomeric coating membrane that is applied at an application rate of: 1.5 gal./100 ft² minimum.

- SBS Roofs: Apply to a minimum thickness of 16 dry mils
- EPDM Roofs: Apply to a minimum thickness of 16 dry mils
- TPO Roofs: Apply to a minimum thickness of 16 dry mils
- PVC Roofs: Apply to a minimum thickness of 16 dry mils

Container Size: 5 and 55 gallons. Note all precautions on container.

Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly System's Product Control Notice of Acceptance where it exceeds standards of this NOA..

MAINTENANCE COATING APPLICATION:

Preparation: Remove all loose gravel, dirt, dust and any foreign matter that may inhibit adhesion of coating by vacuuming, sweeping, power brooming or power washing. Repair all blisters and delaminations.

Coating Application: Coat clean and dry existing roof with PermaGard Base Coat at a minimum rate of: 0.5 gal/sq.(Apply to a minimum thickness of 8 dry mils)

Apply PermaThane Top Coat onto PermaGard Base Coat at a minimum rate of: 1.5 gal/sq.(Apply to a minimum thickness of 16 dry mils)

LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
2. **Elasta-Gard** shall not be applied in inclement weather conditions.
3. **Elasta-Gard** shall only be applied to EPDM, PVC, TPO and SBS roofing only.
4. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list the products listed herein as part of their roof assemblies Notice of Acceptance.
5. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to BCCO upon request.
6. All approved products listed herein shall be labeled in compliance with TAS 121.
7. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
8. **Elasta-Gard** shall be applied in accordance with manufacturer's published application instructions and limitations.
9. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 05-1102.07
Expiration Date: 04/13/11
Approval Date: 04/13/06
Page 3 of 3