



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

**CertainTeed Corporation  
1400 Union Meeting Road  
Blue Bell, PA 19422**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

**DESCRIPTION: Grand Manor Shingle, Carriage House Shingle and Centennial Slate Asphalt Shingles**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This renews NOA #04-0616.01 and consists of pages 1 through 5.  
The submitted documentation was reviewed by Alex Tigera.



**NOA No.:06-0110.09  
Expiration Date: 07/26/11  
Approval Date: 04/27/06  
Page 1 of 5**

## ROOFING SYSTEM APPROVAL

**Category:** Roofing  
**Sub-Category:** 07310 Asphalt Shingles  
**Materials:** Laminate  
**Deck Type:** Wood

### 1. SCOPE

This revises **Grand Manor Shangle, Carriage House Shangle and Centennial Slate** Asphalt Shingles as manufactured by **CertainTeed Corporation (PA)** as described in Section 2 of this Notice of Acceptance.

### 2. PRODUCT DESCRIPTION

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Carriage House Shangle™	18" x 36"	TAS 110	A heavy weight, fiberglass reinforced laminated asphalt shingle.
Grand Manor Shangle	18" x 36"	TAS 110	A heavy weight, fiberglass reinforced laminated asphalt shingle.
Centennial Slate Shingle™	18" x 36"	TAS 110	A heavy weight, fiberglass reinforced laminated asphalt shingle.

### 3. EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Center for Applied Engineering	Uplift and wind driven rain resistance.	TAS 100	04/28/04
Underwriters Laboratories, Inc.	Wind uplift resistance	TAS 107	10/03/03
	Material properties 03NK29847 (Centennial)	ASTM D 3462 TAS 107	02/13/06 10/03/03
PRI Asphalt Technologies, Inc.	CTC-009-02-01 (Centennial)	TAS 100	04/28/04

### 4. LIMITATION

- 4.1 Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 4.2 Shall not be installed on roof mean heights in excess of 33 ft.
- 4.3 All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.



NOA No.:06-0110.09  
 Expiration Date: 07/26/11  
 Approval Date: 04/27/06  
 Page 2 of 5

**5 INSTALLATION**

- 5.1 Shingles shall be installed in compliance with Roofing Application Standard RAS 115.
- 5.2 Flashing shall be in accordance with Roofing Application Standard RAS 115
- 5.3 The manufacturer shall provide clearly written application instructions.
- 5.4 Exposure and course layout shall be in compliance with Detail 'A', attached.
- 5.5 Nailing shall be in compliance with Detail 'B', attached.

**6 LABELING**

- 6.1 Shingles shall be labeled with the Miami-Dade Logo or the wording "Miami-Dade County Product Control Approved".


**7 BUILDING PERMIT REQUIREMENTS**

- 7.1 Application for building permit shall be accompanied by copies of the following:
  - 7.1.1 This Notice of Acceptance.
  - 7.1.2 Any other documents required by the Building Official or the applicable code in order to properly evaluate the installation of this system.

**8 MANUFACTURING PLANTS**

- 8.1 Oxford, NC


**DETAIL 'A'**




**GRAND MANOR**



### DETAIL 'A' (CON'T)




CARRIAGE HOUSE




CENTENNIAL SLATE




### DETAIL 'B'



GRAND MANOR



CARRIAGE HOUSE



CENTENNIAL

END OF THIS ACCEPTANCE

