



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

**Warrior Roofing Manufacturing, Inc.  
3050 Warrior Road  
P.O. Box 40185  
Tuscaloosa, AL 35404**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Mineral Surface Roll Roofing**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This New NOA consists of pages 1 through 2.

The submitted documentation was reviewed by Jorge L. Acebo



**NOA 06-0113.03  
Expiration Date: 06/08/11  
Approval Date: 06/08/06  
Page 1 of 2**

## ROOFING COMPONENT APPROVAL

Category: Roofing  
Sub-Category: Underlayment  
Material: Asphalt

### SCOPE:

This approves **Mineral Surface Roll Roofing**, as manufactured by Warrior Roofing Manufacturing, Inc. and described in this Notice of Acceptance, designed to comply with the High Velocity Hurricane Zone of the Florida Building Code. This product is for use with approved prepared roof assemblies where ASTM D 249 Type I underlayment is specified. ( See limitations below)

### PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Mineral Surface Roll Roofing	36" x 36' rolls	ASTM D 249 Type I ASTM D 6380 M II	Mineral granules surfaced asphalt saturated felt underlayment.

### LIMITATIONS:

1. Fire classification is not part of this acceptance.
2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable Building Codes.

### INSTALLATION:

Warrior Roofing Manufacturing, Inc's Mineral Surface Roll Roofing shall be installed in strict compliance with applicable Building Codes.

### LABELING:

All packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo and a yellow line in the center of the roll to identify the ASTM Standard designation.

### BUILDING PERMIT REQUIREMENTS:

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this material.

### EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Asphalt Technologies, Inc.	WRMI-003-02-01	ASTM D 249 Type I ASTM D 6380 M II	06/24/05

**END OF THIS ACCEPTANCE**



NOA 06-0113.03  
Expiration Date: 06/08/11  
Approval Date: 06/08/06  
Page 2 of 2