



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Gambale SRL
Corso Italia, 538
44043 Mirabella
Ferrara, Italy**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Gambale SRL Coppo Portoghese Concrete Roof Tile

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 4.

The submitted documentation was reviewed by Alex Tigera.



**NOA No.: 06-0209.03
Expiration Date: 07/13/11
Approval Date: 07/13/06
Page 1 of 4**

ROOFING ASSEMBLY APPROVAL

Category: Roofing
Sub Category: Roofing Tiles
Material: Concrete

1. SCOPE

This new roofing system using **Coppo Portuguese Tile**, as manufactured by **Gambale SRL** as described in Section 2 of this Notice of Acceptance. For locations where the pressure requirements, as determined by applicable Building Code does not exceed the design pressure values obtained by calculations in compliance with RAS 127 using the values listed in section 4 herein. The attachment calculations shall be done as an uplift based system.

2. PRODUCT DESCRIPTION

<u>Manufactured by Applicant</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Coppo Portuguese	l = 16- $\frac{1}{2}$ " w = 10- $\frac{3}{4}$ " varying thickness	TAS 112	High profile one-piece, extruded concrete roof tile. For mortar, adhesive set, or mechanically attached applications.
Trim Pieces	Length: varies Width: varies varying thickness	TAS 112	Accessory trim, concrete roof pieces for use at hips, rakes, ridges and valley terminations. Manufactured for each tile profile.

2.1 COMPONENTS OR PRODUCTS MANUFACTURED BY OTHERS

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>	<u>Manufacturer</u>
PolyproAH 160	N/A	TAS 101	Two part polyurethane foam adhesive.	Polyfoam Products, Inc.

2.2 SUBMITTED EVIDENCE:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Architectual Testing	55633.01-122-18	TAS 100	August 2005
Architectual Testing	55633.01-122-18	TAS 101	August 2005
Architectual Testing	55633.01-122-18	TAS 102	August 2005
Architectual Testing	55633.01-122-18	TAS 112	August 2005



NOA No.: 06-0209.03
Expiration Date: 07/13/11
Approval Date: 07/13/06
Page 2 of 4

3. LIMITATIONS

- 3.1 Fire classification is not part of this acceptance.
- 3.2 For mortar or adhesive set tile applications, a static field uplift test shall be performed in accordance with RAS 106.
- 3.3 Applicant shall retain the services of a Miami-Dade County Certified Laboratory to perform quarterly test in accordance with PA 112, appendix 'A'. Such testing shall be submitted to the Building Code Compliance Office for review.
- 3.4 Minimum underlayment shall be in compliance with the applicable Roofing Applications Standards listed section 4.1 herein.
- 3.5 30/90 hot mopped underlayment applications may be installed perpendicular to the roof slope unless stated otherwise by the underlayment material manufacturers published literature.
- 3.6 This acceptance is for wood deck applications. Minimum deck requirements shall be in compliance with applicable building code.

4. INSTALLATION

- 4.1 Coppo Portuguese Concrete Roof Tile and its components shall be installed in strict compliance with Roofing Application Standard RAS 120.
- 4.2 Data For Attachment Calculations

Table 1: Average Weight (W) and Demensions (l x w) From PA 101 Testing			
TileProfile	Weight-W (lbf)	Length-l (ft)	Width-w (ft)
Coppo Portuguese	9.60	1.375	.896


Table 2: Minimum Characteristic Resistance Load - F' (lbf) from Single Patty Adhesive Set System		
Tile Profile	Tile Application	Attachment Resistance
Coppo Portuguese	Adhesive Set ¹	70.3
1. Polyfoam Products PolyproAH160 avg weight of patty 35grams		

Table 3: Minimum Characteristic Resistance Load - F' (lbf) For Mechanically Attached Systems		
Tile Profile	Tile Application	Attachment Resistance
Coppo Portuguese	Two #10 x 2-3/4" Tru-Fast self drilling screws per tile	28.36 ¹
1. Installation with 3-1/2" tile headlap and fasteners are located a min. of 2-1/2" from head of tile.		



5. LABELING

All tiles shall bear the imprint or identifiable marking of the manufacturer's name or logo (See **Detail Below**), or following statement: "Miami-Dade County Product Control Approved".



COPPO PORTUGHESE CONCRETE TILE LABEL (LOCATED ON UNDERSIDE OF TILE)


6. BUILDING PERMIT REQUIREMENTS

6.1 Application for building permit shall be accompanied by copies of the following:

6.1.1 This Notice of Acceptance.

6.1.2 Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this system.

PROFILE DRAWINGS



**COPPO PORTUGHESE CONCRETE ROOF TILE
END OF THIS ACCEPTANCE**



**NOA No.: 06-0209.03
Expiration Date: 07/13/11
Approval Date: 07/13/06
Page 4 of 4**