



MIAMI-DADE COUNTY
 BUILDING CODE COMPLIANCE OFFICE (BCCO)
 PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
 METRO-DADE FLAGLER BUILDING

140 WEST FLAGLER STREET, SUITE 1603
 MIAMI, FLORIDA 33130-1563
 (305) 375-2901 FAX (305) 375-2908

www.miamidade.gov

NOTICE OF ACCEPTANCE (NOA)

Jordan's Aluminum, Inc.
5731 Dewey Street
Hollywood, Florida 33023

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Extruded Bertha Aluminum Bahama Shutter

APPROVAL DOCUMENT: Drawing No. 06-038, titled "Extruded Bertha Bahama Shutter", sheets 1 through 9 of 9, prepared by Tilteco, Inc., dated March 17, 2006, signed and sealed by Walter A. Tillit Jr., P.E., bearing the Miami-Dade County Product Control Approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: Large and Small Missile Impact

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of this page 1, evidence submitted page E-1 as well as approval document mentioned above. The submitted documentation was reviewed by **Helmy A. Makar, P.E., M.S.**



Helmy A. Makar
 12/11/2006

NOA No 06-0403.08
Expiration Date: 12/11/2011
Approval Date: 12/11/2006
 Page 1

Jordan's Aluminum, Inc.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. *Drawing No. 06-038, titled " Extruded Bertha Bahama Shutter ", sheets 1 through 9 of 9, prepared by Tilteco, Inc., dated March 17, 2006, signed and sealed by Walter A. Tillit Jr., P.E.*

B. TESTS

1. *See Association's generic approval under 05-0237.*

C. CALCULATIONS

1. *See Association's generic approval under 05-0237.*

D. QUALITY ASSURANCE

1. *By Miami-Dade County Building Code Compliance Office.*

E. MATERIAL CERTIFICATIONS

1. *See Association's generic approval under 05-0237.*

F. STATEMENTS

1. *Release letter issued by American Shutter Systems Association, Inc., dated March 15, 2006, certifying this product to meet the criteria of product tested and approved, and allowing Jordan's Aluminum, Inc. to use the test results approved under Miami-Dade County Approval No. 05-0237, signed by Legny Santana.*
2. *Acknowledgment letter by Jordan's Aluminum, Inc., dated February 20, 2006, signed by Glenn Jordan.*
3. *Letter issued by Tiltico, Inc., dated March 23, 2006, certifying that the drawing (No. 06-038) prepared for Jordan's Aluminum, Inc., signed and sealed by Walter A. Tillit Jr., P.E. is engineering wise identical to American Shutter Systems Association, Inc. generic drawing (No. 05-094).*
4. *Acceptance Letter issued to Mr. Glenn Jordan December 09, 2006 and returned signed by Mr. Glenn Jordan on December 11, 2006, indicating to please issue the proposed Notice of Acceptance as submitted and reviewed.*



Helmy A. Makar, P.E., M.S.
Product Control Examiner
NOA No 06-0403.08
Expiration Date: 12/11/2011
Approval Date: 12/11/2006

GENERAL NOTES:

1. EXTRUDED BERTHA BAHAMA SHUTTER SHOWN ON THIS PRODUCT APPROVAL DOCUMENT (P. A. D.) HAS BEEN VERIFIED FOR COMPLIANCE IN ACCORDANCE WITH THE 2004 EDITION OF THE FLORIDA BUILDING CODE.
THIS BAHAMA SHUTTER SYSTEM MAY BE INSTALLED AT HIGH VELOCITY HURRICANE ZONES. DESIGN WIND LOADS SHALL BE DETERMINED AS PER SECTION 1620 OF THE ABOVE MENTIONED CODE. IN ORDER TO VERIFY THAT ANCHORS ON THIS P.A.D., AS TESTED, WERE NOT OVERSTRESSED, A 33% INCREASE IN ALLOWABLE LOADS FOR WIND LOADS WAS NOT USED IN THEIR ANALYSIS. HOWEVER, FOR LAG SCREWS INTO WOOD, A 1.60 WIND LOAD DURATION FACTOR WAS USED TO CALCULATE SCREWS SPACINGS.
EXTRUDED BERTHA BAHAMA SHUTTER'S ADEQUACY FOR HAS BEEN VERIFIED IN ACCORDANCE WITH SECTION 1609.1.4 OF THE ABOVE MENTIONED CODE AS PER ATL REPORTS #0923.01-97 AND #0309.01-04 AS PER PROTOCOLS TAS-201, TAS-202 AND TAS-203.
2. ALL ALUMINUM EXTRUSIONS SHALL BE ALUMINUM ASSOCIATION 6063-T6 ALLOY AND TEMPER, WITH $F_y = 25.0$ ksi MINIMUM (UNLESS OTHERWISE NOTED).
3. ALL SCREWS TO BE STAINLESS STEEL 304 OR 316 SERIES W/ 50 ksi YIELD STRENGTH AND 90 ksi TENSILE STRENGTH OR CORROSION RESISTANT COATED CARBON STEEL AS PER DIN 50018.
4. BOLTS TO BE ALUMINUM ASSOCIATION 2024-T4 ALLOY AND TEMPER, ASTM A-307 GALVANIZED STEEL, OR AISI 304 SERIES STAINLESS STEEL WITH 36 ksi MINIMUM YIELD STRENGTH.
5. ALL ALUMINUM POP RIVETS TO BE 5052 ALUMINUM ALLOY WITH ALUMINUM MANDREL.
6. ANCHORS TO WALL SHALL BE AS FOLLOWS: (UNLESS OTHERWISE NOTED)
 - (A) TO EXISTING POURED CONCRETE: (Min. $f'_c=3145$ p.s.i.)
 - 1/4" ϕ TAPCON ANCHORS AS MANUFACTURED BY I.T.W. BUILDDEX.
 - 1/4" ϕ x 7/8" CALK-IN ANCHORS AS MANUFACTURED BY THE POWERS FASTENERS, INC.

NOTES:

- A.1) MINIMUM EMBEDMENT OF TAPCON ANCHORS INTO POURED CONCRETE IS 1 1/2".
- A.2) CALK-IN ANCHORS SHALL BE ENTIRELY EMBEDDED INTO THE POURED CONCRETE. NO EMBEDMENT INTO STUCCO SHALL BE PERMITTED.
1/4" ϕ -20 SCREWS USED SHALL BE 1 1/2" LONG MINIMUM SHOULD STUCCO EXIST AND 1" MINIMUM FOR WALLS WITH NO STUCCO.
- A.3) IN CASE THAT PRECAST STONE, PRECAST CONCRETE PANELS, OR PAVERS BE FOUND ON THE EXISTING WALL OR FLOOR, ANCHORS SHALL BE LONG ENOUGH TO REACH THE MAIN STRUCTURE BEHIND SUCH PANELS. ANCHORAGE SHALL BE AS INDICATED ON NOTES A.1) & A.2) ABOVE.
- (B) TO EXISTING CONCRETE BLOCK WALL:
 - 1/4" ϕ TAPCON ANCHORS AS MANUFACTURED BY I.T.W. BUILDDEX.
 - 1/4" ϕ x 7/8" CALK-IN ANCHORS AS MANUFACTURED BY THE POWERS FASTENERS, INC.

NOTES:

- B.1) MINIMUM EMBEDMENT OF TAPCON ANCHORS INTO THE CONCRETE BLOCK UNIT SHALL BE 1 1/4".
- B.2) CALK-IN ANCHORS SHALL BE ENTIRELY EMBEDDED INTO THE CONCRETE BLOCK UNIT. NO EMBEDMENT INTO STUCCO SHALL BE PERMITTED. 1/4" ϕ -20 SCREWS USED SHALL BE 1 1/2" LONG MINIMUM SHOULD STUCCO EXIST AND 1" MINIMUM FOR WALLS WITH NO STUCCO.

B.3) IN CASE THAT PRECAST STONE OR PRECAST CONCRETE PANELS BE FOUND ON THE EXISTING WALL, ANCHORS SHALL BE LONG ENOUGH TO REACH THE MAIN STRUCTURE BEHIND SUCH PANELS. ANCHORAGE SHALL BE AS INDICATED ON NOTES B.1) & B.2) ABOVE.

(C) ANCHORS SHALL BE INSTALLED FOLLOWING ALL OF THE RECOMMENDATIONS AND SPECIFICATIONS OF THE ANCHOR'S MANUFACTURER.

7. EACH SHUTTER SHALL HAVE A LEGIBLE AND READILY VISIBLE MARKING INSTRUCTING OWNER OR TENANT TO SECURE SHUTTER WITH SIDE & SILL BRACKETS DURING PERIODS OF HURRICANE WARNINGS.

8. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO VERIFY THE SOUNDNESS OF THE STRUCTURE WHERE SHUTTER IS TO BE ATTACHED TO INSURE PROPER ANCHORAGE. CONTRACTOR TO SEAL/CAULK ALL SHUTTER COMPONENT EDGES WHICH REMAIN IN PERMANENT AND CONTINUOUS CONTACT WITH THE BUILDING TO PREVENT WIND/RAIN INTRUSION. CAULK AND SEAL SHUTTER TRACKS ALL AROUND FULL LENGTH. THIS SHUTTER SHALL ONLY BE ATTACHED TO CONCRETE, BLOCK OR WOOD FRAME BUILDINGS.

9. EXTRUDED BERTHA BAHAMA SHUTTER'S INSTALLATION SHALL COMPLY WITH SPECS INDICATED IN THIS DRAWING PLUS ANY BUILDING AND ZONING REGULATIONS PROVIDED BY THE JURISDICTION WHERE PERMIT IS APPLIED TO.

10. (a) THIS P.A.D. PREPARED BY THIS ENGINEER IS GENERIC AND DOES NOT PROVIDE INFORMATION FOR A SITE SPECIFIC PROJECT; i.e. WHERE THE SITE CONDITIONS DEVIATE FROM THE P.A.D.

(b) CONTRACTOR TO BE RESPONSIBLE FOR THE SELECTION, PURCHASE AND INSTALLATION INCLUDING LIFE SAFETY OF THIS PRODUCT, BASED ON THIS P.A.D., PROVIDED HE/SHE DOES NOT DEVIATE FROM THE CONDITIONS DETAILED ON THIS DOCUMENT. CONSTRUCTION SAFETY AT SITE IS THE CONTRACTOR'S RESPONSIBILITY.

(c) THIS P.A.D. WILL BE CONSIDERED INVALID IF ALTERED BY ANY MEANS.

(d) SITE SPECIFIC PROJECTS SHALL BE PREPARED BY A FLORIDA REGISTERED ENGINEER OR ARCHITECT WHICH WILL BECOME THE ENGINEER OF RECORD (E.O.R.) FOR THE PROJECT AND WHO WILL BE RESPONSIBLE FOR THE PROPER USE OF THE P.A.D. ENGINEER OF RECORD, ACTING AS A DELEGATED ENGINEER TO THE P.A.D. ENGINEER SHALL SUBMIT TO THIS LATTER THE SITE SPECIFIC DRAWINGS FOR REVIEW.

(e) THIS P.A.D. SHALL BEAR THE DATE AND ORIGINAL SEAL AND SIGNATURE OF THE PROFESSIONAL ENGINEER OF RECORD THAT PREPARED IT.






11. SHUTTER'S MANUFACTURER LABEL SHALL BE PLACED ON THE EXPOSED SURFACE OF THE BAHAMA FRAME (E) OR (C). ONE LABEL SHALL BE PLACED FOR EVERY OPENING. LABEL SHALL READ AS FOLLOWS:
JORDAN'S ALUMINUM, INC.
HOLLYWOOD, FL.
MIAMI-DADE COUNTY PRODUCT CONTROL APPROVED.

F.B.C. (High Velocity Hurricane Zone)

Approved as complying with the
Florida Building Code
Date 12/11/2006
NOA# 06-0403-08
Miami Dade Product Control
Division
By Helmut A. Miller

[Signature]
3/27/06

 TILTECO INC. TILLIT TESTING & ENGINEERING COMPANY 6355 N.W. 36th St., Ste. 305, VIRONIA GARDENS, FLORIDA 33166 Phone: (305)871-1530 • Fax: (305)871-1531 EB-0006719 WALTER A. TILLIT Jr., P. E. FLORIDA Lic. # 44167 © 2004 TILTECO INC.		ASSA / EXTRUDED BERTHA BAHAMA SHUTTER		DRAWN BY: S.M.	
		JORDAN'S ALUMINUM, INC. (ASSA # 124) 5731 DEWEY STREET HOLLYWOOD, FL. 33023 PH. #(954)986-1329, FAX#(954)986-1349		3/17/06 DATE	
				06-038 DRAWING No	
REV. No	DESCRIPTION	DATE	REV. No	DESCRIPTION	DATE
1	-	-	3	-	-
2	-	-	4	-	-
					SHEET 1 OF 9



A1 REGULAR INTERIOR MULLION

6005-T5 Alum. ALLOY
SCALE: 1/2" = 1"

A2 HEAVY INTERIOR MULLION

6005-T5 Alum. ALLOY
SCALE: 1/2" = 1"

B FEMALE HINGE







SCALE: 1/2" = 1"

C 1" B. O. FEMALE HINGE

SCALE: 1/2" = 1"

D FLAT FEMALE HINGE

SCALE: 1/2" = 1"



E BAHAMA MALE TOP FRAME

SCALE: 1/2" = 1"

F SNAP CAP

SCALE: 1/2" = 1"

G BAHAMA FRAME

SCALE: 1/2" = 1"

G1 ALTERNATE BAHAMA FRAME





SCALE: 1/2" = 1"

H CORNER KEY

1" LONG
SCALE: 1/2" = 1"


N WALL MOUNT Alum. BRACKET

7" LONG
SCALE: 1/2" = 1"




O BUILD-OUT Alum. BRACKET

7" LONG
SCALE: 1/2" = 1"



P BUILD-OUT SIDE BRACKET

7" LONG
SCALE: 1/2" = 1"



Q SILL ANGLE

SCALE: 1/2" = 1"

I HALF SHUTTER BLADE

SCALE: 1/2" = 1"

J SHUTTER BLADE

SCALE: 1/2" = 1"

SHUTTER BLADE ELEVATION

SCALE: 1/2" = 1"




[Signature]
3/2/06

COMPONENTS




Approved as complying with the Florida Building Code
Date: 12/11/2006
NDAL 06-0403.08
Miami Code Product Control
Division:
By: *[Signature]*

F.B.C. (High Velocity Hurricane Zone)

 TILTECO INC. TILLIT TESTING & ENGINEERING COMPANY 6355 N.W. 36th St., Ste. 305, VIRGINIA GARDENS, FLORIDA 33166 Phone: (305)871-1530, Fax: (305)871-1531 EB-0006719 WALTER A. TILLIT Jr., P. E. FLORIDA Lic. # 44167 © 2004 TILTECO INC.		ASSA / EXTRUDED BERTHA BAHAMA SHUTTER		DRAWN BY: S.M.	
		JORDAN'S ALUMINUM, INC. (ASSA # 124) 5731 DEWEY STREET HOLLYWOOD, FL. 33023 PH. # (954) 986-1329, FAX # (954) 986-1349		3/17/06 DATE	
REV. No	DESCRIPTION	DATE	REV. No	DESCRIPTION	DATE
1	-	-	3	-	-
2	-	-	4	-	-
					06-038 DRAWING No
					SHEET 2 OF 9





NOTE:
E. D. = 3 1/2" Min.



Approved as complying with the Florida Building Code
Date: 12/11/2006
NOA: 06-0403-08
Miami Code Product Control
Division
By: *Heinz A. Miller*

F.B.C. (High Velocity Hurricane Zone)


<p>TILTECO INC. TILLIT TESTING & ENGINEERING COMPANY 6385 N.W. 36th. St., Ste. 305, VIRGINIA GARDENS, FLORIDA 33166 Phone: (305)871-1530, Fax: (305)871-1531 EB-0006719 WALTER A. TILLIT Jr., P. E. FLORIDA Lic. # 44167 © 2004 TILTECO INC.</p>		<p>ASSA / EXTRUDED BERTHA BAHAMA SHUTTER</p> <p>JORDAN'S ALUMINUM, INC. (ASSA # 124) 5731 DEWEY STREET HOLLYWOOD, FL. 33023 PH. (954)986-1329, FAX (954)986-1349</p>		<p>DRAWN BY: S.M.</p> <p>3/17/06 DATE</p> <p>06-038 DRAWING No</p> <p>SHEET 3 OF 9</p>	
REV. No	DESCRIPTION	DATE	REV. No	DESCRIPTION	DATE
1	-	-	3	-	-
2	-	-	4	-	-




SECTION C - C (WALL MOUNT)
 HURRICANE POSITION
 SCALE: 3/8" = 1"

SECTION D - D (BUILD-OUT)
 HURRICANE POSITION
 SCALE: 3/8" = 1"


SECTION E - E (BUILD-OUT)
 HURRICANE POSITION
 SCALE: 3/8" = 1"



(K) .875" SERRATED TUBE
 INSIDE ARM
 6063-T6 ALLOY
 SCALE: 3/8" = 1"



(L) 1" SERRATED TUBE
 OUTSIDE ARM
 6063-T6 ALLOY
 SCALE: 3/8" = 1"



(M) CAMEL BACK HINGE
 3003-H14 Alum. ALLOY
 SCALE: 3/8" = 1"


NOTE:
 E. D. = 3 1/2" Min.

3/27/06


Approved as complying with the Florida Building Code
 Date: 12/11/2006
 NOAH: 06-0403-08
 Miami North Product Control
 Division
 By: *Helmut A. Miller*

F.B.C. (High Velocity Hurricane Zone)

 TILLIT TESTING & ENGINEERING COMPANY 6355 N.W. 36th St., Ste. 305, VIRGINIA GARDENS, FLORIDA 33168 Phone: (305)871-1530, Fax: (305)871-1531 EB-0006719 WALTER A. TILLIT Jr., P. E. FLORIDA Lic. # 44167 © 2004 TILTECO INC.		ASSA / EXTRUDED BERTHA BAHAMA SHUTTER		DRAWN BY: S.M.	
		JORDAN'S ALUMINUM, INC. (ASSA # 124) 5731 DEWEY STREET HOLLYWOOD, FL. 33023 PH. (954)986-1329, FAX (954)986-1349		3/17/06 DATE	
REV. No	DESCRIPTION	DATE	REV. No	DESCRIPTION	DATE
1	-	-	3	-	-
2	-	-	4	-	-
06-038 DRAWING No					SHEET 4 OF 9




MULTIPLE UNIT



SINGLE UNIT


ELEVATIONS

N. T. S.



DETAIL 1

SCALE : 1/2" = 1"




Handwritten signature and date: 3/27/06

Approved as complying with the Florida Building Code
 Date: 12/11/2006
 NOA# 06-0403-08
 Miami Dade Product Control
 Division
 By: *Handwritten signature*


F.B.C. (High Velocity Hurricane Zone)

TILTECO INC.
 TILLIT TESTING & ENGINEERING COMPANY
 6355 N.W. 36th St., Ste. 305, VIRGINIA GARDENS, FLORIDA 33146
 Phone : (305)871-1830 . Fax : (305)871-1831
 EB-0006719
 WALTER A. TILLIT JR., P. E.
 FLORIDA Lic. # 44167
 © 2004 TILTECO INC.

ASSA / EXTRUDED BERTHA BAHAMA SHUTTER		DRAWN BY: S.M.	
JORDAN'S ALUMINUM, INC. (ASSA # 124) 5731 DEWEY STREET HOLLYWOOD, FL 33023 PH. # (954) 986-1329, FAX # (954) 986-1349		3/17/06 DATE	
		06-038 DRAWING No	
REV. No	DESCRIPTION	DATE	REV. No
1	-	-	3
2	-	-	4
		SHEET 5 OF 9	




SECTION F - F (TRAPPED MOUNT)
HURRICANE POSITION
SCALE: 3/8" = 1"




SECTION G - G
(TRAPPED MOUNT)
HURRICANE POSITION
SCALE: 3/8" = 1"

NOTE:
E. D. = 3 1/2" Min.



DETAIL 2 WALL MOUNT.
SCALE: 1/2" = 1"




DETAIL 3 TRAPPED
SCALE: 1/2" = 1"

Approved as complying with the
Florida Building Code
Date 12/11/2006
NOA# 06-0403-08
Miami Building Product Control
Division
By *Helmut A. Miller*


F.B.C. (High Velocity Hurricane Zone)

[Signature]
3/27/06


 TILTECO INC. TILLIT TESTING & ENGINEERING COMPANY 6325 N.W. 38th St., Ste. 305, VIRGINIA GARDENS, FLORIDA 33166 Phone: (305)871-1530 Fax: (305)871-1531 EB-0006719 WALTER A. TILLIT Jr., P. E. FLORIDA Lic. # 44167 © 2004 TILTECO INC.	ASSA / EXTRUDED BERTHA BAHAMA SHUTTER	DRAWN BY: S.M.																	
	JORDAN'S ALUMINUM, INC. (ASSA # 124) 5731 DEWEY STREET HOLLYWOOD, FL. 33023 PH. # (954) 986-1329, FAX # (954) 986-1349	DATE 3/17/06																	
<table border="1"> <thead> <tr> <th>REV. No</th> <th>DESCRIPTION</th> <th>DATE</th> <th>REV. No</th> <th>DESCRIPTION</th> <th>DATE</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>-</td> <td>-</td> <td>3</td> <td>-</td> <td>-</td> </tr> <tr> <td>2</td> <td>-</td> <td>-</td> <td>4</td> <td>-</td> <td>-</td> </tr> </tbody> </table>	REV. No	DESCRIPTION	DATE	REV. No	DESCRIPTION	DATE	1	-	-	3	-	-	2	-	-	4	-	-	DRAWING No 06-038
REV. No	DESCRIPTION	DATE	REV. No	DESCRIPTION	DATE														
1	-	-	3	-	-														
2	-	-	4	-	-														
		SHEET 6 OF 9																	




NON HURRICANE POSITION DETAIL: (74 m.p.h. OR LESS WIND SPEED)
SCALE: 3/8" = 1"




ALTERNATIVE 1
HURRICANE POSITION
SCALE: 3/8" = 1"



ALTERNATIVE 2
HURRICANE POSITION
SCALE: 3/8" = 1"



ALTERNATIVE 3
HURRICANE POSITION
SCALE: 3/8" = 1"



ALTERNATE NON HURRICANE POSITION DETAIL
SCALE: 3/8" = 1"

- NOTES :**
- INSTALLATIONS ARE ONLY VALID FOR INSTALLATIONS WITH DESIGN WIND LOADS LESS OR EQUAL THAN +62.0, -75.0 p.s.f. AND Max. SHUTTER SPAN AS PER SCHEDULES ON SHEET 9 OF 9.
 - NEW 2" x 6" P. T. TO BE SOUTHERN PINE No. 2, SURFACED DRY WITH 19% M. M. C. W/ SPECIFIC DENSITY OF 0.55.
 - FOR NEW WOOD FRAME CONSTRUCTION: WOOD MEMBERS TO BE SOUTHERN PINE No. 2, W/ SPECIFIC DENSITY OF 0.55 OR EQUAL.

WALL MOUNTING INSTALLATION & BUILD-OUT
- SECTION A
INSTALLATION DETAILS ON EXISTING WOOD BUILDINGS


Approved as complying with the Florida Building Code
Date: 12/11/2006
NOA# 06-0403-08
Miami Code Product Control
Division By: *Helmut A. Miller*

F.B.C. (High Velocity Hurricane Zone)

TILTECO INC.
TILLIT TESTING & ENGINEERING COMPANY
6355 N.W. 36th St., Ste. 305, VIRGINIA GARDENS, FLORIDA 33168
Phone: (305)871-1530 Fax: (305)871-1531
EB-0006719
WALTER A. TILLIT Jr., P. E.
FLORIDA Lic. # 44167
© 2004 TILTECO INC.


ASSA / EXTRUDED BERTHA BAHAMA SHUTTER		DRAWN BY: S.M.	
JORDAN'S ALUMINUM, INC. (ASSA # 124) 5731 DEWEY STREET HOLLYWOOD, FL 33023 PH. (954)986-1329, FAX (954)986-1349		3/17/06 DATE	
REV. No		06-038 DRAWING No	
1	DESCRIPTION	DATE	REV. No
2			
		SHEET 7 OF 9	

3/27/06




ALTERNATIVE 4A

FLOOR/CEILING MOUNTING INSTALLATION
- SECTION A SCALE: 1/4" = 1"




ALTERNATIVE 4B


INSTALLATION DETAILS ON EXISTING WOOD BUILDINGS



SECTION A-A
(WALL MOUNT)
 SCALE: 1/4" = 1"



SECTION B-B
(WALL MOUNT)
 SCALE: 1/4" = 1"



SECTION G-G
(FLOOR/CEILING MOUNT)
 SCALE: 1/4" = 1"

NOTES :

1. INSTALLATIONS ARE ONLY VALID FOR INSTALLATIONS WITH DESIGN WIND LOADS LESS OR EQUAL THAN +62.0, -75.0 p.s.f. AND Max. SHUTTER SPAN AS PER SCHEDULES ON SHEET 9 OF 9.
2. NEW 2" x 6" P. T. TO BE SOUTHERN PINE No. 2, SURFACED DRY WITH 19% M. M. C. W/ SPECIFIC DENSITY OF 0.55.
3. FOR NEW WOOD FRAME CONSTRUCTION: WOOD MEMBERS TO BE SOUTHERN PINE No. 2, W/ SPECIFIC DENSITY OF 0.55 OR EQUAL.

[Handwritten Signature]
 3/27/06

Approved as complying with the Florida Building Code
 Date: 12/11/2006
 NOAH 06-0403-08
 Miami Dade Product Control
 Division
 By: *[Handwritten Signature]*

F.B.C. (High Velocity Hurricane Zone)


TILECO INC.
 TILLIT TESTING & ENGINEERING COMPANY
 6395 N.W. 38th St., Ste. 305, VIRGINIA GARDENS, FLORIDA 33186
 Phone: (305)871-1530 Fax: (305)871-1531
 EB-0006719
 WALTER A. TILLIT JR., P. E.
 FLORIDA Lic. # 44167
 © 2004 TILECO INC.

ASSA / EXTRUDED BERTHA BAHAMA SHUTTER						DRAWN BY: S.M.
JORDAN'S ALUMINUM, INC. (ASSA # 124) 5731 DEWEY STREET HOLLYWOOD, FL. 33023 PH. (954)986-1329, FAX (954)986-1349						3/17/06 DATE
						06-038 DRAWING No
REV. No	DESCRIPTION	DATE	REV. No	DESCRIPTION	DATE	SHEET 8 OF 9
1	-	-	3	-	-	
2	-	-	4	-	-	

SCHEDULE # 1

MAXIMUM SINGLE UNIT FOR A CORRESPONDING DESIGN PRESSURE AND MOUNTING TYPE


DESIGN PRESSURE RATING (p.s.f.) AND CASE #	MAXIMUM UNIT WIDTH "W" (IN)	MAXIMUM SPAN "L" (IN)		
		W/O SIDE BRACKET	W/ SIDE BRACKET	MINIMUM SEPARATION TO GLASS (IN)
CASES I & II +56.0, -63.0	42"	52"	N/A	3 1/8"
CASES I & II +75.0, -100.0	42"	N/A	96"	2 1/8"



SCHEDULE # 1A

MAXIMUM MULTIPLE UNIT FOR A CORRESPONDING DESIGN PRESSURE AND MOUNTING TYPE

DESIGN PRESSURE RATING (p.s.f.) AND CASE #	MAXIMUM UNIT WIDTH "W" (IN)	MAXIMUM SPAN "L" (IN)			
		W/O SIDE BRACKET	W/ SIDE BRACKET	INTERIOR MULLION TYPE REQUIRED	MINIMUM SEPARATION TO GLASS (IN)
CASE I +50.0, -43.3	36 1/2"	72 1/2"	N/A	A1	2 1/2"
CASE I +62.0, -75.0	36 1/2"	N/A	83"	A2	2 3/8"
CASE II +62.0, -75.0	36 1/2"	N/A	84"	A2	2 3/8"



SCHEDULE # 2

LIMITATIONS FOR SINGLE AND MULTIPLE UNITS BAHAMA SHUTTER'S UNIT WIDTH (IN), SPAN L (IN) AND CORRESPONDING MAXIMUM DESIGN PRESSURE (p.s.f.) FOR THE INSTALLATION OF SIDE & SILL BRACKETS INTO CONCRETE & MASONRY BUILDINGS BY MEANS OF (3) 1/4" Ø x 7/8" CALK-IN ANCHORS *

MAXIMUM NEGATIVE DESIGN PRESSURE RATING (p.s.f.)	SINGLE UNITS				MULTIPLE UNITS			
	SIDE & SILL BRACKETS **				SIDE & SILL BRACKETS **			
	TO CONCRETE		TO BLOCK		TO CONCRETE		TO BLOCK	
	Max. "W"	Max. "L"	Max. "W"	Max. "L"	Max. "W"	Max. "L"	Max. "W"	Max. "L"
-55.7	42"	96"	42"	96"	36 1/2"	84"	36"	84"
-65.0	42"	96"	42"	96"	36 1/2"	84"	36"	72"
							31"	84"
-75.0	42"	96"	42"	96"	36 1/2"	83"	36 1/2"	62"
							27"	83"
-83.0	42"	96"	42"	96"	N/A	N/A	N/A	N/A
-100.0	42"	96"	42"	63"	N/A	N/A	N/A	N/A
			36"	73"				

SCHEDULE # 3

MAXIMUM ANCHOR SPACING AT TOP FEMALE HINGES (B), (C), OR (D) AS WELL AS SILL ANGLE (E) AT BOTTOM (AS APPLICABLE) FOR INSTALLATIONS INTO POURED CONCRETE HEADERS AND SILL ***

DESIGN PRESSURE RATING (p. s. f.)	SINGLE & MULTIPLE UNITS
	TOP & BOTTOM TO CONCRETE
ALL PRESSURES COVERED IN SCHEDULE # 1 & # 1A	9" O.C. TOP & 7" O.C. BOTTOM.

*** SEE SHEETS 7 & 8 OF 9 FOR ANCHOR SPACING FOR INSTALLATIONS INTO WOOD FRAME BUILDINGS.

* FOR ELCO PANELMATES ((3) 1/4" Ø W/ 1 7/8" PENETRATION) USED AT SILL & SIDE BRACKETS FOR INSTALLATIONS INTO WOOD. SEE SCHEDULES # 1 & # 1A FOR SHUTTER SIZE.

** IN ANY CASE, MAXIMUM "W" & "L" VALUES W/ CORRESPONDING DESIGN LOADS SHALL NOT EXCEED MAXIMUM VALUES INDICATED ON SCHEDULES # 1 & 1A.

Approved as complying with the Florida Building Code
 Date 12/11/2006
 NOA# 06-0403-08
 Miami Dade Product Control
 Division
 By *Helmy A. Mebr*

F.B.C. (High Velocity Hurricane Zone)

3/27/06

 TILTECO INC. TILLIT TESTING & ENGINEERING COMPANY 6385 N.W. 36th St., Ste. 308, VIRGINIA GARDENS, FLORIDA 33166 Phone: (305)871-1530 Fax: (305)871-1531 EB-0006719 WALTER A. TILLIT Jr., P. E. FLORIDA Lic. # 44167 © 2004 TILTECO INC.	ASSA / EXTRUDED BERTHA BAHAMA SHUTTER	DRAWN BY: S.M.
	JORDAN'S ALUMINUM, INC. (ASSA # 124) 5731 DEWEY STREET HOLLYWOOD, FL 33023 PH. # (954) 986-1329, FAX # (954) 986-1349	3/17/06 DATE
	06-038 DRAWING No	
		SHEET 9 OF 9